

CITY OF UNION CITY ADA TRANSITION PLAN NOVEMBER 2019



Contents

Introduction and Overview.....	4
APPLICABLE FEDERAL LAW.....	5
PROGRAM ACCESS.....	7
PUBLIC RIGHT-OF-WAY.....	8
AGENCY REQUIREMENTS.....	9
PURPOSE AND NEED OF THE TRANSITION PLAN.....	10
RELATIONSHIP OF SELF-EVALUATION & TRANSITION PLANS.....	10
IMPLEMENTATION OF TRANSITION PLAN.....	11
DESCRIPTION OF FACILITY ACCESSIBILITY.....	11
POLICIES, PROGRAMS AND PROCEDURES.....	11
ON-GOING ACCESSIBILITY IMPROVEMENTS.....	12
MEASURING THE SUCCESS OF THE TRANSITION PLAN.....	12
EFFECTIVE COMMUNICATION REQUIREMENTS.....	13
PROGRAM ACCESSIBILITY TOOLKIT.....	13
TELECOMMUNICATION DEVICES FOR THE DEAF (TDD'S).....	14
INFORMATION AND SIGNAGE.....	14
SELF EVALUATION OF PUBLIC BUILDINGS, OTHER CITY FACILITIES AND PARKS ACCESSIBILITY	15
PRIORITY AREAS FOR BUILDINGS, OTHER CITY FACILITIES AND PARKS.....	16
MAINTENANCE OF ACCESSIBLE FEATURES.....	18
REMEDATION PRIORITY.....	19
PROJECT SCHEDULE PERIODS.....	20
REMOVAL OF ARCHITECTURAL BARRIERS.....	20
PEDESTRIAN FACILITIES IN THE PUBLIC RIGHT-OF-WAY ACCESSIBILITY.....	21
SIDEWALKS, CURB RAMPS, CROSSWALKS AND PEDESTRIAN SIGNALS PROGRAMS.....	21
SELF-EVALUATION OF PEDESTRIAN ACCESS TO PUBLIC RIGHT-OF-WAY.....	22
STREET AND INTERSECTIONS PRIORITY.....	22
SELF-EVALUATION REPORTS.....	23
POLICIES FOR NEW CONSTRUCTION & ALTERATIONS.....	23
REPORTING.....	23

TRAINING	24
ESTIMATED CONSTRUCTION COSTS.....	24
RESPONSIBLE INDIVIDUAL	25
ATTACHMENT A - CITY GRIEVANCE FORMS AND POLICY.....	27
ATTACHMENT B – SELF EVALAUTION OF PUBLIC BUILDINGS, OTHER CITY FACILITIES AND PARKS ACCESSIBILITY.....	37
ATTACHMENT C - SELF-EVALUATION OF PEDESTRIAN ACCESS TO PUBLIC RIGHT-OF-WAY	73
ATTACHMENT D – PUBLIC INVOLVEMENT.....	146

The City of Union City ADA Transition Plan is the summary of a three-phase approach to evaluating accessibility of the community's infrastructure and achieving compliance with the Americans with Disabilities Act.

This plan includes documentation of the following:

- ✓ The purpose and need of the document, and a summary of applicable federal law related to accessibility
- ✓ Documentation of Union City's policies and procedures related to accessibility of public rights-of-way
- ✓ Project field review guide
- ✓ Complete inventory of sidewalks, curb ramps, buildings, other facilities and their condition
- ✓ Required elements of an ADA Transition Plan – public comments, grievance procedure, appointment of ADA Coordinator, etc.

Pursuant to Title II of the ADA, public entities are prohibited from discriminating on the basis of a disability. All programs, services and activities offered by the public entity must be accessible to persons with disabilities. To accomplish this, the U. S. Department of Justice developed regulations requiring the City to conduct a self-evaluation of the accessibility of its programs and services to determine whether issues of accessibility could be addressed through changes in the way such programs and services are provided. The City is obligated to remove physical barriers to accessibility when program changes cannot ensure access to services, programs, and activities in existing facilities. Realizing structural changes would take time and money to provide, the Department of Justice Regulations, Federal Register 28 CFR Part 35 states that "in the event that structural changes to facilities will be undertaken to achieve program accessibility, a public entity that employs 50 or more persons shall develop a Transition Plan setting forth the steps necessary to complete such changes." Additionally, "if a public entity has responsibility or authority over streets, roads, or walkways, its Transition Plan shall include a schedule for providing curb ramps or other sloped areas where pedestrian walks cross curbs, giving priority to walkways serving entities covered by the Act."

The ADA Regulations further require the Transition Plan to contain the following elements:

- A. A list of physical barriers in the public facilities that limit the accessibility of its programs, services, or activities to individuals with disabilities;
- B. A detailed description of the methods to be utilized to remove these barriers and make the facilities accessible;

- C. The schedule for taking the necessary steps to achieve compliance with Title II;
- D. The name of the official responsible for the plan's implementation;
- E. A schedule for providing curb ramps or other slopes areas where pedestrian walks cross curbs.
- F. The opportunity for the disability community and other interested parties to participate in the development of the Transition Plan.

Priorities should be given in the following order:

- 1. State and local government offices
- 2. Transportation
- 3. Places of public accommodation
- 4. Employers
- 5. Other areas (e.g., residential areas where people needing curb cuts reside)

APPLICABLE FEDERAL LAW

The legal background for ADA compliance is based on the following Acts and Regulations:

Architectural Barriers Act (ABA – originated 1968); Rehabilitation Act (1973) – Section 504 (49 CFR Part 27); Civil Rights Restoration Act (1987); Americans with Disabilities Act (ADA) (1990); and, DOJ Implementing Regulations (28 CFR 35) There are Five Titles of ADA: Title I Employment; Title II State & Local Governments (28 CFR Part 35); Title III Public Accommodations (retail, commercial, sports complexes, movie theaters, etc.) (28 CFR Part 36); Title IV Telecommunications; and, Title V, Misc., including requirements for the U.S. Access Board to develop design guideline. The focus for the City of Union City for ADA compliance is Title II.

All federal agencies recommitted to enforcing the enforcement of the ADA in July 2010.

Federal and State Agencies (on behalf of the federal government enforcing ADA) significant to be considered in the review for the City of Union City include: TDOT as the conduit for federal funds for the City as a recipient of Federal and State Funds; and, the DOJ for Title II Entities through Project Civic Access, and teamed with HUD on multi- family and housing authority cases.

Regulations and policies that must be ADA compliant were reviewed. City design standards, specifications and details were reviewed based on ADA guidance for *ADA Accessible Guidelines (ADAAG)*, and street designs based on *Proposed Right-of-Way Guidelines (PROWAG)*. The review for ADA compliance for written policies was determined on the use of detectable warnings, use of accessible pedestrian signals, designation of furniture and landscaping zones and shared use paths. The review was done in a manner to ensure all city-owned and operated parks comply with ADA guidance. Other compliance issues unveiled during the discovery process were reviewed. The *Uniform Federal Accessibility Standard (UFAS)*, developed by four (4) federal agencies should be considered but as a Title II city, Union City may prefer to defer to the ADAAG Guidelines. UFAS is

used by the federal government based on the Architectural Barriers Act of 1968. The Tennessee Department of Transportation (TDOT) adheres to the Federal Highway Administration's (FHWA) *Manual of Uniform Traffic Devices (MUTCD)*. The City's conformance with this guidance was evaluated for ADA compliance for traffic signals, signs and markings specifically for pedestrian pathways for crosswalks, pedestrian signals, signs markings and audible detection. Recommendations were made and are included in this *ADA Transition Plan*.

The ADA Transition Plan and Self Evaluation Services project is part of the City's public entities' program accessibility obligations. The Field Survey Report was developed to comply with the ADA Act of 1990, Section 504 of the Rehabilitation Act of 1973, and 2010 Standards and Accessibility guidelines for Pedestrian Facilities in the Public Right-of-Way ("PROWAG") and other relevant city, state or federal laws, rules or regulations.

Among other things, the *Americans with Disabilities Act (ADA)* ensures access to the built environment for people with disabilities. ADA Standards establish design requirements for the construction and alteration of facilities subject to the law. These enforceable standards apply to places of public accommodation, commercial facilities, and *state and local government facilities*. The *Architectural and Transportation Barriers Compliance Board (United States Access Board)* is the federal agency responsible for developing accessibility guidelines. The Access Board is responsible for developing and updating design guidelines known as the *ADA Accessibility Guidelines (ADAAG)*.

These guidelines are used by the Department of Justice (DOJ) and the Department of Transportation (DOT) in setting enforceable standards the public must follow. Both DOJ's and DOT's current ADA Standards are based on the Board's updated ADAAG. As a result, for the most part, these two sets of standards are very similar. However, each contains additional requirements specific to the facilities covered by the respective agencies. These additional requirements define the types of facilities covered, set effective dates, and provide additional scoping or technical requirements for those facilities. DOJ's ADA Standards apply to all facilities except public transportation facilities, which are subject to DOT's ADA

Standards. The edition of the ADA Standards provided on the Board's website includes DOJ's and DOT's additional provisions. The ADA standards are issued by the Department of Justice (DOJ) and the Department of Transportation (DOT) and apply to facilities covered by the ADA in new construction and alterations.

ADA consists of five titles outlining protections in the following areas:

1. Employment
2. State and local government services
3. Public accommodations
4. Telecommunications

5. Miscellaneous provisions

Title II of ADA pertains to the programs, activities and services public entities provide. As a public entity that employs 50 or more persons, the City of Union City must comply with this section of the Act as it specifically applies to public service agencies. Title II of ADA provides that, "...no qualified individual with a disability shall, by reason of such disability, be excluded from participation in or be denied the benefits of the services, programs, or activities of a public entity, or be subjected to discrimination by any such entity." (42 USC. Sec. 12132; 28 CFR. Sec. 35.130)

As required by Title II of ADA, 28 CFR. Part 35 Sec. 35.105 and Sec. 35.150, the City of Union City has conducted a self-evaluation of its facilities throughout the City and has developed this Transition Plan detailing how the organization will ensure those facilities are accessible to all individuals.

This Transition Plan and its implementation is overseen by the City of Union City ADA Coordinator, Jim Temple, Director of Planning and Codes, 408 S. Depot St., Union City, TN 38261, 731/885-0918 (Direct Office), 731/885-1341 (City Hall), 731-446-0848 (Cell), planning.codesdirector@unioncitytn.gov

PROGRAM ACCESS

The ADA's Section 202. Discrimination states:

... no qualified individual with a disability shall, by reason of such disability, be excluded from participation in or be denied the benefits of the services, programs, or activities of a public entity, or be subjected to discrimination by any such entity.

The ADA's Section 204 required that the U.S. Department of Justice (DOJ) promulgate implementing regulations by 26 July 1991, one year after enactment of the legislation. These regulations are 28 CFR 35, published on July 26, 1991. 28 CFR 35.149 states:

... no otherwise qualified individual with a disability shall, because a public entity's facilities are inaccessible to or unusable by individuals with disabilities, be excluded from participation in, or be denied the benefits of the services, programs, or activities of a public entity or be subjected to discrimination by any public entity. 28 CFR 35.150 states that: A public entity shall operate each service, program, or activity so that the service, program, or activity, when viewed in its entirety, is readily accessible to and usable by individuals with disabilities.

This statutory and regulatory language above describes what is known as "program access" – a situation where all programs are readily accessible to, and usable by qualified persons with disabilities. In addition, qualified students with disabilities must be provided with equal services in as integrated a setting as possible. The determination of what is an equal and integrated setting will

be made on a case-by-case basis. What is appropriate for one person with a specific impairment may not be useful or appropriate for another person with the same impairment.

Failure to provide "program access" is an illegal act of discrimination under Title II of the ADA. The City must identify and correct policies and practices that have the effect of discriminating against individuals with disabilities.

PUBLIC RIGHT-OF-WAY

Public right-of-way in the City of Union City includes roadways, trails, and their adjacent facilities that serve a transportation purpose. This includes sidewalks, curb ramps, pedestrian signals, crosswalks, and trails that provide a transportation route. Since the Tennessee Department of Transportation has adopted the requirements of PROWAG (Public Rights-of-Way Accessibility Guidelines), this report assumes all accessibility improvements are to be done within PROWAG.

AGENCY REQUIREMENTS

Under Title II, the City of Union City shall meet these general requirements:

- ✓ Must operate their programs so that, when viewed in their entirety, the programs are accessible to and useable by individuals with disabilities (28 C.F.R. Sec. 35.150).
- ✓ May not refuse to allow a person with a disability to participate in a service, program or activity simply because the person has a disability (28 C.F.R. Sec. 35.130 (a)).
- ✓ Must make reasonable modifications in policies, practices and procedures that deny equal access to individuals with disabilities unless a fundamental alteration in the program would result (28 C.F.R. Sec. 35.130(b) (7)).
- ✓ May not provide services or benefits to individuals with disabilities through programs that are separate or different unless the separate or different measures are necessary to ensure that benefits and services are equally effective (28 C.F.R. Sec. 35.130(b)(iv) & (d)).
- ✓ Must take appropriate steps to ensure that communications with applicants, participants and members of the public with disabilities are as effective as communications with others (29 C.F.R. Sec. 35.160(a)).
- ✓ Must designate at least one responsible employee to coordinate ADA compliance [28 CFR Sec. 35.107(a)]. This person is often referred to as the "ADA Coordinator." The public entity must provide the ADA coordinator's name, office address, and telephone number to all interested individuals [28 CFR Sec. 35.107(a)].
- ✓ Must provide notice of ADA requirements. All public entities, regardless of size, must provide information about the rights and protections of Title II to applicants, participants, beneficiaries, employees, and other interested persons [28 CFR Sec.35.106].
- ✓ The notice must include the identification of the employee serving as the ADA coordinator and must provide this information on an ongoing basis [28 CFR Sec. 104.8(a)].
- ✓ Must establish a grievance procedure. Public entities must adopt and publish grievance procedures providing for prompt and equitable resolution of complaints [28 CFR Sec. 35.107(b)]. This requirement provides for a timely resolution of all problems or conflicts related to ADA compliance before they escalate to litigation and/or the federal complaint process.

PURPOSE AND NEED OF THE TRANSITION PLAN

The major purpose of a Transition Plan as it relates to buildings and facilities owned and operated by a public entity is to document the existing barriers to persons with disabilities, and to propose the structural and non-structural steps to be undertaken to provide program accessibility. Many components contributed to the development of this Transition Plan including comprehensive surveys and evaluation of the architectural barriers present at City owned, operated, or utilized facilities. The term “facilities” is intended to include buildings, structures, or any part of real property that involves a specific use by persons. The surveying process was conducted between October 2019 and November 2019, leading up to the drafting of this Transition Plan.

It is important to note that for the purposes of this Transition Plan, the date of each accessibility survey serves as the “datum” point, indicative of the state of the facility as included in the accessibility reports. While the City has been making ongoing improvements and removing barriers on a continual basis, some physical improvements listed in the detailed surveys may have begun, been partially completed, or fully completed prior to the adoption of the Transition Plan.

The City of Union City has undertaken a comprehensive evaluation of its policies, programs, and facilities (both structural and transportation) to determine the extent to which individuals with disabilities may be restricted in their access to City services and activities.

This report describes the process developed to complete the evaluation of Union City’s activities, provides policy and program recommendations, and presents a Transition Plan for the modification of facilities and programs to ensure accessibility.

This document will guide the planning and implementation of necessary program and facility modifications. It is intended to be a living document, updated and refreshed as changes occur. The ADA Self-Evaluation and Transition Plan establishes the City’s commitment to the development and maintenance of policies, programs, and facilities that include all its citizenry.

RELATIONSHIP OF SELF-EVALUATION & TRANSITION PLANS

28 CFR 35.150 details the methods a public entity such as the City may use to provide program access. These include:

- ✓ Reassignment of services to accessible buildings;
- ✓ Delivery of services at alternate accessible sites;
- ✓ Alteration of existing facilities and construction of new facilities; or
- ✓ Any other methods that result in making its services, programs, or activities readily accessible to and usable by individuals with disabilities.

From an architectural standpoint, this requirement does not mean every building has to be accessible. However, every program must be accessible. The transition plan documents facility accessibility and provides a plan for making necessary changes.

One of the most important aspects of preparing a transition plan is assigning priorities to structural modifications necessary to achieve program access. Obviously, the highest priority items should be undertaken first, and the schedule for completion is dependent on these determinations.

IMPLEMENTATION OF TRANSITION PLAN

With the acceptance of the final Transition Plan by the City Council, the mitigation of physical barriers in facilities and the public rights-of-way will begin.

The City of Union City's final document shall be a living document, updated as improvements in accessibility are completed. The plan shall remain available for public information and inspection.

DESCRIPTION OF FACILITY ACCESSIBILITY

Determination that a facility, or part thereof, is accessible is based on the standards of the Americans with Disabilities Act Accessibility Guidelines (ADAAG), and the criteria established by this document. The ADAAG sets standards for accessibility of specific elements and establishes "scoping" requirements for new construction and remodeling. "Scoping" determines which elements need to be accessible for a given type of work.

Where the City undertakes new construction or modernization of facilities not restricted to accessibility work, modifications may be required that are not proposed in this transition plan.

Such work may also be triggered by the applicable state or local building codes. This future work is separate from the program access requirement addressed by the self-evaluation and transition plan.

POLICIES, PROGRAMS AND PROCEDURES

In 2019, the City conducted an evaluation of its policies, programs, and procedures to determine current levels of service and the extent to which its policies and programs created barriers to accessibility for persons with disabilities. Department staff provided information on the nature of the program, forms and methods used to advertise the program's services and activities, a profile of current participants, the types of equipment and materials used, testing and entrance requirements, the level of staff training, and any special modifications provided. It is the intent of the City to address many of the citywide programmatic accessibility barriers through the development of Administrative Directives.

Additionally, when a policy, program, or procedure creates an accessibility barrier unique to a department or a certain program, the City's ADA Coordinator will coordinate with the City's Engineering Consultant to address the matter in the most reasonable and accommodating manner.

The City has established a procedure for anyone wishing to file a complaint alleging discrimination based on disability in the provision of services, activities, programs or benefits by the City of Union City. These forms and procedure may be found in Attachment A.

Additionally, when a policy, program, or procedure creates an accessibility barrier unique to a department or a certain program, the City's ADA Coordinator will coordinate with the City's Public Works Department to address the matter in the most reasonable and accommodating manner.

The City has established a procedure for anyone wishing to file a complaint alleging discrimination based on disability in the provision of services, activities, programs or benefits by the City of Union City. These forms and procedure may be found in Attachment A.

ON-GOING ACCESSIBILITY IMPROVEMENTS

Opportunities for further improvement of City services and facilities for ADA compliance will continue to arise as advances are made in technology and the provision of programs for people with disabilities. Additionally, as the City acquires new facilities and develops new programs, it will be necessary to review each for access compliance. It is the intent of the City to keep its programs up to date through increased community involvement and partnerships with organizations of and those offering services to persons with disabilities. All new facilities must comply with ADA design standards for new construction throughout the entire facility and not just in the public access areas.

MEASURING THE SUCCESS OF THE TRANSITION PLAN

It is the intent of the City to periodically evaluate the success of improving access to its programs by compiling statistical measures of success. Examples of such measures of success include:

- ✓ Measuring the level of public participation in programs.
- ✓ Revising evaluation forms to include questions about how adequately special needs were met.
- ✓ Tracking the number of people with disabilities who participate in selected programs.
- ✓ Tracking the number of requests for programs that are accessible to people with disabilities.
- ✓ Tracking attendance and repeat registrants.
- ✓ Asking staff to evaluate the success of a program.
- ✓ Surveying program participants about desired improvements.
- ✓ Conducting an initial assessment/suggestion box program for accessibility.

- ✓ Soliciting feedback from personal contact (i.e., word-of-mouth).
- ✓ Comparing programs to goals and objectives published by the federal government.
- ✓ Preparing and distributing a participants' questionnaire to measure increases in participation, and, where appropriate, socialization, health, and self-esteem.

EFFECTIVE COMMUNICATION REQUIREMENTS

28 CFR § 35.163(a) requires the City to provide information to individuals with disabilities concerning accessible services, activities, and facilities.

28 CFR § 35.160 requires the City to take such steps as may be necessary to ensure communications with applicants, participants, and members of the public with disabilities are as effective as communications with others. The City of Union City's communication is designed for all citizens and interested parties.

28 CFR § 35.160 (b)(1) requires the City to furnish appropriate auxiliary aids and services when necessary to afford an individual with a disability an equal opportunity to participate in, and enjoy the benefits of the City's services, programs, or activities when viewed in their entirety.

Union City has a program to provide the necessary communication aids to citizens with needs for those aids. Citizens with those needs request the auxiliary aids and services by contacting the ADA Coordinator, Jim Temple, Director of Planning and Codes, 408 S. Depot St., Union City, TN 38261, 731/885-0918 (Direct Office), 731/885-1341 (City Hall), 731-446-0848 (Cell).

The City makes every effort to provide the auxiliary aid and/or service requested by the individual.

The City of Union City will generally, upon request, provide appropriate aids and services leading to effective communication for qualified persons with disabilities so they can participate equally in the City's programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to people who have speech, hearing, or vision impairments.

The following are primary sources for obtaining interpreter services:

PROGRAM ACCESSIBILITY TOOLKIT

To facilitate access to City programs by all citizens, the City will assemble a toolkit of information designed to assist its staff in communicating with and providing customer service to individuals with a variety of disabilities. The City will periodically review the components of the toolkit, as new technologies become available, to ensure the best types of technology are being used to improve accessibility to City services and programs.

TELECOMMUNICATION DEVICES FOR THE DEAF (TDD'S)

28 CFR § 35.161 requires that, where a public entity communicates with applicants and beneficiaries by telephone, TDD's or equally effective telecommunication systems be used to communicate with individuals with impaired speech or hearing.

The City of Union City, TN provides telephone emergency services by which individuals can seek immediate assistance from police, fire, ambulance, and other emergency services. This telephone emergency service -- including "911" services -- are an important public service whose reliability can be a matter of life or death.

INFORMATION AND SIGNAGE

28 CFR § 35.163 (b) requires a public entity to provide signage at all inaccessible entrances of each facility that directs users to an accessible entrance or to a location with information about accessible facilities. The City makes every effort to provide this signage at the appropriate locations.

SELF EVALUATION OF PUBLIC BUILDINGS, OTHER CITY FACILITIES AND PARKS ACCESSIBILITY

In 2019, the City of Union City conducted a self-evaluation of publicly accessible areas for each public building, other City facilities and parks. Assessment was conducted for the following locations:

1. Public Works Department
2. Central Fire Station (Fire Station #1)
3. City Hall/Municipal Building
4. Police Department
5. Parks and Recreation Department
6. Animal Control Shelter
7. Fifth Street Park
8. Veteran's Park
9. Nash Street Park
10. Kiwanis Park
11. Graham Park
12. Turf Management Department
13. Water Treatment Plant (Martin Luther King Jr Drive)
14. Wastewater Treatment Plant (Lynch Lane)
15. College Street Basketball Court

Each public area of accessibility was evaluated by guidance provided for one of four priorities by the Americans with Disabilities Accessibility Guidelines (ADAAG) denoting the priority for accessibility. The primary purpose of the self-evaluation survey was to inventory compliance for public buildings, other city facilities and parks and to identify remediation methods and costs necessary to provide accessibility to the public in publicly accessible areas for existing facilities. Public buildings, other City facilities and parks. Self-evaluation established the remediation work necessary to achieve removal of architectural barriers as described in the self-evaluation and as required by ADAAG and by the Department of Justice (DOJ) in its administration of ADA requirements. Collection was performed by field surveys using ArcGIS geodatabases using open source collection software to organize and memorialize the data sets. This allows querying of the data sets to provide grouping of the data for analysis such as costs, priorities, pedestrian traffic etc. Photographs and descriptions are provided. Barriers are organized by architectural element attribute and located by reference number. The complete self-evaluation survey for each facility is provided in Attachment B. A presentation of the collection attributes for each facility is provided in Attachment B along with a photo log of items requiring remediation for compliance to ADAAG along with costs. The elements and their related features addressed in the survey include:

- ✓ Parking Area Passenger
- ✓ Loading Zone
- ✓ Door Corridor or Aisle Curb Ramp Sidewalk Signage
- ✓ Exterior Ramp
- ✓ Telephone Hazards
- ✓ Exterior Stairway
- ✓ Interior Stairway
- ✓ Site Furnishings
- ✓ Interior Ramps
- ✓ Grandstand or Bleacher Multiple User Restrooms
- ✓ Swimming Pool Single User Restroom
- ✓ Drinking Fountain Eating or Dining Area
- ✓ Building Level Library Dressing or Locker Rooms Picnic Area

PRIORITY AREAS FOR BUILDINGS, OTHER CITY FACILITIES AND PARKS

The following priorities have been provided by ADAAG for accessibility of each publicly accessible area for each public building, other City facility and park.

- ✓ Priority 1 - Accessible approach and entrance
- ✓ Priority 2 - Access to goods and services
- ✓ Priority 3 - Access to public toilet rooms
- ✓ Priority 4 - Access to additional amenities

Priority 1 - Accessible approach and entrance

An accessible approach route from site arrival points and an accessible entrance should be provided for everyone, including the disabled. Priority 1 buildings and facilities are required to comply with the standards for accessible approach and entrance regarding all city programs, services, and activities. There should be an accessible route from site arrival points to include parking, passenger loading zones, public sidewalks and public transportation stops that do not require the use of stairs.

Priority 2 - Access to goods and services

The layout of the building should allow people with disabilities to obtain goods and services and to participate in activities without assistance. The accessible entrance should provide direct access to the main floor, lobby and elevator. All public spaces should have at least one access route.

Priority 3 - Access to public toilet rooms

When toilet rooms are open to the public, they should be accessible to people with disabilities. If toilet rooms are available to the public, at least one toilet room should be accessible, with either one for each sex, or one unisex. There should be signs at inaccessible toilet rooms that give directions to accessible toilet rooms. If not all toilet rooms are accessible, there should be a sign at the accessible toilet room with the International Symbol of Accessibility.

Priority 4 - Access to additional amenities

Access to additional amenities such as water fountains, public telephones and fire alarm systems should be provided. Assessment of priority 4 not a part of this plan.

Below is a summary of the estimated costs for remediation at each building, other facility and parks by ADAAG accessibility priority. Attachment B contains the detailed summary report for the accessibility remediation at each location.

REMEDATION ESTIMATED COSTS OF PUBLIC BUILDINGS, OTHER CITY FACILITIES AND PARKS ACCESSIBILITY UNION CITY SUMMARY OF REMEDIATION COSTS (ADAAG)

LOCATION	PRIOR- ITY 1	PRIOR- ITY 2	PRIOR- ITY 3	PRIOR- ITY 4	ESTI- MATED COSTS	%%%
Public Works Department	\$15,630	\$1,000	\$0		\$16,630	5.21%
Central Fire Station (Fire Station #1)	\$16,190	\$1,500	\$0		\$17,690	5.54%
City Hall/Municipal Building	\$25,510	\$2,000	\$50		\$27,560	8.63%
Police Department	\$12,140	\$3,500	\$100		\$15,740	4.93%
Parks and Recreation Department	\$4,200	\$0	\$200		\$4,400	1.38%
Animal Control Shelter	\$14,490	\$0	\$0		\$14,490	4.54%
Fifth Street Park	\$49,600	\$6,560	\$0		\$56,160	17.59%
Veteran's Park	\$12,330	\$0	\$50		\$12,380	3.88%
Nash Street Park	\$42,100	\$8,550	\$22,360		\$73,010	22.87%
Kiwanis Park	\$10,930	\$20,060	\$30,000		\$60,990	19.10%
Graham Park	\$10,800	\$1,200	\$7,580		\$19,580	6.13%
Turf Management Department	\$50	\$0	\$0		\$50	0.02%
Water Treatment Plant (Martin Lu- ther King Jr. Drive)	\$50	\$0	\$0		\$50	0.02%
Wastewater Treatment Plant (Lynch Lane)	\$50	\$0	\$0		\$50	0.02%
College Street Basketball Court	\$500	\$0	\$0		\$500	0.16%
Remediation Totals:	\$214,570	\$44,370	\$60,340		\$319,280	100.00%
%%%	67.20%	13.90%	18.90%		100.00%	

MAINTENANCE OF ACCESSIBLE FEATURES

Under ADA Title II 28 CFR § 35.133(a), the City must maintain in working condition those features of facilities and equipment that are required to be readily accessible to and usable by persons with disabilities. Isolated or temporary interruptions in service or access due to maintenance or repairs are not prohibited under 28 CFR. § 35.133(b). However, allowing obstructions or "out of service" equipment to persist beyond a reasonable period would violate this requirement, as would repeat mechanical failures due to improper or inadequate maintenance under 28 C.F.R. § 35.133 (Preamble).

The City of Union City will maintain a system of monitoring accessibility improvements at all City facilities to assure ongoing compliance with the ADA and ADA Accessibility Guidelines and take all reasonable steps to provide both programmatic and physical access for persons with disabilities. Programmatic requirements, such as the provision of TTY's, sign language interpreters and alternative written formats, will be monitored by the ADA Coordinator.

While physical access items will be reviewed and monitored at a general level by the ADA Coordinator, detailed monitoring of such items will be delegated to the City's Public Works Director. The Public Works Director will advise the Codes Director who will be responsible for scheduling and completing needed repairs and changes.

Maintenance of accessible features and specific conditions that should be maintained to provide physical accessibility include, but are not necessarily limited to, the following items:

1. Maintain exterior pathways and repair any surface irregularities that may become greater than 1/4" due to wear, settling or cracking and make other repairs to keep pathways from causing hazardous conditions.
2. Maintain accessible parking spaces with all appropriate signage and keep access aisles to the spaces and the main entrances clear and usable.
3. Maintain and replace as required all building signage directing persons with disabilities to accessible paths of travel and accessible entrances.
4. Maintain all doors providing primary accessibility in a fully operable and unlocked status during normal hours of operation of any facility. Facilities that do not have automatic doors will be converted as soon as possible. Maintain and monitor objects mounted on walls to protrude no more than 4" into paths of travel.
5. Maintain audible and visual fire alarms and pull stations to be fully operational.
6. Maintain all accessible plumbing fixtures, including toilets, urinals, lavatories, sinks, faucets, showers, and drinking fountains, to be fully operational and in compliance with accessibility codes.

7. Maintain all toilet accessories to be fully operational and mounted no more than 17"-19" from the floor to the toilet seat at all accessible restrooms.

REMEDIATION PRIORITY

The self-evaluation survey is intended to provide a baseline for planning purposes. The required work generated from the survey data was used to determine scope of work, budgets and schedule for architectural barrier removal projects. It is understood each project to remove architectural

barriers, as well as general modernization projects will review current conditions at the facilities and in specific areas of work to verify the conditions and work necessary. Recommended facility modifications form the basis for cost estimates. These modifications generally represent the best standard design solution to eliminate the identified architectural barrier. In some cases, the solution or cost may be based on specific knowledge of the site conditions, in other cases it is based on a standard approach or average cost for the type of work. Attachment B contains the detailed summary report for the remediation at each location.

The location priority of 1 through 3 are designated for each facility. Priority should be highest for locations that serve a larger number of residents and those that may be disabled. Location priority assignment is given to the locations as presented below. Priority should also be for ADAAG accessible service areas at each location for Priority 1 – Accessible Approach and Entrance and second to the Priority 2 – Access to and Services at all locations.

LOCATION	PRIORITY
Public Works Department	2
Central Fire Station (Fire Station #1)	3
City Hall/Municipal Building	2
Police Department	2
Parks and Recreation Department	2
Animal Control Shelter	3
Fifth Street Park	1
Veteran's Park	1
Nash Street Park	1
Kiwanis Park	1
Graham Park	1
Turf Management Department	3
Water Treatment Plant (Martin Luther King Jr. Drive)	3
Wastewater Treatment Plant (Lynch Lane)	3
College Street Basketball Court	1

PROJECT SCHEDULE PERIODS

The project schedule periods are distributed over twenty years:

Period	Start	End
A	January 2020	December 2020
B	January 2021	December 2021
C	January 2022	December 2022
D	January 2023	December 2023
E	January 2024	December 2024
F	January 2025	December 2025
G	January 2026	December 2026
H	January 2027	December 2027
I	January 2028	December 2028
J	January 2029	December 2029
K	January 2030	December 2030
L	January 2031	December 2031
M	January 2032	December 2032
N	January 2033	December 2033
O	January 2034	December 2034
P	January 2035	December 2035
Q	January 2036	December 2036
R	January 2037	December 2037
S	January 2038	December 2038
T	January 2039	December 2039

The City will schedule funding for budgeting remediation over a period of a suggested ten years to comply with the Title II requirements. This should be performed with emphasis on the location and accessibility priority presented in this report.

REMOVAL OF ARCHITECTURAL BARRIERS

The City will implement a staggered approach to make all buildings, other City facilities, and parks fully accessible according to ADAAG. The following criteria is the basis for prioritizing the removal of architectural barriers for buildings, facilities and parks:

- ✓ Program uniqueness: Some programs are unique to a building, facility, or park and cannot occur at another location;
- ✓ Level of use by the public: Buildings, facilities, and parks that receive a high level of public use will receive a high priority; and
- ✓ Geographic distribution: By selecting a range of buildings, facilities, and parks that are distributed throughout the City, the City can ensure maximum access for all residents.

PEDESTRIAN FACILITIES IN THE PUBLIC RIGHT-OF-WAY

ACCESSIBILITY

The purpose of this part of this plan is to ensure the City of Union City creates reasonable, accessible paths of travel in the public right-of-way for everyone, including people with disabilities. The self-evaluation identifies physical barriers and prioritizes improvements that should be made throughout the City. This Transition Plan describes the existing policies and programs to enhance overall pedestrian accessibility.

SIDEWALKS, CURB RAMPS, CROSSWALKS AND PEDESTRIAN SIGNALS PROGRAMS

Union City has several programs devoted to making the City's streets, sidewalks, crosswalks and pedestrian signals more accessible.

- ✓ New Development and Infill Program: New development projects and those projects occurring as infill or redevelopment are required to install sidewalks and ADA-compliant curb ramps.
- ✓ Citizen Request Program: Citizens can submit a request to have a new curb ramp installed or an existing curb ramp repaired at any location within the City.
- ✓ Annual Installation, Repair, and Maintenance Program: On an annual basis, the City's Public Works Department repairs sidewalks and installs new PROWAG-compliant curb ramps as part of routine maintenance.
- ✓ Street-Related Capital Improvement Projects: Sidewalks, curb ramps, crosswalks and pedestrian signals are installed and/or repaired in all street-related capital improvement projects (e.g., street widening or other street upgrades).
- ✓ Federally Aided Street Overlay Construction Projects: The City is required to include the retrofit of existing, non-compliant curb ramps to comply with prevailing PROWAG standards as part of federally aided street overlay projects. It is the goal of the City to continue its efforts to improve pedestrian accessibility.

SELF-EVALUATION OF PEDESTRIAN ACCESS TO PUBLIC RIGHT-OF-WAY

The guidance used in the evaluations are based on Public Right-of-Way Accessibility Guidelines (PROWAG) for Pedestrian Facilities in the Public Right-of-Way (ADA Guidelines) from the

U.S. Architectural and Transportation Barriers Compliance Board as well as the standards that the Tennessee Department of Transportation (TDOT) requires for compliance when more restrictive than PROWAG. The City of Union City has a two-tiered system to identify and assess obstacles in the public right-of-way:

1. Self-Evaluation of curb ramps, sidewalks, crosswalks, and pedestrian crossings at signalized intersections for compliance with PROWAG TDOT
2. Detailed Evaluation of Remediation, Costs of Remediation and Priority for Remediation

Self-Evaluation of the curb ramps, sidewalks, crosswalks and pedestrian signals was completed in November of 2019. The purpose of the evaluation was to determine which features are non-compliant to PROWAG and TDOT Guidelines which may be more restrictive, and to have the highest priority non-complying items under construction as soon as practical and develop a comprehensive overview of the complete pedestrian network. Detailed evaluation of remediation, costs of remediation and priority for remediation were also performed. The surveys provide the City an overview of the architectural barriers that prevent people with disabilities from using its pedestrian public rights-of-way and participating in its programs.

Photos and maps of each non-compliant curb ramp, sidewalk, crosswalk and pedestrian signal were annotated during the survey process and are included in the full report in Appendix C in digital form.

STREET AND INTERSECTIONS PRIORITY

The basis for assignment of remediation priority are

1. pedestrian traffic volume, and
2. where safety is a concern with higher volume vehicle traffic.

The main criteria for pedestrian accessibility priority for curb ramps and sidewalks is the volume of pedestrian traffic and the probable geographic locations where disabled citizens may use the pedestrian pathways. Higher priority should be assigned for crosswalks and pedestrian signals for non-compliant feature locations where there are high volumes of vehicle traffic on arterial and collector streets and safety is of greater concern.

Remediation priority for the attribute classes should be as follows:

Curb Ramps	1
Sidewalks	2
Pedestrian Signals	3
Crosswalks	4

SELF-EVALUATION REPORTS

A self-evaluation report has been produced for each curb ramp, sidewalk, crosswalk and pedestrian signal. Remediation methods, costs and priorities have been determined and presented in Attachment C. The self-evaluation report has been compiled for each feature in accordance with PROWAG and TDOT guidance for accessibility. Collection was performed using field surveys and ArcGIS geodatabases using open source collection software to organize and memorialize the data sets. This allows querying of the data sets to provide grouping of the data for analysis such as costs, priorities, pedestrian traffic etc. Photographs, descriptions and sketches are provided. Barriers are organized by architectural element attribute and located by reference number. A summary of the estimated remediation costs by street and barrier category priority has been provided below. The complete self-evaluation survey for each curb ramp, sidewalk, crosswalk and pedestrian signal is provided in Attachment C. A presentation of the collection attributes is provided as well in Attachment C along with a photo log of each item(s) requiring remediation for compliance to PROWAG and TDOT. Included in Attachment C are both a summary of the remediation locations by street and remediation costs plus a digital thumb drive that contains the detailed Self-Evaluation attributes.

POLICIES FOR NEW CONSTRUCTION & ALTERATIONS

To ensure the correct design of curb ramps, sidewalks, and crosswalks is applied in new construction and alterations, the City of Union City will adopt the Accessibility Guidelines for Pedestrian Facilities in the Public Right-of-Way. Intersection improvement projects or new construction projects that affect curb ramps, sidewalks, crosswalks and pedestrian signals will be built to these ADA design guidelines, where feasible and reasonable.

REPORTING

Union City will be using two methods to help keep the public and city officials up to date on the progress made in removing barriers. First Method: The Public Works Department will submit an annual report to the City Council. The report will summarize accomplishments from the previous year, plans for the current year and any anticipated challenges that need to be addressed. Second Method: The City of Union City's Website will have a separate section devoted to ADA rules, plans, contact information, policies, ordinances, and reports. The Annual Report to the city council will

also be posted here for public review. The website will also provide a method for concerns and complaints about accessibility city-wide. Complaints will be retrieved by the ADA Coordinator. Response will be made within 36 hours in the absence of unusual circumstances.

TRAINING

The City of Union City has initiated a training program to ensure its staff is prepared for implementation of the Public Facilities & Public Rights of Way transition plans. The plan considers types of training based on the level and type of involvement of each staff member with the ADA Transition Plan implementation. After the initial training, follow-up training will be provided on an annual basis. Overview Training: Department Heads and key management staff will attend a seminar covering the law and practical applications of the elements of the law.

Design Staff Training

Design Personnel will attend a seminar covering current ADA design practices and techniques to improve construction plans preparation and review as they relate to ADA Compliance. Inspection Staff Training: Inspection personnel and code enforcement personnel will attend a seminar covering inspection techniques for ADA Compliance. Construction Staff Training: Street and inspection personnel will attend a training session. This training session should include information on the techniques used to install sidewalks, curb ramps and other ROW appurtenances that comply with ADA regulations

ESTIMATED CONSTRUCTION COSTS

The project schedule periods are distributed over twenty years:

Period	Start	End
A	January 2020	December 2020
B	January 2021	December 2021
C	January 2022	December 2022
D	January 2023	December 2023
E	January 2024	December 2024
F	January 2025	December 2025
G	January 2026	December 2026
H	January 2027	December 2027
I	January 2028	December 2028
J	January 2029	December 2029
K	January 2030	December 2030
L	January 2031	December 2031
M	January 2032	December 2032
N	January 2033	December 2033
O	January 2034	December 2034
P	January 2035	December 2035

Q	January 2036	December 2036
R	January 2037	December 2037
S	January 2038	December 2038
T	January 2039	December 2039

The City should schedule funding for budgeting remediation over a period of a suggested ten years to comply with the Title II requirements.

RESPONSIBLE INDIVIDUAL

The official responsible for the implementation of the City of Union City's ADA Transition Plan for the pedestrian facilities in the public right-of-way is: Jim Temple, Director of Planning and Codes, 408 S. Depot St, Union City, TN 38261, 731/885-0918 (Direct Office), 731/885-1341 (City Hall), 731-446-0848 (Cell), planning.codesdirector@unioncitytn.gov

UNION CITY SUMMARY OF REMEDIATION COSTS (PROWAG)

Street	Broken Surface Material	Canopy	Cross Slope	Curb Ramp/Mid-block	Drive Ramp	Grass & Debris	Mailbox	Missing/ Narrow sidewalk/ curb	Other Obstacles	Pole	Run Slope	Scrub	Sidewalk Intrusions	Settling	Sign	Trees/ Vegetation	Upheaval/ Heaved	Total	%/%
East Reeffoot Avenue	\$49,850	\$0	\$0	\$12,050	\$434,300	\$3,300	\$11,300	\$6,000	\$900	\$2,700	\$0	\$0	\$0	\$13,200	\$1,450	\$0	\$1,750	\$536,800	10.36%
West Reeffoot Avenue	\$4,875	\$0	\$0	\$0	\$50,850	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$55,725	1.08%
East Main Street	\$56,450	\$0	\$0	\$0	\$21,550	\$2,650	\$0	\$600	\$0	\$0	\$0	\$300	\$0	\$6,300	\$1,300	\$0	\$0	\$89,150	1.72%
West Main Street	\$40,500	\$2,500	\$0	\$4,350	\$26,850	\$700	\$0	\$0	\$0	\$0	\$0	\$250	\$200	\$0	\$2,300	\$0	\$0	\$77,650	1.50%
North Drive	\$575	\$0	\$0	\$3,100	\$1,200	\$200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$600	\$0	\$0	\$0	\$5,675	0.11%
Westview Drive	\$10,500	\$0	\$0	\$8,000	\$2,400	\$300	\$0	\$9,600	\$0	\$0	\$0	\$0	\$0	\$1,800	\$0	\$0	\$0	\$32,600	0.63%
North 1st Street	\$28,500	\$1,500	\$0	\$90,950	\$0	\$1,600	\$0	\$6,300	\$0	\$0	\$0	\$0	\$0	\$900	\$200	\$1,000	\$0	\$130,950	2.53%
South 1st Street	\$75,009	\$5,500	\$0	\$0	\$48,900	\$650	\$0	\$7,775	\$175	\$4,950	\$1,200	\$600	\$4,500	\$9,750	\$3,750	\$500	\$0	\$163,259	3.15%
North 2nd Street	\$9,600	\$0	\$0	\$53,400	\$2,400	\$3,050	\$0	\$9,300	\$0	\$0	\$0	\$850	\$0	\$6,165	\$0	\$1,000	\$0	\$85,765	1.65%
South 2nd Street	\$96,759	\$0	\$0	\$84,900	\$31,500	\$4,900	\$0	\$5,975	\$0	\$0	\$1,200	\$300	\$200	\$9,040	\$1,500	\$0	\$2,100	\$238,374	4.60%
North 3rd Street	\$9,900	\$0	\$0	\$16,700	\$1,800	\$1,500	\$0	\$0	\$0	\$0	\$0	\$100	\$0	\$0	\$0	\$0	\$2,100	\$32,100	0.62%
South 3rd Street	\$31,200	\$0	\$0	\$17,900	\$2,400	\$400	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,200	\$53,100	1.02%
Bill Burnett Circle	\$2,250	\$0	\$0	\$7,900	\$1,800	\$0	\$0	\$0	\$3,475	\$9,000	\$0	\$0	\$0	\$600	\$1,100	\$0	\$0	\$26,125	0.50%
South 3rd Street	\$126,500	\$0	\$0	\$28,450	\$6,600	\$900	\$0	\$0	\$0	\$0	\$0	\$1,000	\$0	\$3,300	\$0	\$600	\$0	\$167,250	3.23%
South 4th Street	\$52,200	\$0	\$0	\$54,700	\$6,300	\$1,400	\$0	\$19,200	\$0	\$0	\$0	\$0	\$0	\$1,200	\$0	\$700	\$0	\$135,700	2.62%
South 5th Street	\$67,800	\$0	\$0	\$36,250	\$36,750	\$3,200	\$0	\$13,800	\$0	\$5,625	\$0	\$0	\$0	\$9,600	\$0	\$0	\$0	\$173,025	3.34%
North 6th Street	\$16,660	\$0	\$0	\$11,050	\$0	\$2,600	\$0	\$12,600	\$0	\$0	\$0	\$0	\$0	\$9,000	\$0	\$0	\$0	\$51,910	1.00%
North Division Street	\$101,880	\$0	\$0	\$0	\$7,500	\$2,800	\$0	\$19,200	\$0	\$0	\$0	\$2,000	\$0	\$1,200	\$100	\$1,200	\$0	\$135,880	2.62%
South Division Street	\$750	\$0	\$2,700	\$8,400	\$6,300	\$200	\$0	\$0	\$1,500	\$0	\$0	\$0	\$0	\$0	\$250	\$0	\$0	\$20,100	0.39%
South Rose Street	\$6,300	\$0	\$0	\$11,000	\$10,200	\$800	\$0	\$0	\$3,250	\$0	\$0	\$0	\$400	\$0	\$0	\$0	\$0	\$31,950	0.62%
North Ury Street	\$133,425	\$0	\$0	\$72,200	\$19,809	\$1,200	\$0	\$3,000	\$0	\$0	\$0	\$0	\$0	\$600	\$0	\$500	\$0	\$230,734	4.45%
South Ury Street	\$83,820	\$0	\$0	\$60,650	\$22,450	\$2,700	\$0	\$9,000	\$0	\$0	\$0	\$100	\$0	\$1,950	\$200	\$1,100	\$0	\$181,970	3.51%
North Morgan Street	\$82,500	\$0	\$0	\$49,450	\$11,500	\$2,400	\$0	\$0	\$0	\$0	\$0	\$500	\$0	\$600	\$0	\$3,200	\$0	\$150,150	2.90%
South Morgan Street	\$0	\$0	\$0	\$6,200	\$5,200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$11,400	0.22%
North Home Street	\$148,950	\$0	\$0	\$68,500	\$7,500	\$1,800	\$0	\$7,500	\$0	\$0	\$0	\$0	\$0	\$1,200	\$0	\$200	\$0	\$235,650	4.55%
South Home Street	\$50,400	\$0	\$0	\$39,450	\$14,350	\$600	\$0	\$5,100	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$200	\$0	\$110,100	2.12%
Melrose Street	\$600	\$0	\$0	\$6,100	\$14,400	\$600	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$21,700	0.42%
North Street	\$14,400	\$0	\$0	\$17,100	\$26,250	\$1,600	\$0	\$0	\$0	\$0	\$3,000	\$0	\$0	\$0	\$0	\$0	\$0	\$62,350	1.20%
South Miles Street	\$23,400	\$0	\$0	\$13,750	\$4,800	\$0	\$0	\$3,600	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$45,550	0.88%
East Cheatham Street	\$124,500	\$0	\$0	\$15,900	\$15,900	\$1,200	\$0	\$13,800	\$0	\$0	\$8,400	\$299	\$0	\$4,200	\$0	\$0	\$900	\$185,099	3.57%
East Mercer Street	\$21,600	\$0	\$0	\$0	\$0	\$600	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$22,200	0.43%
East Gibbs Street	\$63,975	\$0	\$0	\$0	\$9,750	\$1,800	\$0	\$8,400	\$0	\$0	\$0	\$0	\$0	\$2,250	\$0	\$0	\$1,200	\$87,375	1.69%
East Palmer Street	\$94,050	\$0	\$0	\$11,200	\$0	\$200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$2,100	\$107,550	2.08%
East College Street	\$91,050	\$0	\$0	\$1,600	\$6,600	\$1,800	\$0	\$6,300	\$0	\$0	\$0	\$0	\$0	\$900	\$0	\$0	\$600	\$108,850	2.10%
West College Street	\$11,100	\$0	\$0	\$0	\$0	\$200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$11,300	0.22%
Dr Martin Luther King Jr Drive	\$85,500	\$0	\$0	\$0	\$9,300	\$400	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$95,200	1.84%
East Vine Street	\$30,580	\$0	\$0	\$2,500	\$3,000	\$600	\$0	\$900	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$37,580	0.73%
East Church Street	\$133,750	\$0	\$0	\$51,450	\$5,850	\$800	\$0	\$0	\$300	\$0	\$3,350	\$0	\$2,300	\$0	\$0	\$400	\$600	\$198,800	3.84%
West Church Street	\$27,700	\$0	\$0	\$2,100	\$30,600	\$600	\$0	\$6,600	\$0	\$0	\$0	\$0	\$1,000	\$1,400	\$100	\$300	\$1,500	\$71,900	1.39%
West Washington Avenue	\$28,200	\$0	\$0	\$6,700	\$6,000	\$200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$41,100	0.79%
High Street	\$107,700	\$0	\$0	\$31,900	\$0	\$2,600	\$0	\$4,200	\$0	\$0	\$1,200	\$0	\$0	\$7,500	\$0	\$300	\$6,300	\$161,700	3.12%
East Lee Street	\$0	\$0	\$0	\$3,050	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,000	\$0	\$0	\$0	\$0	\$4,050	0.08%
West Lee Street	\$33,000	\$0	\$0	\$0	\$18,300	\$400	\$0	\$0	\$0	\$0	\$0	\$0	\$800	\$0	\$0	\$500	\$900	\$53,900	1.04%
East High School Drive	\$600	\$0	\$0	\$24,750	\$0	\$200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$2,400	\$0	\$0	\$0	\$27,950	0.54%
East Florida Avenue	\$32,700	\$0	\$0	\$22,400	\$0	\$600	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$55,700	1.07%
West Florida Avenue	\$102,600	\$0	\$0	\$1,550	\$6,000	\$200	\$0	\$6,300	\$0	\$0	\$0	\$0	\$0	\$900	\$0	\$0	\$6,000	\$123,550	2.38%
East Bransford Street	\$18,600	\$0	\$0	\$9,950	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$28,550	0.55%
West Bransford Street	\$13,800	\$0	\$0	\$2,100	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$15,900	0.31%
East Bishop Street	\$0	\$0	\$0	\$4,010	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$4,010	0.08%
North Clover Street	\$0	\$0	\$0	\$1,400	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$1,400	0.03%
South Clover Street	\$24,000	\$0	\$0	\$2,450	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$26,450	0.51%
West Jackson Street	\$31,200	\$0	\$0	\$2,800	\$0	\$600	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$34,600	0.67%
West Sterling Street	\$8,100	\$0	\$0	\$5,600	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$13,700	0.26%
Harrison Street	\$38,000	\$0	\$0	\$28,200	\$12,300	\$800	\$0	\$1,800	\$1,200	\$1,200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$83,500	1.61%
Waddell Street	\$31,200	\$0	\$0	\$0	\$0	\$200	\$0	\$10,200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$41,600	0.80%
Exchange Street	\$69,300	\$0	\$0	\$19,600	\$8,250	\$0	\$0	\$0	\$0	\$0	\$4,200	\$0	\$0	\$600	\$0	\$1,500	\$0	\$103,450	2.00%
Adams Street	\$45,900	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$45,900	0.89%
South Taylor Street	\$18,600	\$0	\$0	\$0	\$0	\$1,400	\$0	\$600	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$20,600	0.40%
North Dobbins Street	\$16,800	\$0	\$0	\$2,800	\$7,500	\$1,200	\$0	\$5,000	\$1,200	\$0	\$0	\$0	\$0	\$900	\$0	\$0	\$0	\$35,400	0.68%
South Dobbins Street	\$16,800	\$0	\$0	\$0	\$6,300	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$23,100	0.45%
Perkins Street	\$17,400	\$0	\$0	\$0	\$0	\$200	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$17,600	0.34%
Total:	\$2,663,858	\$9,500	\$2,700	\$1,036,510	\$971,509	\$58,750	\$11,300	\$202,650	\$12,000	\$23,475	\$22,550	\$6,299	\$10,400	\$98,055	\$12,250	\$13,200	\$27,250	\$5,182,256	100.00%
%/%	51.40%	0.18%	0.05%	20.00%	18.75%	1.13%	0.22%	3.91%	0.23%	0.45%	0.44%	0.12%	0.20%	1.89%	0.24%	0.25%	0.53%	100.00%	

Priority One	\$1,239,160
Priority Two	\$2,896,538
Priority Three	\$1,153,933
	\$5,289,631

Union City Pedestrian Signal Remediation Cost:	\$107,375
--	-----------

Union City total PROWAG Remediation Cost:	\$5,289,631
---	-------------

ATTACHMENT A - CITY GRIEVANCE FORMS AND POLICY

Note: The City is adopting a grievance policy and an ADA policy within the next few months to complement that shown here from its Police Department.



Communications with Persons with Disabilities

333.1 PURPOSE AND SCOPE

This policy provides guidance to members when communicating with individuals with disabilities, including those who are deaf or hard of hearing, have impaired speech or vision, or are blind.

333.1.1 DEFINITIONS

Definitions related to this policy include:

Auxiliary aids - Tools used to communicate with people who have a disability or impairment. They include but are not limited to the use of gestures or visual aids to supplement oral communication; a notepad and pen or pencil to exchange written notes; a computer or typewriter; an assistive listening system or device to amplify sound; a teletypewriter (TTY) or videophones (video relay service or VRS); taped text; qualified readers; or a qualified interpreter.

Deaf-blind person - An individual who (T.C.A. § 71-4-210(1)):

- (a) Has a central visual acuity of 20/200 or less in the better eye with corrective lenses, or a field defect such that the peripheral diameter of visual field subtends an angular distance no greater than 20 degrees, or a progressive visual loss having a prognosis leading to one or both of these conditions:
 - 1. A chronic hearing impairment so severe that most speech cannot be understood with optimum amplification, or a progressive hearing loss having a prognosis leading to this condition
 - 2. A combination of impairments that cause extreme difficulty in attaining independence in daily life activities, achieving psychosocial adjustment, or obtaining a vocation.
- (b) Despite the inability to be measured accurately for hearing and vision loss due to cognitive or behavioral constraints, or both, can be determined through functional and performance assessment to have severe hearing and visual disabilities that cause extreme difficulty in attaining independence in daily life activities, achieving psychosocial adjustment, or obtaining vocational objectives.

Deaf or hard of hearing - An individual who has or is regarded as having substantially limited hearing with or without assistance. This includes a person whose hearing is totally impaired or whose hearing, with or without amplification, is so seriously impaired that it prevents the person from understanding language spoken in a normal tone, and the primary means of receiving spoken language is through visual input such as but not limited to speechreading, sign language, finger spelling, or writing. A deaf person also includes but is not limited to a person who is mute and a person who is both deaf and mute (T.C.A. § 24-1-211(a)(1); T.C.A. § 71-4-210(2)).

Disability or impairment - A physical or mental impairment that substantially limits a major life activity, including hearing or seeing, regardless of whether the disabled person uses assistive or adaptive devices or auxiliary aids. Individuals who wear ordinary eyeglasses or contact lenses

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

are not considered to have a disability. This includes a person with an acquired brain injury, an intellectual disability, or a developmental disability (T.C.A. § 38-3).

Qualified interpreter - A person who is able to interpret effectively, accurately, and impartially, both receptively and expressively, using any necessary specialized vocabulary. Qualified interpreters include oral interpreters, transliterators, sign language interpreters, and intermediary interpreters. Qualified interpreters should be certified by the National Registry of Interpreters for the Deaf or the Tennessee Registry of Interpreters for the Deaf (T.C.A. § 24-1-211(a)(3)).

333.2 POLICY

It is the policy of the Union City Police Department to reasonably ensure that people with disabilities, including victims, witnesses, suspects and arrestees, have equal access to law enforcement services, programs and activities. Members must make efforts to communicate effectively with individuals with disabilities.

The Department will not discriminate against or deny any individual access to services, rights or programs based upon disabilities.

333.3 AMERICANS WITH DISABILITIES (ADA) COORDINATOR

The Chief of Police shall delegate certain responsibilities to an ADA coordinator (28 CFR 35.107). The coordinator shall be appointed by and directly responsible to the Patrol Lieutenant or the authorized designee.

The responsibilities of the coordinator include but are not limited to:

- (a) Working with the City ADA coordinator regarding the Union City Police Department's efforts to ensure equal access to services, programs and activities.
- (b) Developing reports or new procedures or recommending modifications to this policy.
- (c) Acting as a liaison with local disability advocacy groups or other disability groups regarding access to department services, programs, and activities.
- (d) Ensuring that a list of qualified interpreter services is maintained and available to each Shift Supervisor and Dispatch Supervisor. The list should include information regarding:
 - 1. Contact information.
 - 2. Availability.
- (e) Developing procedures that will enable members to access auxiliary aids or services, including qualified interpreters, and ensure the procedures are available to all members.
- (f) Ensuring signage is posted in appropriate areas indicating that auxiliary aids are available free of charge to individuals with disabilities.
- (g) Ensuring appropriate processes are in place to provide for the prompt and equitable resolution of complaints and inquiries regarding discrimination in access to department services, programs, and activities.

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

333.4 FACTORS TO CONSIDER

Because the nature of any law enforcement contact may vary substantially from one situation to the next, members of this department should consider all information reasonably available to them when determining how to communicate with an individual with a disability. Members should carefully balance all known factors in an effort to reasonably ensure people who are disabled have equal access to services, programs, and activities. These factors may include but are not limited to:

- (a) Members should not always assume that effective communication is being achieved. The fact that an individual appears to be nodding in agreement does not always mean he/she completely understands the message. When there is any doubt, members should ask the individual to communicate back or otherwise demonstrate his/her understanding.
- (b) The nature of the disability (e.g., deafness or blindness vs. hard of hearing or low vision).
- (c) The nature of the law enforcement contact (e.g., emergency vs. non-emergency, custodial vs. consensual contact).
- (d) The availability of auxiliary aids. The fact that a particular aid is not available does not eliminate the obligation to reasonably ensure access. However, in an emergency, availability may factor into the type of aid used.

333.4.1 LIST OF QUALIFIED INTERPRETER SERVICES

The list of interpreters shall be developed from a list provided by the Tennessee Council for the Deaf, Deaf-Blind and Hard of Hearing (T.C.A. § 37-1-406).

333.5 INITIAL AND IMMEDIATE CONSIDERATIONS

Recognizing that various law enforcement encounters may be potentially volatile and/or emotionally charged, members should remain alert to the possibility of communication problems.

Members should exercise special care in the use of all gestures and verbal and written communication to minimize initial confusion and misunderstanding when dealing with any individual with known or suspected disabilities.

In a non-emergency situation, when a member knows or suspects an individual requires assistance to effectively communicate, the member shall identify the individual's choice of auxiliary aid or service.

The individual's preferred communication method must be honored unless another effective method of communication exists under the circumstances (28 CFR 35.160).

Factors to consider when determining whether an alternative method is effective include:

- (a) The methods of communication usually used by the individual.
- (b) The nature, length, and complexity of the communication involved.
- (c) The context of the communication.

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

In emergency situations involving an imminent threat to the safety or welfare of any person, members may use whatever auxiliary aids and services reasonably appear effective under the circumstances. This may include, for example, exchanging written notes or using the services of a person who knows sign language but is not a qualified interpreter, even if the person who is deaf or hard of hearing would prefer a qualified sign language interpreter or another appropriate auxiliary aid or service. Once the emergency has ended, the continued method of communication should be reconsidered. The member should inquire as to the individual's preference and give primary consideration to that preference.

If an individual who is deaf, is hard of hearing or has impaired speech must be handcuffed while in the custody of the Union City Police Department, consideration should be given, safety permitting, to placing the handcuffs in the front of the body to facilitate communication using sign language or writing.

333.6 TYPES OF ASSISTANCE AVAILABLE

Union City Police Department members shall never refuse an available service to an individual with disabilities who is requesting assistance. The Department will not charge anyone to receive auxiliary aids, nor shall it require anyone to furnish their own auxiliary aid or service as a condition for receiving assistance. The Department will make every reasonable effort to provide equal access and timely assistance to disabled individuals through a variety of services.

Disabled individuals may choose to accept department-provided auxiliary aids or services or they may choose to provide their own.

Department-provided auxiliary aids or services may include but are not limited to the assistance methods described in this policy.

333.7 AUDIO RECORDINGS AND ENLARGED PRINT

The Department may develop audio recordings to assist people who are blind or have a visual impairment with accessing important information. If such a recording is not available, members may read aloud from the appropriate form (e.g., a personnel complaint form) or provide forms with enlarged print.

333.8 QUALIFIED INTERPRETERS

A qualified interpreter may be needed in lengthy or complex transactions (e.g., interviewing a victim, witness, suspect or arrestee) if the individual to be interviewed normally relies on sign language or speechreading (lip-reading) to understand what others are saying. The qualified interpreter should not be a person with an interest in the case or the investigation. A person providing interpretation services may be required to establish the accuracy and trustworthiness of the interpretation in a court proceeding.

Qualified interpreters should be:

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

- (a) Available within a reasonable amount of time but in no event longer than one hour if requested.
- (b) Experienced in providing interpretation services related to law enforcement matters.
- (c) Familiar with the use of VRS and/or video remote interpreting services.
- (d) Certified in either American Sign Language (ASL) or Signed English (SE).
- (e) Able to understand and adhere to the interpreter role without deviating into other roles, such as counselor or legal adviser.
- (f) Knowledgeable of the ethical issues involved when providing interpreter services.

Members should use department-approved procedures to request a qualified interpreter at the earliest reasonable opportunity, and generally not more than 15 minutes after a request for an interpreter has been made or it is reasonably apparent that an interpreter is needed. No individual who is disabled shall be required to provide his/her own interpreter (28 CFR 35.160).

333.8.1 MANDATORY USE FOR CHILD AND DOMESTIC ABUSE

Any member investigating a possible domestic abuse or child abuse incident that may have involved or occurred in the presence of a hearing-impaired child shall not use the child's parent or family member as an interpreter to communicate with the child. The member shall instead use a qualified interpreter (T.C.A. § 37-1-406).

333.9 TTY AND RELAY SERVICES

In situations where an individual without a disability would have access to a telephone (e.g., booking or attorney contacts), members must also provide those who are deaf, are hard of hearing or have impaired speech the opportunity to place calls using an available TTY (also known as a telecommunications device for deaf people, or TDD). Members shall provide additional time, as needed, for effective communication due to the slower nature of TTY and TDD communications.

The Department will accept all TTY or TDD calls placed by those who are deaf or hard of hearing and received via a telecommunications relay service (28 CFR 35.162).

Note that relay services translate verbatim, so the conversation must be conducted as if speaking directly to the caller.

333.10 COMMUNITY VOLUNTEERS

Interpreter services may be available from community volunteers who have demonstrated competence in communication services, such as ASL or SE, and have been approved by the Department to provide interpreter services.

Where qualified interpreters are unavailable to assist, approved community volunteers who have demonstrated competence may be called upon when appropriate. However, department members must carefully consider the nature of the contact and the relationship between the individual with

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

the disability and the volunteer to ensure that the volunteer can provide neutral and unbiased assistance.

333.11 FAMILY AND FRIENDS

While family or friends may offer to assist with interpretation, members should carefully consider the circumstances before relying on such individuals. The nature of the contact and relationship between the individual with the disability and the person offering services must be carefully considered (e.g., victim/suspect).

Children shall not be relied upon except in emergency or critical situations when there is no qualified interpreter reasonably available.

Adults may be relied upon when (28 CFR 35.160):

- (a) There is an emergency or critical situation and there is no qualified interpreter reasonably available.
- (b) The person with the disability requests that the adult interpret or facilitate communication and the adult agrees to provide such assistance, and reliance on that adult for such assistance is reasonable under the circumstances.

333.12 ASSISTANCE SPECIFIC TO PERSONS WITH AN ACQUIRED BRAIN INJURY, A DEVELOPMENTAL DISABILITY, OR AN INTELLECTUAL DISABILITY

Any member who, in relation to an offense or violation, interacts with a person who exhibits characteristics of an acquired brain injury, a developmental disability, or an intellectual disability should contact the parent or guardian of a minor, or a person's conservator regarding the interaction as soon as practicable. Any member who seeks to interview a victim, suspect, or defendant formally accused of a crime who the member knows to be diagnosed with an acquired brain injury, a developmental disability, or an intellectual disability should, at the request of the person, his/her parent or guardian, or his/her conservator, ensure that a psychiatrist, psychologist, mental health counselor, special education instructor, clinical social worker, or related professional is present at all interviews (T.C.A. § 38-3).

333.13 REPORTING

Whenever any member of this department is required to complete a report or other documentation, and communication assistance has been provided, such services should be noted in the related report. Members should document the type of communication services utilized and whether the individual elected to use services provided by the Department or some other identified source. If the individual's express preference is not honored, the member must document why another method of communication was used.

All written communications exchanged in a criminal case shall be attached to the report or placed into evidence.

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

333.14 FIELD ENFORCEMENT

Field enforcement will generally include such contacts as traffic stops, pedestrian stops, serving warrants and restraining orders, crowd/traffic control, and other routine field contacts that may involve individuals with disabilities. The scope and nature of these activities and contacts will inevitably vary.

The Department recognizes that it would be virtually impossible to provide immediate access to complete communication services to every member of this department. Members and/or supervisors must assess each situation and consider the length, complexity and importance of the communication, as well as the individual's preferred method of communication when determining the type of resources to use and whether a qualified interpreter is needed.

Although not every situation can be addressed in this policy, it is important that members are able to effectively communicate the reason for a contact, the need for information, and the meaning or consequences of any enforcement action. For example, it would be meaningless to verbally request consent to search if the officer is unable to effectively communicate with an individual who is deaf or hard of hearing and requires communications assistance.

If available, officers should obtain the assistance of a qualified interpreter before placing an individual with a disability under arrest. Individuals who are arrested and are assisted by service animals should be permitted to make arrangements for the care of such animals prior to transport.

333.14.1 QUALIFIED INTERPRETER REQUIRED

In the event that a person who is deaf is arrested and taken into custody for any alleged violation of a criminal law of this state, the officer and the supervisor shall procure a qualified interpreter in order to properly interrogate the person and to interpret his/her statements. A statement taken from a deaf person before an interpreter is present is not admissible in court (T.C.A. § 24-1-211(b)(3)).

333.14.2 FIELD RESOURCES

Examples of methods that may be sufficient for transactions, such as checking a license or giving directions to a location, or for urgent situations such as responding to a violent crime in progress, may, depending on the circumstances, include such simple things as:

- (a) Hand gestures or visual aids with an individual who is deaf, is hard of hearing, or has impaired speech.
- (b) Exchange of written notes or communications.
- (c) Verbal communication with an individual who can speechread by facing the individual and speaking slowly and clearly.
- (d) Use of computer, word processing, personal communication device, or similar device to exchange texts or notes.
- (e) Slowly and clearly speaking or reading simple terms to individuals who have a visual or mental impairment.

Members should be aware that these techniques may not provide effective communication as required by law and this policy depending on the circumstances.

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

333.15 CUSTODIAL INTERROGATIONS

In an effort to ensure that the rights of individuals who are deaf, are hard of hearing or have speech impairment are protected during a custodial interrogation, this department will provide interpreter services before beginning an interrogation, unless exigent circumstances exist or the individual has made a clear indication that he/she understands the process and desires to proceed without an interpreter. The use of a video remote interpreting service should be considered, where appropriate, if a live interpreter is not available. *Miranda* warnings shall be provided to suspects who are deaf or hard of hearing by a qualified interpreter or by providing a written *Miranda* warning card.

To ensure that communications during custodial investigations are accurately documented and are admissible as evidence, interrogations should be recorded whenever reasonably possible. See guidance on recording custodial interrogations in the Investigation and Prosecution Policy.

333.16 ARRESTS AND BOOKINGS

If an individual with speech or hearing disabilities is arrested, the arresting officer shall use department-approved procedures to provide a qualified interpreter at the place of arrest or booking as soon as reasonably practicable, unless the individual indicates that he/she prefers a different auxiliary aid or service or the officer reasonably determines another effective method of communication exists under the circumstances.

When gathering information during the booking process, members should remain alert to the impediments that often exist when communicating with those who are deaf, are hard of hearing, have impaired speech or vision, are blind, or have other disabilities. In the interest of the arrestee's health and welfare, to protect the safety and security of the facility, and to protect individual rights, it is important that accurate medical screening and booking information be obtained. If necessary, members should seek the assistance of a qualified interpreter whenever there is concern that accurate information cannot be obtained or that booking instructions may not be properly understood by the individual.

Individuals who require and possess personally owned communication aids (e.g., hearing aids, cochlear processors) should be permitted to retain them while in custody.

333.17 COMPLAINTS

The Department shall ensure that individuals with disabilities who wish to file a complaint regarding members of this department are able to do so. The Department may provide a qualified interpreter or forms in enlarged print, as appropriate. Complaints will be referred to the ADA coordinator.

Investigations into such complaints shall be handled in accordance with the Personnel Complaints Policy. Qualified interpreters used during the investigation of a complaint should not be members of this department.

Union City Police Department

Policy Manual

Communications with Persons with Disabilities

333.18 COMMUNITY OUTREACH

Community outreach programs and other such services offered by this department are important to the ultimate success of more traditional law enforcement duties. This department will continue to work with community groups, local businesses and neighborhoods to provide equal access to such programs and services.

333.19 TRAINING

To ensure that all members who may have contact with disabled individuals are properly trained, the Department will provide periodic training that should include:

- (a) Awareness and understanding of this policy and related procedures, related forms and available resources.
- (b) Procedures for accessing qualified interpreters and other available resources.
- (c) Working with in-person and telephone interpreters and related equipment.
- (d) Identifying deaf or hard of hearing designations included in the Vehicle Title and Registration System database (2018 Tennessee Laws Pub. Ch. 735).

The Training Officer shall be responsible for ensuring new members receive training related to interacting with individuals who have disabilities, including those who are deaf, are hard of hearing, have impaired speech or vision, or are blind. Those who may have contact with such individuals should receive refresher training at least once every two years thereafter. The Training Officer shall maintain records of all training provided and will retain a copy in each member's training file in accordance with the established records retention schedule.

333.19.1 CALL-TAKER TRAINING

Emergency call-takers shall be trained in the use of TTY equipment protocols for communicating with individuals who are deaf, are hard of hearing, or have speech impairments. Such training and information should include:

- (a) The requirements of the ADA and Section 504 of the Rehabilitation Act for telephone emergency service providers.
- (b) ASL syntax and accepted abbreviations.
- (c) Practical instruction on identifying and processing TTY or TDD calls, including the importance of recognizing silent TTY or TDD calls and using proper syntax, abbreviations, and protocol when responding to TTY or TDD calls.
- (d) Hands-on experience in TTY and TDD communications, including identification of TTY or TDD tones.

Training should be mandatory for all Dispatch members who may have contact with individuals from the public who are deaf, are hard of hearing, or have impaired speech. Refresher training should occur every six months.

*ATTACHMENT B – SELF EVALAUTION OF PUBLIC BUILDINGS,
OTHER CITY FACILITIES AND PARKS ACCESSIBILITY*





Americans with Disability Act Accessibility Guidelines (ADAAG)

Supporting Photography

01 - Public Works Department
Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
01-01	Needs one van accessible handicapped parking space	Level area to 2% cross slope - 16 feet by 20 feet	Square Feet	320	\$30	\$9,600
		Paint with Markings and international accessibility symbol	Square Feet	320	\$12	\$3,840
		Handicapped accessible sign 60 inches from ground to bottom of the sign	Each	1	\$100	\$100
01-02	Sidewalk leading to front entrance is greater than 2% slope	Level area to 2% cross slope - 6 feet by 20 feet - Top Coat	Square Feet	120	\$12	\$1,440
01-03	Front Door has sign that reads: <i>This building is not handicapped accessible. Service provided at Municipal building 408 Depot Street.</i>	Allow for handicapped accesibility				
01-04	Front entrance door does not have enough minimum clearance 30 ½" wide should be 32" wide	Widen Doorway	Each	1	\$500	\$500
01-05	Thresholds at Front entrance door exceed ½ inch vertical clearance	Replace with ¼ inch threshold or ½ inch threshold beveled at 1:1 slope.	Each	1	\$150	\$150
Public Works Department Priority 1 Remediation Cost:						\$15,630

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
01-06	Service counter in foyer exceeds 36" minimum height (40 ½").	Lower service counter to 36"	Each	1	\$1,000	\$1,000
Public Works Department Priority 2 Remediation Cost:						\$1,000

Public Works Department ADAAG Remediation Cost:	\$16,630
--	-----------------

02 - Central Fire Station (Fire Station #1)

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
02-01	Needs one van accessible handicapped parking space	Level area to 2% cross slope - 16 feet by 20 feet	Square Feet	320	\$30	\$9,600
		Paint with Markings and international accessibility symbol	Square Feet	320	\$12	\$3,840
		Handicapped accessible sign 60 inches from ground to bottom of the sign	Each	1	\$100	\$100
02-02	Inaccessible surface at front entrance	Replace asphalt at front entrance with a concrete ramp for a 10 foot x 10 foot square area	Square Feet	100	\$25	\$2,500
02-03	Threshold at front entrance door exceed ½ inch vertical clearance.	Replace with ¼ inch threshold or ½ inch threshold beveled at 1:1 slope.	Each	1	\$150	\$150
Central Fire Station (Fire Station #1) Priority 1 Remediation Cost:						\$16,190

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
02-04	No service counter in front foyer.	Add service counter at 36 inches above the floor.	Each	1	\$1,500	\$1,500
Central Fire Station (Fire Station #1) Priority 2 Remediation Cost:						\$1,500

Central Fire Station (Fire Station #1) ADAAG Remediation Cost:						\$17,690
---	--	--	--	--	--	-----------------

03 - City Hall/Municipal Building

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
03-01	Sandwiched between 2 parking lots, neither are for the Municipal Building	Observation; no remediation requirement				
03-02	32 parking spots behind the Municipal Building without handicapped parking spaces. Needs 2 handicap accessible parking spaces one of which needs to be van accessible (Area 20 x 24).	Level area to 2% cross slope - 24 feet by 20 feet	Square Feet	480	\$30	\$14,400
		Paint with Markings and international accessibility symbol	Square Feet	480	\$12	\$5,760
		Handicapped accessible sign 60 inches from ground to bottom of the sign	Each	2	\$100	\$200
03-03	3 public entrances 1 of which is handicapped accessible. 2 accessible entrances required.	Recommend entrance behind building by extending porch out 5 feet. Ramp will go from 3 feet to existing grade	Each	1	\$5,000	\$5,000
03-04	All entrance doors need to be adjusted for 5' close time from 90° to 12° of the latch.	Adjust entrance doors as required	Each	2	\$25	\$50
03-05	Handicap parking space in front of building on the road. Inaccessible, curb ramp not compliant, sidewalks are non-compliant.	Eliminate Handicapped space in favor of 2 spaces in lot behind building	Each	1	\$100	\$100
City Hall/Municipal Building Priority 1 Remediation Cost:						\$25,510

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
03-06	Threshold to Codes section exceed ½ inch vertical clearance	Replace with ¼ inch threshold or ½ inch threshold beveled at 1:1 slope.	Each	1	\$150	\$150
03-07	Service counter in foyer exceeds 36" minimum height.	Lower service counter to 36"	Each	1	\$1,000	\$1,000
03-08	4 service windows in main hall exceed 4 inches into walkway path; one is handicapped accessible	Adjust counters to under a 4 inch intrusion into the walkway path.	Each	4	\$200	\$800
03-09	Display extends 1 foot into walkway path in main hall	Remove or Modify display	Each	1	\$50	\$50
City Hall/Municipal Building Priority 2 Remediation Cost:						\$2,000

03 - City Hall/Municipal Building

Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
03-10	3 Public Restrooms in the Municipal Building – Men/Women/Handicap-Family. The Handicap-Family is ADA compliant. Men/Women are not.	Add sign adjacent to Men/Women pointing to the handicap accessible restroom.	Each	2	\$25	\$50
City Hall/Municipal Building Priority 3 Remediation Cost:						\$50
City Hall/Municipal Building ADAAG Remediation Cost:						\$27,560

04 - Police Department

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
04-01	Handicapped parking spaces need to be leveled.	Level parking spaces.	Square Feet	480	\$12	\$5,760
04-02	1 of the 2 handicapped spaces needs to be van accessible.	Add van accessible sign under handicapped sign.	Each	1	\$20	\$20
04-03	No accessible route in front of Police Department.	Add a concrete ramp to create an accessible route.	Square Feet	50	\$30	\$1,500
04-04	Ramp at the right hand side entrance to courthouse is 9.1%	Extend ramp to make 8.33% slope. Approximately 9 x 18 feet.	Square Feet	162	\$30	\$4,860
04-05	Police Storage at 615 Perkins Ave is labeled "No Public Access".	Observation; no remediation requirement				
04-06	Fire Dept #2 at 1615 Bishop Street is labeled "No Public Access".	Observation; no remediation requirement				
Police Department Priority 1 Remediation Cost:						\$12,140

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
04-07	Courtroom ramp is at a 10% slope.	Extend Ramp to make an 8.33% slope.	Square Feet	120	\$25	\$3,000
04-08	In Lobby, service counters are too high above the floor.	Lower one service counter at the dispatch widow to a maximum of 36" above the floor.	Each	1	\$500	\$500
Police Department Priority 2 Remediation Cost:						\$3,500

Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
04-09	Toilet paper dispenser is not located properly.	Relocate toilet paper dispenser to 7-9" above the center of the toilet.	Each	1	\$50	\$50
04-10	Restroom mirror is not located properly.	Lower restroom mirror to a maximum of 40" above the floor	Each	1	\$50	\$50
Police Department Priority 3 Remediation Cost:						\$100

Police Department ADAAG Remediation Cost:						\$15,740
---	--	--	--	--	--	----------

05 - Parks and Recreation Department

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				Approximate Remediation Cost:
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	
05-01	Front door handle is twist type.	Change front door handle to wing type or equivalent.	Each	1	\$50	\$50
05-02	Thresholds at front entrance door exceed ½ inch vertical clearance.	Replace with ¼ inch threshold or ½ inch threshold beveled at 1:1 slope.	Each	1	\$150	\$150
05-03	Surface to front door non-compliant	Resurface from the street to the Front Door.	Each	1	\$4,000	\$4,000
Parks and Recreation Department Priority 1 Remediation Cost:						\$4,200

Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				Approximate Remediation Cost:
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	
05-04	Toilet paper dispenser is not located properly.	Relocate toilet paper dispenser to 7-9" above the center of the toilet.	Each	1	\$50	\$50
05-05	Paper towel and soap dispenser are not located properly.	Relocate paper towel and soap dispenser to within 48 inches above the floor.	Each	2	\$50	\$100
05-06	Flush handle not located properly.	Relocate toilet flush valve to open side of the toilet.	Each	1	\$50	\$50
Parks and Recreation Department Priority 3 Remediation Cost:						\$200

Parks and Recreation Department ADAAG Remediation Cost:						\$4,400
--	--	--	--	--	--	----------------

06 - Animal Control Shelter

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
06-01	No marked parking	Level area to 2% cross slope - 16 feet by 20 feet	Square Feet	320	\$30	\$9,600
		Paint with Markings and international accessibility symbol	Square Feet	320	\$12	\$3,840
		Handicapped accessible sign 60 inches from ground to bottom of the sign	Each	1	\$100	\$100
06-02	Elaborate ramp with non-compliant handrail.	Install bottom rail against the concrete.	Linear Feet	50	\$15	\$750
06-03	Front door handle is twist type.	Change front door handle to wing type or equivalent.	Each	1	\$50	\$50
06-04	Thresholds at front entrance door exceed ½ inch vertical clearance.	Replace with ¼ inch threshold or ½ inch threshold beveled at 1:1 slope.	Each	1	\$150	\$150
Animal Control Shelter Priority 1 Remediation Cost:						\$14,490

Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
06-05	Restroom is employees only.	Observation; no remediation requirement				
Animal Control Shelter ADAAG Remediation Cost:						\$14,490

07 - Fifth Street Park
Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
07-01	No parking provided for access	Create parking area with one van accessible parking space. (5 Spaces with one van accessible handicapped space.)	Square Feet	1000	\$30	\$30,000
		Paint with Markings and international accessibility symbol	Square Feet	1000	\$12	\$12,000
		Handicapped accessible sign 60 inches from ground to bottom of the sign	Each	1	\$100	\$100
07-02	No accessible route.	Create accessible route - 5 feet x 50 feet	Square Feet	250	\$30	\$7,500
Fifth Street Park Priority 1 Remediation Cost:						\$49,600

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
07-03	Upon entry wood chips is the ground cover. A lot has migrated from underneath swing set.	Adapt maintenance plan for near daily raking of the mulch to ensure accessible route to all play areas.	Daily	253	\$20	\$5,060
07-04	No ground level features for handicapped children.	Add features for handicapped children	Each	2	\$500	\$1,000
07-05	No swings for handicapped children.	Install a Jenn swing with lift assist	Each	1	\$500	\$500
Fifth Street Park Priority 2 Remediation Cost:						\$6,560

Fifth Street Park ADAAG Remediation Cost:						\$56,160
--	--	--	--	--	--	-----------------

08 - Veteran's Park
Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
08-01	2 Handicapped parking spaces and 11 foot access aisle are greater than 2% cross slope.	Level with top coat (low priority barely out of spec)	Square Feet	540	\$12	\$6,480
08-02	From parking area to main park area there is settling of the sidewalk and has a 3 ½% cross slope.	Sidewalk should be raised and leveled. (6 feet x 65 feet)	Square Feet	390	\$15	\$5,850
Veteran's Park Priority 1 Remediation Cost:						\$12,330

Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
08-03	Men's and Women's restroom have a pipe under left hand sinks uncovered	Cover exposed pipe.	Each	2	\$25	\$50
Veteran's Park Priority 3 Remediation Cost:						\$50

Veteran's Park ADAAG Remediation Cost:						\$12,380
---	--	--	--	--	--	-----------------

09 - Nash Street Park
Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
09-01	Drive encircling the park. Consisting of a bathroom pod, a playground, a pavilion and a basketball court.	Observation; no remediation requirement				
09-02	No parking provided for access	Create parking area with one van accessible parking space. (5 Spaces with one van accessible handicapped space.)	Square Feet	1000	\$30	\$30,000
		Paint with Markings and international accessibility symbol	Square Feet	1000	\$12	\$12,000
		Handicapped accessible sign 60 inches from ground to bottom of the sign	Each	1	\$100	\$100
Nash Street Park Priority 1 Remediation Cost:						\$42,100

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
09-03	No accessible route from entrance to the park to playground area	Add accessible route.	Square Feet	250	\$10	\$2,500
09-04	No accessible route from pavilion to playground area.	Add accessible route.	Square Feet	250	\$10	\$2,500
09-05	No accessible route from pavilion to circular drive.	Add accessible route.	Square Feet	250	\$10	\$2,500
09-06	No ground level features for handicapped children.	Add features for handicapped children	Each	2	\$500	\$1,000
09-07	Pavilion has grill with no accessible route. Grill in not functional.	Remove grill	Each	1	\$50	\$50
Nash Street Park Priority 2 Remediation Cost:						\$8,550

09 - Nash Street Park
Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
09-08	Men's and Women's restroom have a pipe under sinks uncovered	Cover exposed pipe.	Each	2	\$25	\$50
09-09	The sink in Men's and Women's room are too high off the floor	Lower sinks to 34 inches maximum above the floor	Each	2	\$100	\$200
09-10	Faucets in Men's and Women's room are twist type.	Replace faucets handles with wing type.	Each	4	\$20	\$80
09-11	Block wall in Men's and Women's room don't allow enough access room to toilet	Remove block walls.	Each	2	\$500	\$1,000
09-12	Men's and Women's restroom do not have proper signage	Install handicap restroom signs on men's and women's restroom doors.	Each	2	\$15	\$30
09-13	Sidewalk around bathroom pod is non-compliant.	Replace sidewalk - approximately 5 feet by 140 feet.	Square Feet	700	\$30	\$21,000
Nash Street Park Priority 3 Remediation Cost:						\$22,360

Nash Street Park ADAAG Remediation Cost:						\$73,010
---	--	--	--	--	--	-----------------

10 - Kiwanis Park

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
10-01	Park consists of a gazebo, a fountain, and a restroom building	Observation; no remediation requirement				
10-02	No handicapped spaces in existing parking lot that requires 3 spaces with one van accessible space.	Paint with markings and international accessibility symbol	Square Feet	640	\$12	\$7,680
		Handicapped accessible sign 60 inches from ground to bottom of the sign	Each	1	\$100	\$100
10-03	Access aisle from parking lot has no accessibility over or around existing curb	Cut curb and provide 5 foot by 18 foot sidewalk/ramp.	Square Feet	90	\$35	\$3,150
Kiwanis Park Priority 1 Remediation Cost:						\$10,930

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
10-04	Serveral pieces of playground equipment with no access	Provide access to playground equipment	Square Feet	1000	\$10	\$10,000
10-05	Wood chips is the ground cover underneath playground equipment.	Adapt maintenance plan for near daily raking of the mulch to ensure accessible route to all play areas.	Daily	253	\$20	\$5,060
10-06	No ground level features for handicapped children.	Add feature for handicapped children adjacent to slide and red 6-set swing set and one feature adjacent to the blue slide set	Each	2	\$500	\$1,000
10-07	No swing for handicapped children.	Install a Jenn swing with lift assist at 4-set blue swing set.	Each	1	\$500	\$500
10-08	No accessible route to the gazebo.	Remove Brick pavers	Square Feet	100	\$10	\$1,000
10-09		Install concrete sidewalk from the fountain to the gazebo - 5 feet by 20 feet.	Square Feet	100	\$25	\$2,500
Kiwanis Park Priority 2 Remediation Cost:						\$20,060

10 - Kiwanis Park

Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				Approximate Remediation Cost:
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	
10-08	Restroom as constructed has no accessibility	Construct accessible restroom facility	Each	1	\$30,000	\$30,000
Kiwanis Park Priority 3 Remediation Cost:						\$30,000
Kiwanis Park ADAAG Remediation Cost:						\$60,990

11 - Graham Park

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
11-01	Park consists of Skate Park, splash pad and tennis courts and LH Ladd Field	Observation; no remediation requirement				
11-02	Access route to tennis court entrance needs repair	Create a ramp level with tennis court surface sloping to sidewalk. 5 feet by 10 feet.	Square feet	50	\$30	\$1,500
		Install compliant handrail	Each	1	\$1,800	\$1,800
11-03	Second tennis court entrance needs sidewalk	Install sidewalk	Square feet	250	\$30	\$7,500
Graham Park Priority 1 Remediation Cost:						\$10,800

Priority 2 - Access to Goods and Services

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
11-04	Service counter at Skate Park/Splash pad exceeds 4 inches into pathway	Modify Service counter to less than 4 inches into pathway	Each	1	\$250	\$250
11-05	Dugout #1 has no handicapped access from field	Pour pad to allow Handicapped access and raise field level at dugout for access from field to dugout	Square feet	24	25	\$600
11-06	Dugout #2 has no handicapped access from sidewalk	Create opening for access from sidewalk	Each	1	\$1,200	\$1,200
Graham Park Priority 2 Remediation Cost:						\$1,200

11 - Graham Park

Priority 3 - Toilet Rooms

Issue Number	Issue	Remediation				
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	Approximate Remediation Cost:
11-07	Men's/Women's room have twist type faucet handles	Change faucet handles to wing type	Each	2	\$75	\$150
11-08	Men's/Women's room towel dispenser too high	Lower towel dispenser to 40 inches	Each	2	\$40	\$80
11-09	Men's/Women's room have no handicapped accessible stall	Reconfigure toilet stalls to create handicapped accessible stall. Men's room will loose one urinal, Women's room will loose one stall.	Each	2	\$3,500	\$7,000
11-10	Men's/Women's room need appropriate grab bars	Install appropriate grab bars	Each	2	\$100	\$200
11-11	Men's Room has exposed pipes under sink	Insulate pipes under sink	Each	1	\$50	\$50
11-12	Men's/Women's sign not properly located	Relocate signs to south side of the door	Each	2	\$50	\$100
Graham Park Priority 3 Remediation Cost:						\$7,580
Graham Park ADAAG Remediation Cost:						\$19,580

12 - Turf Management Department

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				Approximate Remediation Cost:
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	
12-01	No public Access	Add "Employee Only" Signage	Each	1	\$50	\$50
Turf Management Department Priority 1 and ADAAG Remediation Cost:						\$50

13 - Water Treatment Plant (Martin Luther King Jr. Drive)

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				Approximate Remediation Cost:
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	
13-01	No public Access	Add "Employee Only" Signage	Each	1	\$50	\$50
Water Treatment Plant (Martin Luther King Jr. Drive) Priority 1 and ADAAG Remediation Cost:						\$50

14 - Wastewater Treatment Plant (Lynch Lane)

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				Approximate Remediation Cost:
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	
14-01	No public Access	Add "Employee Only" Signage	Each	1	\$50	\$50
Wastewater Treatment Plant (Lynch Lane) Priority 1 and ADAAG Remediation Cost:						\$50

15 - College Street Basketball Court

Priority 1 - Approach and Entrance

Issue Number	Issue	Remediation				Approximate Remediation Cost:
		Recommendation	Unit	Size of Area or # of Items	Cost per Unit	
15-01	No parking area, no accessible route from street	Provide an accessible route from street to court by adding entrance at the street side of the court	Each	1	\$500	\$500
College Street Basketball Court Priority 1 and ADAAG Remediation Cost:						\$500



Americans with Disability Act Accessibility Guidelines (ADAAG)

Supporting Photography



01-01
Add Parking Space



01-02
Level Area to 2% Cross Slope



01-03
Allow for Handicapped Access



01-04
Widen Front Entrance Doorway





01-06
Lower Service Counter



02-01
Add Parking Space



02-02
Replace Asphalt with concrete ramp



02-03
Replace Threshold



03-03
Extend porch and
Install ramp



03-05
Eliminate handicapped
space



03-06
Replace Threshold



03-07
Lower Service Counter



03-08
Adjust counter intrusion into walkway



03-09
Remove or modify Display



04-03
Add concrete ramp




04-04
Extend Ramp



04-07
Extend Ramp



04-08
Lower one service counter




04-09
Relocate Toilet Paper Dispenser



05-01
Change door handle




05-03
Resurface from street
to front door



05-04
Relocate toilet paper
dispenser



06-01
Create compliant parking



06-02
Install bottom rail against the concrete



06-03
Install wing type knob



07-01 & 07-02
Create parking and accessible route



07-03
Daily raking of wood chips



07-05
Install Jenn swing with lift assist



08-01
Level with topcoat




08-02
Raise and level sidewalk



08-03
Cover exposed pipe



09-01
Nash Street Park



09-06
**Add features for
Handicapped children**



09-04
Add accessible route from pavilion to playground



09-05
Add accessible route from pavilion to circular drive



09-07
**Grill Non-functional
remove**



09-08
Cover exposed pipe



09-09
**Lower sinks to 34 inches
above the floor**



09-10
**Replace faucet knobs with
wing type**



09-11
Remove block walls





09-12
Install handicapped
restroom signs



09-13
Replace sidewalk around restroom pod



**10-01
Kiwanis Park**



**10-08 & 10-09
Accessible route to Gazebo**



**10-02 & 10-03
Install handicapped parking &
Curb cut and sidewalk/ramp**



10-04 thru 10-07

Provide access, maintain wood chips, add features for handicapped children including Jenn swing



10-10

Construct accessible restroom facility



**11-01
Graham Park**



**11-02
Create ramp and rail**




**11-03
Install Sidewalk**



**11-04
Modify service counter**

*ATTACHMENT C - SELF-EVALUATION OF PEDESTRIAN ACCESS TO
PUBLIC RIGHT-OF-WAY*



UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0001	East Reelfoot Avenue	Railroad Bridge (City Limits)	Lone Oak Drive	Y	Y	Sidewalk exists across bridge and also from 2928 to Lone Oak Drive	SW0001-03	Broken Surface Material	Replace broken surface material	\$3,000
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-01	Broken Surface Material	Replace broken surface material	\$3,000
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-08	Broken Surface Material	Replace Surface Material; Broken curb and gutter	\$1,000
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-12	Broken Surface Material	Replace broken surface material Replace curb and gutter	\$2,625
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-05	Broken Surface Material	Replace Broken Surface Material	\$1,125
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-13	Broken Surface Material	Replace Broken Surface Material	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-14	Broken Surface Material	Replace curb and gutter	\$375
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-16	Broken Surface Material	Replace Broken Surface Material	\$1,500
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-23	Broken Surface Material	Replace Broken Surface Material	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-26	Broken Surface Material	Replace Broken Surface Material	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-35	Broken Surface Material	Replace Broken Surface Material	\$1,500
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-36	Broken Surface Material	Replace Broken Surface Material	\$1,125
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-40	Broken Surface Material	Replace Broken Surface Material	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-41	Broken Surface Material	Replace Broken Surface Material	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-45	Broken Surface Material	Replace Broken Surface Material	\$1,125
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-48	Broken Surface Material	Replace Broken Surface Material	\$4,500
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-50	Broken Surface Material	Replace Broken Surface Material	\$1,125
SW0011		South Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at S Sunswept to S Miles	SW0011-01	Broken Surface Material	Replace Broken Surface Material	\$750
SW0012		South Sunswept Drive	Pleasant Valley Avenue	Y	Y	Sidewalk starts at S Sunswept to Pleasant Valley	SW0012-01	Broken Surface Material	Replace Broken Surface Material	\$750
SW0012		South Sunswept Drive	Pleasant Valley Avenue	Y	Y	Sidewalk starts at S Sunswept to Pleasant Valley	SW0012-02	Broken Surface Material	Replace Broken Surface Material	\$750
SW0016		Russell Street	Edwards Street	Y	Y	Sidewalk Starts at Russell to Edwards	SW0016-01	Broken Surface Material	Replace broken surface material	\$375
SW0016		Russell Street	Edwards Street	Y	Y	Sidewalk Starts at Russell to Edwards	SW0016-02	Broken Surface Material	Replace broken surface material	\$750
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-04	Broken Surface Material	Replace broken surface material	\$750
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-11	Broken Surface Material	Replace broken surface material	\$750
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-17	Broken Surface Material	Replace broken surface material	\$750
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-04	Broken Surface Material	Replace broken surface material	\$750
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-05	Broken Surface Material	Replace broken surface material	\$1,500
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-07	Broken Surface Material	Replace broken surface material	\$750
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-08	Broken Surface Material	Replace broken surface material	\$750
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-02	Broken Surface Material	Replace broken surface material	\$1,125
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-06	Broken Surface Material	Remove platform; Add missing sidewalk; Add yellow truncated domes	\$6,350
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-09	Broken Surface Material	Replace Broken Surface Material	\$1,125
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-11	Broken Surface Material	Replace Broken Surface Material	\$375
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-12	Broken Surface Material	Replace Broken Surface Material	\$3,000
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-14	Broken Surface Material	Replace Broken Surface Material	\$375
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-16	Broken Surface Material	Replace Broken Surface Material	\$375
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-09	Curb Ramp	Replace curb ramps with one-way directional ramps with 8.33% run slope; Add yellow truncated domes	\$3,400
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-10	Curb Ramp	Replace curb ramps with one-way directional ramps with 8.33% run slope; Add yellow truncated domes	\$3,400
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-12	Curb Ramp	Replace curb ramp with one-way directional ramps with 8.33% run slope; Add yellow truncated domes	\$1,550

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0017	East Reelfoot Avenue	South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-13	Curb Ramp	Replace curb ramp with one-way directional ramps with 8.33% run slope; Add yellow truncated domes	\$3,350
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-07	Curb Ramp	Add yellow truncated dome	\$350
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-19	Debris	Clean debris and stabilize drive to prevent debris	\$0
SW0001		Railroad Bridge (City Limits)	Lone Oak Drive	Y	Y	Sidewalk exists across bridge and also from 2928 to Lone Oak Drive	SW0001-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,300
SW0001		Railroad Bridge (City Limits)	Lone Oak Drive	Y	Y	Sidewalk exists across bridge and also from 2928 to Lone Oak Drive	SW0001-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0001		Railroad Bridge (City Limits)	Lone Oak Drive	Y	Y	Sidewalk exists across bridge and also from 2928 to Lone Oak Drive	SW0001-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,000
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes; Reconstruct curb	\$3,600
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-11	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-07	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-11	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,000
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-13	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,500
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,500
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-11	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,500
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-12	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,500
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,500

UNION CITY SIDEWALK BARRIERS

[illegible]

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0006	East Reelfoot Avenue	Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-31	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-33	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-34	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-35	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-37	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-39	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-40	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$900
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-41	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-43	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-44	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-07	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,200
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-11	Drive Ramp	Construct 2 compliant one-way directional ramps each side of entrance with yellow truncated domes	\$3,100
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-13	Drive Ramp	Construct 2 compliant one-way directional ramps each side of entrance with yellow truncated domes	\$3,100
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150

UNION CITY SIDEWALK BARRIERS

[illegible]

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0010	East Reelfoot Avenue	Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-18	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-19	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-20	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-21	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-22	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-23	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0013		Pleasant Valley Avenue	South Miles Street	Y	Y	1	SW0013-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0013		Pleasant Valley Avenue	South Miles Street	Y	Y	1	SW0013-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0013		Pleasant Valley Avenue	South Miles Street	Y	Y	1	SW0013-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0013		Pleasant Valley Avenue	South Miles Street	Y	Y	1	SW0014-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0014		South Miles Street	Hillcrest Street	Y	Y	Sidewalk starts at S Miles to Hillcrest	SW0014-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0014		South Miles Street	Hillcrest Street	Y	Y	Sidewalk starts at S Miles to Hillcrest	SW0014-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0014		South Miles Street	Hillcrest Street	Y	Y	Sidewalk starts at S Miles to Hillcrest	SW0014-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0014		South Miles Street	Hillcrest Street	Y	Y	Sidewalk starts at S Miles to Hillcrest	SW0014-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0015		Hillcrest Street	Russell Street	Y	Y	Sidewalk Starts at Hillcrest to Russell	SW0015-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0015		Hillcrest Street	Russell Street	Y	Y	Sidewalk Starts at Hillcrest to Russell	SW0015-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0016		Russell Street	Edwards Street	Y	Y	Sidewalk Starts at Russell to Edwards	SW0016-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-07	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-14	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-15	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-16	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-18	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0018		Edwards Street	Woodlawn Street	Y	Y	Sidewalk starts at Edwards to Woodlawn	SW0018-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0018		Edwards Street	Woodlawn Street	Y	Y	Sidewalk starts at Edwards to Woodlawn	SW0018-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0019	East Reelfoot Avenue	Woodlawn Street	South Home Street	Y	Y	Sidewalk starts at Woodland to S Home	SW0019-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0019		Woodlawn Street	South Home Street	Y	Y	Sidewalk starts at Woodland to S Home	SW0019-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0019		Woodlawn Street	South Home Street	Y	Y	Sidewalk starts at Woodland to S Home	SW0019-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0019		Woodlawn Street	South Home Street	Y	Y	Sidewalk starts at Woodland to S Home	SW0019-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0020		Edwards Street	South Side Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0020		Edwards Street	South Home Street	Y	Y	Sidewalk starts at Edwards to S Home	SW0020-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-07	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0021		South Home Street	South Ury Street	Y	Y	Sidewalk Starts at S Home to Ury	SW0021-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0022		South Ury Street	Perkins Street	Y	Y	Sidewalks starts at S Ury to Perkins	SW0022-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0024	East Reelfoot Avenue	South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-07	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-13	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-15	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-17	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-18	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-01	Fire Hydrant	Construct Sidewalk Around hydrant; Move sign: Repair Broken Surface Material	\$900
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-02	Grass	Trim and edge grass	\$200
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-07	Grass	Trim and edge grass	\$200
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-09	Grass	Trim and edge grass	\$200
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-12	Grass	Trim and edge grass	\$200
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-28	Grass	Trim and edge grass	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-36	Grass	Trim and edge grass	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-46	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-10	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-19	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-25	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-28	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-30	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-31	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-33	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-43	Grass	Trim and edge grass	\$200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-49	Grass	Trim and edge grass	\$200
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-04	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-08	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0002		Railroad Bridge (City Limits)	Hillsboro Street	Y	Y	Sidewalk exists across bridge and also from 3331 to Hillsboro Street	SW0002-10	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-02	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0003		Lone Oak Drive	Lynn Street	Y	Y	Sidewalk starts at Lone Oak to Lynn	SW0003-10	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-02	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-04	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-07	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-10	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0004		Hillsboro Street	Webster Street	Y	Y	Sidewalk Starts at Hillsboro to Webster	SW0004-13	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-04	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-05	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-07	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-09	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-13	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-14	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-16	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-19	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-21	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0005		Lynn Street	Section Line Road	Y	Y	Sidewalk starts at Lynn to Section Line Road	SW0005-23	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-02	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-03	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-06	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-08	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-09	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-12	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-13	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-15	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-18	Mailbox	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-22	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-30	Mailbox	Move Mailbox behind Sidewalk	\$250

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers In Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0006	East Reelfoot Avenue	Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-38	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-42	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-45	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-04	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-07	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-03	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0008		Bryn Street	Highland Avenue	Y	Y	Sidewalk starts at Byrn to Highland	SW0008-04	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-01	Mailbox	Move Mailbox behind Sidewalk	\$250
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-11	Missing sidewalk	Replace missing sidewalk and missing curb and gutter	\$3,000
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-20	Missing sidewalk	Add sidewalk to toward rail crossing with curb ramp and yellow truncated domes	\$3,000
SW0023		Perkins Street	South 1st Street	Y	Y	Sidewalks starts at Perkins to S 1st Street	SW0023-01	Pole	Construct additional sidewalk to the backside of pole to provide a 4 ft pathway; Provide horizontal guy guide to allow a clear 80 inch vertical pathway and 4 ft clear horizontal pathway; Move signs away from vertical and horizontal pathway	\$2,700
SW0007		Section Line Road	Bryn Street	Y	Y	Sidewalk starts at Section Line to Byrn	SW0007-02	Settling	Replace sidewalk	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-06	Settling	Replace sidewalk where settled	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-07	Settling	Replace sidewalk where settled	\$1,200
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-09	Settling	Replace sidewalk where settled	\$1,500
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-20	Settling	Replace Broken Surface Material	\$1,125
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-21	Settling	Replace Broken Surface Material	\$1,125
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-22	Settling	Replace Broken Surface Material	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-24	Settling	Replace Broken Surface Material	\$0
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-29	Settling	Replace Broken Surface Material	\$750
SW0009		Oakshine Road	South Sunswept Drive	Y	Y	Sidewalk starts at Oakshine to S Sunswept	SW0009-32	Settling	Replace Broken Surface Material	\$750
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-08	Settling	Replace sidewalk where settled	\$750
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-09	Settling	Replace sidewalk where settled	\$750
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-12	Settling	Replace sidewalk where settled	\$750
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-13	Settling	Replace sidewalk where settled	\$750
SW0010		Highland Avenue	South Sunswept Drive	Y	Y	Sidewalk starts at Highland to South Sunswept	SW0010-16	Settling	Replace sidewalk where settled	\$750
SW0018		Edwards Street	Woodlawn Street	Y	Y	Sidewalk starts at Edwards to Woodlawn	SW0018-03	Settling	Replace sidewalk where settled	\$750
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-11	Sign	Add sidewalk around sign post to provide a 4 ft clear horizontal pathway; raise sign for 80 inch vertical clearance	\$950
SW0014		South Miles Street	Hillcrest Street	Y	Y	Sidewalk starts at S Miles to Hillcrest	SW0014-03	Sign	Move sign behind sidewalk and raise sign to 80 Inch Vertical clearance	\$250
SW0017		South Miles Street	Edwards Street	Y	Y	Sidewalk starts at South Miles to Edwards	SW0017-05	Sign	Move sign behind sidewalk and raise sign to 80 Inch Vertical clearance	\$250
SW0024		South Home Street	South 1st Street	Y	Y	Sidewalk starts at S Home to Railroad Crossing	SW0024-04	Surface Deterioration	Replace sidewalk and missing curb and gutter	\$2,000
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-26	Upheaval	Replace Heaved sidewalk replace heaved curb and gutter	\$1,125
SW0006		Webster Street	Oakshine Road	Y	Y	Sidewalk starts at Webster and ends at Oakshine	SW0006-32	Upheaval	Replace Heaved sidewalk replace heaved curb and gutter	\$625
East Reelfoot Avenue Remediation Estimated Costs: \$536,800										
SW0025	West Reelfoot Avenue	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S First to S 2nd Street	SW0025-03	Broken Surface Material	Replace broken surface material	\$375
SW0026		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd Street to S 3rd Street	SW0026-03	Broken Surface Material	Replace broken surface material	\$375
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-07	Broken Surface Material	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,625
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-13	Broken Surface Material	Replace broken surface material	\$1,500
SW0025		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S First to S 2nd Street	SW0025-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0025		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S First to S 2nd Street	SW0025-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0025		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S First to S 2nd Street	SW0025-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0026		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd Street to S 3rd Street	SW0026-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0026		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd Street to S 3rd Street	SW0026-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0027	West Reelfoot Avenue	South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-11	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-12	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0027		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd Street to S 5th Street	SW0027-14	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0028		South 5th Street	Unnamed road by Hoosier Creek	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0029		South 1st Street	Entrance to Lowe's	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0030		Unnamed road by Hoosier Creek	Jere B Ford Memorial Highway	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0031		Entrance to Lowe's	Vaden Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0032		Jere B Ford Memorial Highway	Lannom Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0033		Vaden Street	Old Rives Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0034		Lannom Lane	Old Troy Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0035		Old Troy Road	Shopping Center Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0036		Shopping Center Entrance	Walmart Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0037		Old Rives Road	Stad Ave	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0038		Walmart Entrance	Walmart Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0039		Stad Avenue	Rutledge Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0040		Rutledge Lane	Shopping Center Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0041		Shopping Center Entrance	Shopping Center Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0042		Shopping Center Entrance	Shopping Center Service Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0043		Walmart Entrance	Phebus Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0044		Shopping Center Service Road	Phebus Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0045		Phebus Lane	Walker Tanner Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0046		Phebus Lane	Walker Tanner Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Reelfoot Avenue Remediation Estimated Costs:										\$55,725
SW0057	East Main Street	North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-06	Broken Surface Material	Replace Broken Surface Material	\$300
SW0059		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0059-03	Broken Surface Material	Replace broken surface material	\$375
SW0065		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams Street to S Clover	SW0065-03	Broken Surface Material	Replace broken surface material	\$600
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-02	Broken Surface Material	Replace Missing Sidewalk and Broken surface material	\$5,400
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-04	Broken Surface Material	Replace weathered sidewalk	\$1,200
SW0067		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0067-02	Broken Surface Material	Replace broken surface material	\$900
SW0067		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0067-03	Broken Surface Material	Replace broken surface material	\$900
SW0067		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0067-04	Broken Surface Material	Replace broken surface material	\$300
SW0067		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0067-05	Broken Surface Material	Replace broken surface material	\$1,500
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-02	Broken Surface Material	Replace broken and deteriorated surface areas 6 sections	\$1,800
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-03	Broken Surface Material	Replace broken and deteriorated surface areas 2 sections	\$600
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-04	Broken Surface Material	Replace broken and deteriorated surface areas 3 sections	\$900
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-05	Broken Surface Material	Replace broken and deteriorated surface areas 5 sections	\$1,500
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-07	Broken Surface Material	Replace broken and deteriorated surface areas 10 sections	\$3,000
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-05	Broken Surface Material	Replace broken and deteriorated surface areas 1 section	\$300
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-06	Broken Surface Material	Replace broken and deteriorated surface areas 7 sections	\$2,100
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-08	Broken Surface Material	Replace broken and deteriorated surface areas 10 sections	\$3,000
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-09	Broken Surface Material	Replace broken and deteriorated surface areas 7 sections	\$2,100

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pinif remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0069	East Main Street	North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-10	Broken Surface Material	Replace broken and deteriorated surface from the ramp sidewalk continuation area to the corner new ramp at N Morgan	\$3,600
SW0070		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0070-02	Broken Surface Material	Replace broken and deteriorated surface areas 7 sections	\$2,100
SW0070		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0070-03	Broken Surface Material	Replace broken and deteriorated surface areas 2 sections including part of drive sidewalk continuation	\$900
SW0070		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0070-04	Broken Surface Material	Replace broken and deteriorated surface areas 5 sections including part of drive sidewalk continuation	\$1,500
SW0071		North Morgan Street	North Ury Street	Y	y	Sidewalk starts at N Morgan to N Ury	SW0071-02	Broken Surface Material	Replace broken and deteriorated surface areas 6 sections	\$1,800
SW0071		North Morgan Street	North Ury Street	Y	y	Sidewalk starts at N Morgan to N Ury	SW0071-03	Broken Surface Material	Replace broken and deteriorated surface areas 2 sections	\$600
SW0071		North Morgan Street	North Ury Street	Y	y	Sidewalk starts at N Morgan to N Ury	SW0071-04	Broken Surface Material	Replace broken and deteriorated surface areas 10 sections	\$3,000
SW0071		North Morgan Street	North Ury Street	Y	y	Sidewalk starts at N Morgan to N Ury	SW0071-05	Broken Surface Material	Replace broken and deteriorated surface area 5 sections	\$1,500
SW0071		North Morgan Street	North Ury Street	Y	y	Sidewalk starts at N Morgan to N Ury	SW0071-06	Broken Surface Material	Replace broken surface material in the sidewalk continuation area to provide a 4 ft pathway with 2 % maximum cross slope	\$900
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-02	Broken Surface Material	Replace broken and deteriorated surface area 1 section	\$300
SW0073		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0073-02	Broken Surface Material	Replace broken surface material	\$1,200
SW0073		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0073-03	Broken Surface Material	Replace broken surface material	\$300
SW0073		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0073-06	Broken Surface Material	Replace broken surface material	\$1,125
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-03	Broken Surface Material	Replace broken surface material 1 section	\$300
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-04	Broken Surface Material	Replace broken surface material 1 section	\$300
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-05	Broken Surface Material	Replace broken surface material 3 sections	\$900
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-06	Broken Surface Material	Replace broken surface material 5 sections	\$1,500
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-07	Broken Surface Material	Replace broken surface material 3 sections	\$900
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-11	Broken Surface Material	Replace broken surface material 6 sections	\$1,800
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW0075-02	Broken Surface Material	Replace sidewalk from new ramp to the newer sidewalk	\$3,000
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW0075-04	Broken Surface Material	Replace broken surface material; Clean grass in expansion joints	\$1,700
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW0075-08	Broken Surface Material	Replace broken surface material	\$450
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-02	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-03	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-04	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-05	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-08	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-09	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0059		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0059-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0059		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0059-04	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0062		North Taylor Street	Greenwood Street	Y	Y	Sidewalk starts at N Taylor to Greenwood	SW0062-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0062		North Taylor Street	Greenwood Street	Y	Y	Sidewalk starts at N Taylor to Greenwood	SW0062-03	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0063		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0063-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0063		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0063-07	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0064		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood to N Clover	SW0064-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0064		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood to N Clover	SW0064-07	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0065		Adams Street	South Clover Street	Y	y	Sidewalk starts at Adams Street to S Clover	SW0065-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0065		Adams Street	South Clover Street	Y	y	Sidewalk starts at Adams Street to S Clover	SW0065-03	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-08	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0067		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0067-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0067		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0067-06	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-08	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW-0069-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-11	Curb Ramp	Newly Constructed Compliant Ramp	\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0070	East Main Street	South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0070-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0070		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0070-06	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0070		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0070-07	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0071		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0071-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0071		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0071-07	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-08	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0073		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0073-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0073		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0073-07	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-14	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW0075-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0079		East Main Street	South 1st Street	Y	Y	Sidewalk is local to store only;	SW0079-01	Curb Ramp	None recommended now	\$0
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-08	Debris	Clean asphalt and grass off of surface	\$200
SW0063		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0063-03	Drive Ramp	Replace ramp area sidewalk continuation for 2 ramps	\$1,200
SW0063		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0063-06	Drive Ramp	Replace sidewalk and level sidewalk continuation area	\$600
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-03	Drive Ramp	Replace broken surface material in the sidewalk continuation area to provide a 4 ft pathway	\$3,000
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-05	Drive Ramp	Replace ramp and also sidewalk continuation area to provide a 4 ft pathway	\$1,800
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-06	Drive Ramp	Replace drive ramp with compliant 2% cross slopes in sidewalk continuation area: Sidewalk run slope each side reconstruct to provide a maximum of 8.33% side slopes	\$3,000
SW0068		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0068-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,000
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-07	Drive Ramp	Replace sidewalk in drive ramp continuation area	\$900
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0073		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0073-05	Drive Ramp	Construct 2 one-way directional ramp with domes: Add yellow truncated domes	\$3,100
SW0057		North Sunswept Drive	South Miles Street	Y	Y	Sidewalk starts at 1601 E Main to S Miles Street	SW0057-07	Grass	Spray Grass in all Areas at Expansion Joints	\$200
SW0063		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0063-02	Grass	Spray and remove grass growing in expansion joints	\$250
SW0064		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood to N Clover	SW0064-04	Grass	Spray grass and clean expansion joints	\$200
SW0064		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood to N Clover	SW0064-05	Grass	Spray grass and clean expansion joints	\$200
SW0064		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood to N Clover	SW0064-06	Grass	Edge and clean grass various locations	\$200
SW0065		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams Street to S Clover	SW0065-02	Grass	Trim and edge grass	\$200
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-03	Grass	Spray grass and clean expansion joints	\$200
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-05	Grass	Spray grass and clean expansion joints	\$200
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-02	Grass	Trim and edge grass	\$200
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-09	Grass	Remove grass from expansion joints	\$200
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-12	Grass	Clean grass from expansion joints	\$200
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW0075-06	Grass	Clean grass from expansion joints	\$200
SW0064		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood to N Clover	SW0064-03	Missing sidewalk	Replace missing sidewalk and area where settled	\$600
SW0047		Section Line Road	Town and Country Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0048		Section Line Road	Unnamed road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0049		Unnamed road	Unnamed road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0050		Town and Country Road	Parkview Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0051		Parkview Street	Chivers Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0052		Unnamed road	North Sunswept Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0053		Chivers Street	North Sunswept Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0054		North Sunswept Drive	Jernigan Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0055		Jernigan Drive	North Ford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0056		North Ford Street	North Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0058		North Miles Street	Nailling Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0060		Keller Street	South Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0061		Nailling Drive	North Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0076		South Division Street	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0077		Depot Road	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0078		North 1st Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW0075-07	Scrub	Trim scrub from obstructing pathway	\$300
SW0062		North Taylor Street	Greenwood Street	Y	Y	Sidewalk starts at N Taylor to Greenwood	SW0062-02	Settling	Replace sidewalk where settled	\$1,200
SW0063		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0063-04	Settling	Replace sidewalk where settled	\$600
SW0063		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0063-05	Settling	Replace sidewalk where settled	\$600
SW0064		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood to N Clover	SW0064-02	Settling	Replace sidewalk where settled	\$300
SW0066		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0066-07	Settling	Replace sidewalk where settled	\$600
SW0070		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0070-05	Settling	Replace area where settled	\$600
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-06	Settling	Replace sidewalk where settled	\$300
SW0072		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0072-07	Settling	Replace sidewalk where settled	\$300
SW0073		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0073-04	Settling	Replace sidewalk where settled	\$1,200
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-10	Settling	Replace sidewalk where settled	\$600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0059	East Main Street	South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0059-02	Sign	Raise sign to 80 inch minimum vertical distance	\$200
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-02	Sign	Move sign further into grass strip to avoid vertical obstruction	\$100
SW0069		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0069-04	Sign	Move sign further into grass strip to avoid vertical obstruction	\$100
SW0074		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0074-13	Sign	Raise sign to 80 inch minimum vertical distance	\$200
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW-0075-03	Sign	Raise sign to 80 inch minimum vertical distance	\$500
SW0075		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to Depot	SW0075-05	Sign	Raise sign to 80 inch minimum vertical distance	\$200
East Main Street Remediation Estimated Costs:										\$89,150
SW0080	West Main Street	North 1st Street	North 2nd Street	Y	Y	Sidewalk starts at N 1st to N 2nd	SW0080-02	Broken Surface Material	Replace broken surface material	\$900
SW0080		North 1st Street	North 2nd Street	Y	Y	Sidewalk starts at N 1st to N 2nd	SW0080-03	Broken Surface Material	Replace broken surface material; level meter box; replace missing sidewalk	\$3,600
SW0081		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-04	Broken Surface Material	Replace broken surface material	\$600
SW0081		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-05	Broken Surface Material	Replace broken surface material	\$600
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-02	Broken Surface Material	Replace broken surface material	\$600
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-03	Broken Surface Material	Replace broken surface material	\$450
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-05	Broken Surface Material	Replace broken surface material	\$450
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-06	Broken Surface Material	Replace broken surface material	\$1,200
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-10	Broken Surface Material	Replace broken surface material	\$2,250
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-02	Broken Surface Material	Replace broken surface material 3 sections	\$900
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-03	Broken Surface Material	Replace broken surface material 4 sections	\$1,200
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-04	Broken Surface Material	Replace broken surface material 2 sections	\$900
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-05	Broken Surface Material	Replace broken surface material 7 sections	\$2,100
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-07	Broken Surface Material	Replace broken surface material 4 sections	\$1,200
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-08	Broken Surface Material	Replace broken surface material 4 sections	\$1,200
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-10	Broken Surface Material	Replace broken surface material 3 sections	\$900
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-12	Broken Surface Material	Replace broken surface material 2 sections	\$600
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-13	Broken Surface Material	Replace broken surface material 11 sections	\$3,300
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-03	Broken Surface Material	Replace broken surface material 3 sections	\$1,125
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-09	Broken Surface Material	Replace broken surface material 9 sections	\$2,625
SW0089		South 6th Street	Westgate Drive	Y	Y	Sidewalk starts at S 6th and limited to 2 properties	SW0089-02	Broken Surface Material	Replace broken surface material from new ramp at S 5th to 615	\$8,400
SW0089		South 6th Street	Westgate Drive	Y	Y	Sidewalk starts at S 6th and limited to 2 properties	SW0089-03	Broken Surface Material	Replace broken surface material from 616 termination	\$5,400
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-07	Canopy	Raise canopy to provide 80 inch vertical clearance	\$2,500
SW0080		North 1st Street	North 2nd Street	Y	Y	Sidewalk starts at N 1st to N 2nd	SW0080-01	Curb Ramp	Construct a compliant one way directional ramp with yellow truncated domes	\$2,800
SW0080		North 1st Street	North 2nd Street	Y	Y	Sidewalk starts at N 1st to N 2nd	SW0080-05	Curb Ramp	None required	\$0
SW0081		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-01	Curb Ramp	None required	\$0
SW0081		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-08	Curb Ramp	None required	\$0
SW0082		North 2nd Street	North 3rd Street	Y	Y	Sidewalk starts at N 2nd to N 3rd	SW0082-01	Curb Ramp	None required	\$0
SW0082		North 2nd Street	North 3rd Street	Y	Y	Sidewalk starts at N 2nd to N 3rd	SW0082-02	Curb Ramp	None required	\$0
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-01	Curb Ramp	None required	\$0
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-11	Curb Ramp	None required	\$0
SW0084		North 3rd Street	North 5th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	SW0084-01	Curb Ramp	None required	\$0
SW0084		North 3rd Street	North 5th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	SW0084-02	Curb Ramp	None required	\$0
SW0085		South 3rd Street	South 4th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	SW0084-01	Curb Ramp	Construct a compliant one way directional ramp with yellow truncated domes	\$1,550
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-01	Curb Ramp	None required	\$0
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-10	Curb Ramp	None required	\$0
SW0089		South 6th Street	Westgate Drive	Y	Y	Sidewalk starts at S 6th and limited to 2 properties	SW0089-01	Curb Ramp	None required	\$0
SW0080		North 1st Street	North 2nd Street	Y	Y	Sidewalk starts at N 1st to N 2nd	SW0080-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$4,200

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0083	West Main Street	South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes; Construct ramp across both the business garage entrance and through drive to provide a compliant ramp tied to the next business sidewalk	\$2,700
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-06	Drive Ramp	Construct a continuous compliant drive ramp with 25 cross slopes and 8.33% side slopes maximum across to drives	\$9,000
SW0087		North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,100
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$5,250
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-07	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0083		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0083-09	Electric meter	Provide cane protection below 27 inches	\$200
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-05	Grass	Spray grass and clean expansion joints	\$200
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-06	Grass	Trim and edge grass	\$0
SW0088		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-08	Grass	Trim and edge grass	\$500
SW0084		North 3rd Street	North 5th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0084		North 3rd Street	North 5th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0085		South 3rd Street	South 4th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0085		South 3rd Street	South 4th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0085		South 3rd Street	South 4th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0085		South 3rd Street	South 4th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0086		South 4th Street	South 5th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0086		South 4th Street	South 5th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0086		South 4th Street	South 5th Street	Y	Y	Sidewalk is poor quality where it exists: The businesses that are in this segment are not conducive to pedestrian traffic	NA	NA	No remediation required for now	\$0
SW0090		Westgate Drive	Jere B Ford Memorial Highway	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0091		Jere B Ford Memorial Highway	Future entry ramp	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0092		Jere B Ford Memorial Highway	Future exit ramp	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0093		Future entry ramp	Future exit ramp	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0094		Future exit ramp	Future entry ramp	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0095		Future exit ramp	Graham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0096		Future entry ramp	Old Lake Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0097		Graham Street	Springdale Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0098		Old Lake Road	Hollywood Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0099		Hollywood Road	Brevard Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0100		Springdale Drive	Clearbrook Dr	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0101		Clearbrook Dr	Brevard Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0088	South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0088-04	Scrub	Trim scrub from obstructing pathway	\$250	
SW0081	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-02	Sign	Provide cane protection below 27 inches	\$1,000	
SW0081	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-03	Sign	Provide cane protection below 27 inches	\$200	
SW0081	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-06	Sign	Provide cane protection below 27 inches	\$200	
SW0081	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-07	Sign	Provide cane protection below 27 inches	\$200	
SW0081	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-09	Sign	Provide cane protection below 27 inches	\$250	
SW0081	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0081-10	Sign	Provide cane protection below 27 inches	\$250	
SW0087	North 5th Street	Jere B Ford Memorial Highway	Y	Y	Sidewalk starts at N 5th Street and terminates just past 6th Street	SW0087-11	Sign	Raise sign to 80 inch minimum vertical distance	\$200	
West Main Street Remediation Estimated Costs:										\$77,650
SW0102	North 5th Street	Law Lane	Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0103		Barnham Road	Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0104		Robinhood Drive	West Tate Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0105		Robinhood Drive	West Tate Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0106		West Tate Street	Westview Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0107		West Tate Street	North Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0108		North Drive	Westview Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0109		Westview Drive	West Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0110		Westview Drive	West Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0111		West Cheatham Street	West Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0112		West Cheatham Street	West Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0113	West Gibbs Street	West Palmer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0114	West Gibbs Street	West Palmer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
North 5th Street Remediation Estimated Costs:										\$0
SW0116	North Drive	North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0116-05	Broken Surface Material	Replace broken surface material	\$575
SW0116		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0116-01	Curb Ramp	Construct a compliant one way directional; Add yellow truncated domes	\$1,550
SW0116		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0116-06	Curb Ramp	Construct one way directional ramp; add yellow truncated domes	\$1,550

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0116	North Drive	North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0116-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,200
SW0116		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0116-04	Grass	Edge and clean grass various locations	\$200
SW0115		North 5th Street	North 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0116		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0116-02	Settling	Replace sidewalk where settled	\$600
North Drive Remediation Estimated Costs:										\$5,675
SW0117	Westview Drive	North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-02	Broken Surface Material	Replace broken surface material	\$900
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-04	Broken Surface Material	Replace broken surface material	\$900
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-06	Broken Surface Material	Replace broken surface material	\$600
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-07	Broken Surface Material	Replace broken surface material	\$600
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-08	Broken Surface Material	Replace broken surface material	\$900
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 206	SW0119-02	Broken Surface Material	Replace broken surface material	\$2,100
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 207	SW0119-03	Broken Surface Material	Replace broken surface material	\$900
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 208	SW0119-04	Broken Surface Material	Replace broken surface material	\$1,200
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 209	SW0119-05	Broken Surface Material	Replace broken surface material	\$600
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 211	SW0119-07	Broken Surface Material	Replace broken surface material	\$600
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 212	SW0119-08	Broken Surface Material	Replace broken surface material	\$1,200
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-01	Curb Ramp	Extend sidewalk to curb; Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,850
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-10	Curb Ramp	Construct a diagonal ramp; add yellow truncated domes	\$2,150
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 205	SW0118-01	Curb Ramp	Extend sidewalk to curb; Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,850
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 215	SW0119-11	Curb Ramp	Construct a diagonal ramp; add yellow truncated domes	\$2,150
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 213	SW0119-09	Drive Ramp	Replace sidewalk side slopes	\$2,400
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 210	SW0119-06	Grass	Edge and clean grass various locations	\$300
SW0118		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th Street to 214	SW0119-10	Missing sidewalk	Replace missing sidewalk	\$9,600
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-03	Settling	Replace sidewalk where settled	\$600
SW0117		North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-05	Settling	Replace sidewalk where settled	\$600
SW0117	North 5th Street	North 2nd Street	Y	Y	Sidewalk starts at N 5th to N 2nd	SW0117-09	Settling	Replace sidewalk where settled	\$600	
Westview Drive Remediation Estimated Costs:										\$32,600
SW0119	West Tate Street	West 5th Street	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0120				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Tate Street Remediation Estimated Costs:										\$0
SW0128	North 1st Street	West Palmer Street	West College Street	Y	Y	Sidewalk starts at N 1st to W Palmer	SW0127-02	Broken Surface Material	Replace broken surface material 12 sections	\$3,600
SW0129		West Palmer Street	West College Street	Y	Y	Sidewalk starts at N 1st to W Palmer	SW0127-03	Broken Surface Material	Replace broken surface material 14 sections	\$4,200
SW0130		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to Martin Luther King	SW0129-02	Broken Surface Material	Replace broken surface material 6 sections	\$1,800
SW0131		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to Martin Luther King	SW0129-03	Broken Surface Material	Replace broken surface material 6 sections	\$1,800
SW0131		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0130-02	Broken Surface Material	Replace broken surface material 8 sections	\$2,400
SW0132		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to Martin Luther King	SW0129-04	Broken Surface Material	Replace broken surface material 16 sections	\$4,800
SW0133		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0130-04	Broken Surface Material	Replace broken surface material 10 sections	\$3,000
SW0133		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0132-02	Broken Surface Material	Replace sidewalk around the entire curb radius; Extend replacement to replace broken sidewalk past radius point	\$3,300
SW0134		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0131-04	Broken Surface Material	Replace broken surface material 6 sections	\$1,800
SW0138		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0136-03	Broken Surface Material	Replace broken surface material	\$1,200
SW0139		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0136-04	Broken Surface Material	Replace broken surface material	\$600
SW0133		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0131-03	Canopy	Raise canopy to provide 80 inch vertical clearance or provide cane protection	\$1,500
SW0123		West Cheatham Street	West Gibbs Street	Y	Y	Sidewalk only exists from Gibbs in front of 702	SW0123-01	Curb Ramp	Construct a compliant ramp; Add yellow truncated domes	\$2,600
SW0124		East Cheatham Street	East Gibbs Street	Y	Y	Sidewalk only exists from Gibbs in front of 711	SW0124-01	Curb Ramp	Construct a compliant ramp; Add yellow truncated domes	\$2,600
SW0125		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at West Gibbs to W Palmer	SW0125-01	Curb Ramp	Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,550
SW0126		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0126-01	Curb Ramp	Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,550

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0127	North 1st Street	West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at West Gibbs to W Palmer	SW0125-03	Curb Ramp	Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,550
SW0127		West Palmer Street	West College Street	Y	Y	Sidewalk starts at N 1st to W Palmer	SW0127-01	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes	\$3,100
SW0128		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0126-03	Curb ramp	Construct a diagonal ramp for street access with yellow truncated domes; Construct a switchback ramp with 8.335 maximum slope to tie into sidewalk grade; add handrails as required	\$8,200
SW0128		East Palmer Street	East College Street	Y	Y	Sidewalk starts E Palmer to E College	SW0128-01	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct a retaining walls as required and level landing for perpendicular landing access; grades of 8.33 % maximum for run slope	\$7,350
SW0129		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to Martin Luther King	SW0129-01	Curb Ramp	Add yellow truncated dome to existing ramp; Construct a new perpendicular with domes	\$3,100
SW0130		West Palmer Street	West College Street	Y	Y	Sidewalk starts at N 1st to W Palmer	SW0127-04	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes	\$4,900
SW0130		East Palmer Street	East College Street	Y	Y	Sidewalk starts E Palmer to E College	SW0128-03	Curb Ramp	Add yellow truncated dome to existing ramp; Construct a new perpendicular with domes	\$2,200
SW0130		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0130-01	Curb ramp	Construct a compliant diagonal ramp; Add yellow truncated domes; Level curb and gutter and street with paving; Replace sidewalk area in front of building	\$6,250
SW0131		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0131-01	Curb Ramp	Construct a compliant diagonal ramp; Add yellow truncated domes; Level curb and gutter and street with paving;	\$3,000
SW0132		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0132-01	Curb Ramp	Construct a compliant diagonal ramp; Add yellow truncated domes;	\$2,950
SW0133		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to Martin Luther King	SW0129-05	Curb Ramp	Extend sidewalk and construct a one way directional; Add dome; Construct a new perpendicular with domes	\$4,300
SW0133		West Leah Street	West Vine Street	Y	Y	Sidewalk starts at W Leah to W Vine	SW0133-01	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes	\$3,400
SW0134		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0130-05	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes	\$3,100
SW0134		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0132-03	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes	\$3,700
SW0134		East Leah Street	East Vine Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0134-01	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes	\$3,100
SW0135		West Vine Street	West Main Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0135-01	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Remove scrub for perpendicular ramp	\$3,100
SW0136		West Leah Street	West Vine Street	Y	Y	Sidewalk starts at W Leah to W Vine	SW0133-04	Curb Ramp	Add yellow truncated dome to existing ramp; Construct a new perpendicular with domes	\$2,200
SW0136		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0136-01	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Add horizontal guide if required	\$3,100
SW0137		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0131-07	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes	\$3,700
SW0137		East Leah Street	East Vine Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0134-04	Curb Ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Remove scrub for perpendicular ramp	\$3,600
SW0137		West Vine Street	West Main Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0135-03	Curb Ramp	Construct a ramp landing area flush with street for crossing; Add yellow domes	\$1,550
SW0140		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0136-05	Curb Ramp	Construct 2 perpendicular ramps; add yellow truncated domes; Add sidewalk behind pole for a 4 ft clear pathway	\$5,200
SW0126		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at West Gibbs to W Palmer	SW01225-02	Grass	Edge and clean grass from expansion joints various locations	\$300
SW0127		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0126-02	Grass	Edge and clean grass from expansion joints various locations	\$200
SW0129		East Palmer Street	East College Street	Y	Y	Sidewalk starts E Palmer to E College	SW0128-02	Grass	Edge and clean grass from expansion joints various locations	\$300
SW0132		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0130-03	Grass	Edge grass and clean expansion joints	\$300
SW0135		East Leah Street	East Vine Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0134-02	Grass	Edge grass and clean expansion joints	\$200
SW0136		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0131-06	Grass	Edge grass and clean expansion joints	\$300
SW0125		East Cheatham Street	East Gibbs Street	Y	Y	Sidewalk only exists from Gibbs in front of 712	SW0124-02	Missing sidewalk	City may choose to construct sidewalk later but not required as a part of the Self evaluation	\$0
SW0123		West Cheatham Street	West Gibbs Street	Y	Y	Sidewalk only exists from Gibbs in front of 703	SW0123-02	Missing sidewalk	City may choose to construct sidewalk later but not required as a part of the Self evaluation	\$0
SW0135		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0131-05	Missing sidewalk	Construct Sidewalk in drive continuation area	\$1,800
SW0135		West Leah Street	West Vine Street	Y	Y	Sidewalk starts at W Leah to W Vine	SW0133-03	Missing sidewalk	Replace sidewalk where asphalt	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0136	North 1st Street	West Vine Street	West Main Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0135-02	Missing sidewalk	Replace missing sidewalk in drive continuation area	\$1,500
SW0137		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0136-02	Missing sidewalk	Replace missing sidewalk in drive continuation area and past drive	\$2,100
SW0138		West Vine Street	West Main Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0135-04	Missing sidewalk	Sidewalk missing in property toward rail crossing; No replacement recommended for ADA Plan	\$0
SW0121		West Tate Street	West Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0122		West Tate Street	East Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0134		West Leah Street	West Vine Street	Y	Y	Sidewalk starts at W Leah to W Vine	SW0133-02	Settling	Replace sidewalk where settled	\$900
SW0132		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0131-02	Sign	Raise sign to 80 inch vertical minimum	\$200
SW0136		East Leah Street	East Vine Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0134-03	Trees	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$1,000
North 1st Street Remediation Estimated Costs:										\$130,950
SW0138	South 1st Street	East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-08	Banner	Provide cane protection below 27 inches	\$500
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-15	Banner	Provide cane protection below 27 inches	\$500
SW0139		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0139-04	Banner	Provide cane protection below 27 inches	\$500
SW0139		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0139-05	Banner	Provide cane protection below 27 inches	\$500
SW0143		Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-04	Banner	Raise banners to 80 inch minimum	\$250
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-06	Broken surface material	Replace broken surface material	\$900
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-07	Broken surface material	Replace broken surface material	\$900
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-04	Broken surface material	Replace broken surface material	\$1,200
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-06	Broken surface material	Replace broken surface material in sidewalk continuation area and ramp to street	\$4,200
SW0142		West Washington Avenue	Harrison Street	Y	Y	Sidewalk starts at W Washington to Harrison	SW0142-04	Broken surface material	Replace broken surface material in sidewalk continuation area and ramp to street	\$1,200
SW0143		Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-02	Broken surface material	Replace broken surface material in front of entire building	\$7,500
SW0137		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0137-03	Broken Surface Material	Replace broken surface material	\$750
SW0137		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0137-04	Broken Surface Material	Replace broken surface material	\$750
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-04	Broken Surface Material	Replace broken surface material	\$900
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-07	Broken Surface Material	Replace broken surface material	\$900
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-09	Broken Surface Material	Replace broken surface material	\$750
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-10	Broken Surface Material	Replace broken surface material	\$750
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-13	Broken Surface Material	Replace broken surface material	\$900
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-17	Broken Surface Material	Replace broken surface material	\$900
SW0139		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0139-03	Broken Surface Material	Replace broken surface material	\$900
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-08	Broken Surface Material	Replace broken surface material	\$600
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-09	Broken Surface Material	Replace broken surface material	\$1,200
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-03	Broken Surface Material	Replace broken surface material	\$750
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-05	Broken Surface Material	Replace broken surface material	\$750
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-07	Broken Surface Material	Replace broken surface material	\$375
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-08	Broken Surface Material	Replace broken surface material	\$375
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-09	Broken Surface Material	Replace broken surface material	\$1,875
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-10	Broken Surface Material	Replace broken surface material	\$1,125
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-05	Broken Surface Material	Replace broken surface material	\$384
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-07	Broken Surface Material	Replace broken surface material	\$1,125
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-03	Broken Surface Material	Replace broken surface material	\$1,500
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-04	Broken Surface Material	Replace broken surface material	\$2,250
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-03	Broken Surface Material	Replace broken surface material	\$1,200
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-05	Broken Surface Material	Replace broken surface material	\$1,200
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-06	Broken Surface Material	Replace broken surface material	\$1,800

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0148	South 1st Street	West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-07	Broken Surface Material	Replace broken surface material	\$2,250
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-08	Broken Surface Material	Replace broken surface material	\$1,800
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0149-10	Broken Surface Material	Replace broken surface material	\$3,300
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-03	Broken Surface Material	Replace broken surface material	\$5,100
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-11	Broken Surface Material	Replace broken surface material	\$7,500
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-12	Broken Surface Material	Replace broken surface material	\$750
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-14	Broken Surface Material	Replace broken surface material	\$4,500
SW0150		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0150-03	Broken Surface Material	Remove retaining wall and backfill slope after sidewalk replacement; Construct sidewalk along the extent of retaining to provide a 4 ft clear pathway	\$8,400
SW0151		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to E Jackson	SW0151-02	Broken Surface Material	Replace broken surface material	\$750
SW0151		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to E Jackson	SW0151-04	Broken Surface Material	Remove retaining wall and backfill slope after sidewalk replacement; Construct sidewalk along the extent of retaining to provide a 4 ft clear pathway	\$750
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-11	Canopy	Raise canopy to 80 inch minimum	\$1,500
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-02	Canopy	Raise canopy to 80 inch minimum	\$1,500
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-04	Canopy	Raise canopy to 80 inch minimum	\$2,500
SW0137		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0137-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0137		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0137-07	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-18	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0139		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0139-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0139		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0139-06	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0139		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0139-07	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-09	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-10	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-10	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-11	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0142		West Washington Avenue	Harrison Street	Y	Y	Sidewalk starts at W Washington to Harrison	SW0142-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0142		West Washington Avenue	Harrison Street	Y	Y	Sidewalk starts at W Washington to Harrison	SW0142-02	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0142		West Washington Avenue	Harrison Street	Y	Y	Sidewalk starts at W Washington to Harrison	SW0142-06	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0143		Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0143		Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-08	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-02	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-03	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-04	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-11	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-11	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-02	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-08	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-02	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-08	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-09	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-02	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-11	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-01	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-02	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-16	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0150		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0150-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0137		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0137-02	Drive Ramp	Replace broken surface material in ramp continuation: Cross slope limited to 2% maximum	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0137	South 1st Street	West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0137-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$4,800
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-02	Drive Ramp	Construct a compliant perpendicular ramp; Add yellow truncated domes	\$1,550
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$4,800
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-06	Drive Ramp	Construct Sidewalk in drive continuation area	\$1,500
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-07	Drive Ramp	Construct Sidewalk in drive continuation area	\$1,200
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-07	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-09	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,400
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-13	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,500
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-15	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,300
SW0150		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0150-04	Drive Ramp	Replace with 2 compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$6,750
SW0151		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to E Jackson	SW0151-01	Drive Ramp	Replace with compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes; Add yellow domes to each side of drive ramp on this drive like street	\$2,800
SW0151		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to E Jackson	SW0151-05	Drive Ramp	Replace with compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes;	\$1,200
SW0151		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to E Jackson	SW0151-07	Drive Ramp	Replace with compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes;	\$2,700
SW0153		East Jackson Street	West Wade Street	Y	Y	Sidewalk starts at E Jackson to one property at 100 E Jackson	SW0153-01	Drive Ramp	No remediation recommended unless City decides to do a street project	\$0
SW0154		West Wade Street	West Reelfoot Avenue	Y	Y	Sidewalk only exists by Family Video	SW0154-01	Drive Ramp	No remediation recommended unless City decides to do a street project	\$0
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-10	Grass	Trim and edge grass; clean expansion joints	\$200
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-03	Grass	Trim and edge grass; clean expansion joints	\$250
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-08	Grass	Trim and edge grass; clean expansion joints	\$200
SW0151		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to E Jackson	SW0151-06	Missing curb	Replace curb where missing	\$625
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-05	Missing sidewalk	Replace missing sidewalk and curb	\$1,450
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-02	Missing sidewalk	Construct sidewalk where missing	\$4,200
SW0152		West Jackson Street	West Wade Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0155		West Wade Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0156		West Reelfoot Avenue	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0157		East Reelfoot Avenue	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-06	Narrow Sidewalk	Replace sidewalk where narrowed	\$1,500
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-02	Pole	Level foundation; Add sidewalk to provide a 4 ft clear pathway minimum	\$1,200
SW0150		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0150-02	Pole	Part of sidewalk replacement below	\$0
SW0150		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0150-05	Pole	Construct sidewalk around pole for 4 ft pathway and replace all sidewalk between ramps	\$3,750
SW0149		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at E Bransford to E Park	SW0149-04	Run slope	Replace sidewalk to provide an 8.33% slope maximum	\$1,200
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-12	Sconces	Provide cane protection below 27 inches	\$500
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-14	Sconces	Provide cane protection below 27 inches	\$500
SW0139		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0139-02	Sconces	Provide cane protection below 27 inches	\$500
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-09	Sconces	Provide cane protection below 27 inches	\$250
SW0142		West Washington Avenue	Harrison Street	Y	Y	Sidewalk starts at W Washington to Harrison	SW0142-03	Sconces	Provide cane protection below 27 inches	\$250
SW0142		West Washington Avenue	Harrison Street	Y	Y	Sidewalk starts at W Washington to Harrison	SW0142-05	Scrub	Trim scrub from obstructing pathway	\$200
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-05	Scrub	Trim scrubs	\$200
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-07	Scrub	Trim scrubs	\$200
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-03	Settling	Replace sidewalk where settled	\$600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0143	South 1st Street	Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-05	Settling	Replace sidewalk where settled	\$1,500
SW0143		Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-06	Settling	Replace sidewalk where settled; Area vertically misaligned from new sidewalk to street	\$3,600
SW0144		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at S 1st to W Florida	SW0144-06	Settling	Replace sidewalk where settled	\$1,200
SW0145		East Lee Street	East Florida Avenue	Y	Y	Sidewalk starts at E Lee to E Florida	SW0145-06	Settling	Replace sidewalk where settled	\$600
SW0147		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0147-05	Settling	Replace sidewalk where settled	\$750
SW0148		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0148-04	Settling	Replace sidewalk where settled	\$1,500
SW0137		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0137-06	Sign	Provide cane protection below 27 inches	\$500
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-06	Sign	Provide cane protection below 27 inches	\$250
SW0138		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0138-16	Sign	Raise sign to 80 inch minimum vertical distance	\$250
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-03	Sign	Raise sign to 80 inch minimum	\$500
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-04	Sign	Raise sign to 80 inch minimum	\$500
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-05	Sign	Raise sign to 80 inch minimum	\$500
SW0140		East Church Street	West Washington Avenue	Y	Y	Sidewalk starts at E Church to W Washington	SW0140-08	Sign	Raise sign to 80 inch minimum	\$500
SW0141		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-07	Sign	Raise sign to 80 inch minimum	\$250
SW0143		Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-03	Sign	Raise sign to 80 inch minimum	\$250
SW0143		Harrison Street	East Lee Street	Y	Y	Sidewalk starts at Harrison to E Lee	SW0143-07	Sign	Raise sign to 80 inch minimum	\$250
SW0146		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0146-04	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$500
SW0151		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to E Jackson	SW0151-03	Utility cover	Replace cover and level area around to sidewalk	\$175
SW0141	West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0141-08	Wall AC Unit	Provide cane protection below 27 inches	\$250	
South 1st Street Remediation Estimated Costs:									\$163,259	
SW0166	North 2nd Street	West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-02	Broken Surface Material	Replace broken surface material	\$600
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-03	Broken Surface Material	Replace broken surface material	\$600
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-04	Broken Surface Material	Replace broken surface material	\$1,800
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-07	Broken Surface Material	Replace broken surface material	\$600
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-08	Broken Surface Material	Replace broken surface material	\$4,800
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-02	Broken Surface Material	Replace broken surface material	\$600
SW0170		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0170-04	Broken Surface Material	Replace broken surface material	\$600
SW0163		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk start at W Gibb to SW0163-06	SW0163-01	Curb ramp	Extend sidewalk and construct a one way directional ramp with yellow truncated domes; Construct a perpendicular ramp with domes	\$4,600
SW0163		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk start at W Gibb to SW0163-12	SW0163-07	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,400
SW0164		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0164-01	Curb ramp	Extend sidewalk and construct a one way directional ramp with yellow truncated domes; Construct a perpendicular ramp with domes	\$4,600
SW0164		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0164-06	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,400
SW0165		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0165-01	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,400
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-01	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,400
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-09	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$4,300
SW0167		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0165-03	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,400
SW0167		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewall starts at W College to MLK	SW0167-01	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,400
SW0167		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewall starts at W College to MLK	SW0167-06	Curb ramp	Extend sidewalk; Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; work around curb inlet	\$4,300
SW0168		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0168-01	Curb ramp	Extend sidewalk; Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; work around curb inlet	\$3,700

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0168	North 2nd Street	West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0168-06	Curb ramp	Extend sidewalk; Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; work around curb inlet	\$3,700
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-01	Curb ramp	Construct a compliant diagonal ramp with landing in ramp	\$2,600
SW0170		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0170-01	Curb ramp	Construct a compliant diagonal ramp with landing in ramp	\$2,600
SW0170		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0170-07	Curb ramp	Construct a compliant diagonal ramp with landing in ramp	\$2,600
SW0171		West Leah Street	West Vine Street	N	N	Sidewalk starts at W Leah to W Vine	SW0171-01	Curb ramp	No remediation recommended	\$0
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-05	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$1,200
SW0170		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0170-05	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$1,200
SW0163		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk start at W Gibb to SW0163-10	SW0163-05	Grass	Trim and edge grass; clean expansion joints	\$100
SW0164		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0164-03	Grass	Trim and edge grass; clean expansion joints	\$200
SW0164		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0164-04	Grass	Trim and edge grass; clean expansion joints	\$200
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0165-02	Grass	Trim and edge grass; clean expansion joints; clean up debris	\$250
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-05	Grass	Trim and edge grass; Clean expansion joints	\$100
SW0167		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0167-03	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0167		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0167-04	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0167		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0167-05	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0168		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0168-03	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-03	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-04	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-06	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-07	Grass	Trim and edge grass; Clean expansion joints; clean up debris	\$200
SW0169		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0169-08	Grass	Trim and edge grass; Clean expansion joints; clean up debris	\$200
SW0170		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0170-03	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0170		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0170-06	Grass	Trim and edge grass; Clean expansion joints	\$200
SW0163		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk start at W Gibb to SW0163-11	SW0163-06	Missing sidewalk	Extend sidewalk to W Palmer	\$9,300
SW0158		North Drive	Westview Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0159		Westview Drive	West Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0160		North Drive	West Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0161		West Cheatham Street	West Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0162		West Cheatham Street	West Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0172		West Vine Street	West Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0163		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk start at W Gibb to SW0163-09	SW0163-04	Scrub	Trim scrubs	\$100
SW0164		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0164-02	Scrub	Trim scrubs; Clean mulch and debris and install a landscape edge	\$750
SW0164		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0164-05	Settling	Replace sidewalk where settled	\$750
SW0166		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0166-06	Settling	Replace sidewalk where settled	\$900
SW0167		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0167-02	Settling	Replace sidewalk where settled	\$1,500
SW0168		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0168-04	Settling	Replace sidewalk where settled	\$600
SW0168		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0168-05	Settling	Replace sidewalk where settled	\$615
SW0170		Dr Martin Luther King Jr Drive	West Leah Street	Y	Y	Sidewalk starts at MLK to W Leah	SW0170-02	Settling	Replace sidewalk where settled	\$1,800
SW0163		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk start at W Gibb to SW0163-07	SW0163-02	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$300
SW0163		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk start at W Gibb to SW0163-08	SW0163-03	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$200
SW0168		West College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at W College to MLK	SW0168-02	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$500
North 2nd Street Remediation Estimated Costs:										\$85,765
SW0182	South 2nd Street	West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-08	Broken surface material	Replace broken surface material	\$300
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-14	Broken surface material	Replace broken surface material	\$600
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-02	Broken surface material	Replace broken surface material	\$300
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-07	Broken surface material	Replace broken surface material	\$300
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-09	Broken surface material	Replace broken surface material	\$309
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-04	Broken surface material	Replace broken surface material	\$600
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=03	Broken surface material	Replace broken surface material	\$900
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=04	Broken surface material	Replace broken surface material	\$900
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=05	Broken surface material	Replace broken surface material	\$600
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-03	Broken Surface Material	Reconstruct sidewalk	\$17,100
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-05	Broken Surface Material	Replace broken surface material	\$900
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-07	Broken Surface Material	Replace broken surface material	\$300

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0174	South 2nd Street	West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-09	Broken Surface Material	Replace broken surface material	\$1,800
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-02	Broken Surface Material	Replace broken surface material	\$900
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-05	Broken Surface Material	Replace broken surface material	\$3,300
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-07	Broken Surface Material	Replace broken surface material	\$1,200
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-08	Broken Surface Material	Replace broken surface material	\$1,200
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-09	Broken Surface Material	Replace broken surface material	\$1,200
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-11	Broken Surface Material	Replace broken surface material	\$13,200
SW0176		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0176-02	Broken Surface Material	Replace broken surface material	\$10,800
SW0176		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0176-04	Broken Surface Material	Replace broken surface material	\$6,000
SW0177		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0177-02	Broken Surface Material	Replace broken surface material; Replace with compliant ramps and sidewalks Recommend full block replacement in the retail properties fronts	\$22,650
SW0177		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0177-04	Broken Surface Material	Replace broken surface material	\$300
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-02	Broken Surface Material	Replace broken surface material; Replace with compliant ramps and sidewalks; Consider full block replacement in the retail properties fronts	\$1,500
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-03	Broken Surface Material	Replace broken surface material; Replace with compliant ramps and sidewalks; Consider full block replacement in the retail properties fronts	\$1,500
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-04	Broken Surface Material	Replace broken surface material; Replace with compliant ramps and sidewalks; Consider full block replacement in the retail properties fronts	\$1,500
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-06	Broken Surface Material	Replace broken surface material; Replace with compliant ramps and sidewalks; Consider full block replacement in the retail properties fronts	\$600
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-10	Broken Surface Material	Replace broken surface material	\$300
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-12	Broken Surface Material	Replace broken surface material	\$1,800
SW0179		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0179-02	Broken Surface Material	Replace broken surface material	\$1,200
SW0179		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0179-03	Broken Surface Material	Replace broken surface material	\$1,200
SW0179		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0179-04	Broken Surface Material	Replace broken surface material	\$900
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-05	Broken Surface Material	Replace broken surface material	\$600
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-01	Curb ramp	None required	\$0
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-10	Curb ramp	Reconstruct to have a depressed landing around radius; Add yellow truncated domes	\$3,750
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-01	Curb ramp	Construct a street bubble that will create a new radius that will be linear to the outer street parking along 2nd to allow 4 ft clear pathway at corner and 2 perpendicular ramps; Add yellow truncated domes	\$6,200
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-10	Curb ramp	Construct a street bubble that will create a new radius that will be linear to the outer street parking along 2nd to allow 4 ft clear pathway at corner and 2 perpendicular ramps; Add yellow truncated domes	\$5,200
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-01	Curb ramp	Add yellow truncated domes	\$350
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-13	Curb ramp	Construct street bubble to allow construction of 2 perpendicular ramps; Add yellow truncated domes	\$6,200
SW0176		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0176-01	Curb ramp	Construct street bubble to allow construction of 2 perpendicular ramps; Add yellow truncated domes	\$6,200
SW0176		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0176-05	Curb ramp	Construct street bubble to allow construction of 2 perpendicular ramps; Add yellow truncated domes	\$6,200
SW0177		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0177-01	Curb ramp	Add yellow truncated domes both ramps; Consider street bubbles in all downtown streets	\$700

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0177	South 2nd Street	West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0177-05	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; Construct a mid way common landing; Extend new sidewalk in each sidewalk direction; Run slopes need to be less than 8.33% and cross slopes of landing and sidewalks less than 2%	\$5,200
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-01	Curb ramp	Add yellow truncated domes both ramps; Consider street bubbles in all downtown streets	\$700
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-13	Curb ramp	Construct a depressed diagonal ramp; Add yellow truncated domes	\$2,950
SW0179		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0179-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; Construct a mid way common landing; Extend new sidewalk in each sidewalk direction; Run slopes need to be less than 8.33% and cross slopes of landing and sidewalks less than 2%	\$5,200
SW0179		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0179-05	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,400
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; Construct a mid way common landing; Extend new sidewalk in each sidewalk direction; Run slopes need to be less than 8.33% and cross slopes of landing and sidewalks less than 2%	\$4,300
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-09	Curb ramp	Extend sidewalk; Construct 2 compliant one way directional ramps; Add yellow truncated domes	\$4,300
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-15	Curb ramp	Construct a compliant diagonal ramp; Add yellow truncated domes	\$2,600
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-01	Curb ramp	Construct a compliant diagonal ramp; Add yellow truncated domes	\$2,250
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-13	Curb ramp	Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,250
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-01	Curb ramp	Construct a compliant diagonal ramp; Add yellow truncated domes	\$2,150
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-11	Curb ramp	Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,250
SW0185		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0185=01	Curb ramp	Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,250
SW0185		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0185=04	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$2,750
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=08	Curb ramp	Construct a compliant diagonal ramp; Add yellow truncated domes	\$2,150
SW0187		West Jackson Street	West Wade Street	Y	N	Sidewalk starts at W Jackson to W Wade	SW0187-01	Curb ramp	No remediation recommended	\$0
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-02	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps	\$3,100
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=01	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; Extend sidewalk	\$3,700
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-07	Debris	Clean up debris	\$100
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-04	Debris	Clean up debris and stabilize gravel	\$200
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-11	Debris	Clean up debris	\$100
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-03	Debris	Clean up debris	\$100
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-02	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$900
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-03	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$1,500
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-07	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$8,400
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-08	Drive Ramp	Replace ramp and section next to ramp	\$5,250
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-04	Drive Ramp	Replace ramp	\$7,350
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-10	Drive Ramp	Replace ramp	\$1,800
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-08	Drive Ramp	Replace sidewalk in drive ramp continuation area	\$1,200
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-10	Drive Ramp	Replace sidewalk in drive ramp continuation area	\$2,400
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-11	Drive Ramp	Replace sidewalk in drive ramp continuation area	\$600
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-06	Drive Ramp	Replace sidewalk in drive ramp continuation area	\$1,200
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-08	Drive Ramp	Replace sidewalk in drive ramp continuation area	\$900
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-04	Grass	Trim and edge grass; clean expansion joints	\$200
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-06	Grass	Trim and edge grass; clean expansion joints	\$200
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-09	Grass	Clean expansion joints	\$200
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-04	Grass	Clean expansion joints	\$200
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-06	Grass	Clean expansion joints	\$200
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-03	Grass	Edge and trim grass; clean expansion joints	\$300
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-06	Grass	Edge and trim grass; clean expansion joints	\$200

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0182	South 2nd Street	West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-12	Grass	Edge and trim grass: clean expansion joints	\$200
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-03	Grass	Edge and trim grass: clean expansion joints	\$200
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-06	Grass	Edge and trim grass: clean expansion joints	\$100
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-12	Grass	Edge and trim grass: clean expansion joints	\$200
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-02	Grass	Edge and trim grass: clean expansion joints	\$200
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-05	Grass	Edge and trim grass: clean expansion joints	\$200
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-07	Grass	Edge and trim grass: clean expansion joints	\$200
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-09	Grass	Edge and trim grass: clean expansion joints	\$200
SW0184		West Bransford Street	West Park Street	Y	Y	Sidewalk starts W Bransford to W Park	SW0184-10	Grass	Edge and trim grass: clean expansion joints	\$200
SW0185		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0185=02	Grass	Edge and trim grass: clean expansion joints	\$200
SW0185		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0185=03	Grass	Edge and trim grass: clean expansion joints	\$200
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=02	Grass	Edge and trim grass: clean expansion joints	\$200
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=06	Grass	Edge and trim grass: clean expansion joints	\$200
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-01	Mid Block Island	Construct median crossing sidewalk; Add yellow truncated domes	\$1,600
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-03	Missing curb	Replace missing curb	\$250
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-06	Missing curb	Replace missing curb	\$625
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-06	Missing sidewalk	Replace sidewalk where missing	\$300
SW0186		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0186=07	Missing sidewalk	Replace missing sidewalk	\$4,800
SW0181		West Florida Avenue	West Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0188		West Jackson Street	West Wade Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0189		West Wade Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0190		West Wade Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-08	Sconces	Provide cane protection below 27 inches	\$200
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-09	Scrub	Trim scrub	\$100
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-05	Scrub	Trim scrub	\$100
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-08	Scrub	Trim scrub	\$100
SW0173		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0173-05	Settling	Replace sidewalk where settled	\$40
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-05	Settling	Replace sidewalk where settled	\$1,200
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-11	Settling	Replace sidewalk where settled	\$600
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-02	Settling	Replace sidewalk in drive ramp continuation area	\$1,200
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-04	Settling	Replace sidewalk in drive ramp continuation area	\$1,200
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-05	Settling	Replace sidewalk in drive ramp continuation area	\$600
SW0180		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee Street to W Florida	SW0180-07	Settling	Replace sidewalk where settled	\$1,200
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-07	Settling	Replace sidewalk where vertically misaligned	\$600
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-10	Settling	Replace sidewalk where vertically misaligned	\$600
SW0182		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0182-13	Settling	Replace sidewalk where vertically misaligned	\$600
SW0183		West Bransford Street	West Park Street	Y	Y	Sidewalk starts at W Bransford to W Park	SW0183-04	Settling	Replace sidewalk where settled	\$1,200
SW0174		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0174-02	Sign	Move sign to outside of street bubble; Raise to 80 inch minimum	\$500
SW0175		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0175-12	Sign	Provide cane protection	\$500
SW0176		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0176-03	Sign	Move with bubble construction Provide cane protection	\$500
SW0177		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0177-03	Slope	Replace sidewalk with maximum of 8.33% run slopes and 2% maximum drive slopes	\$1,200
SW0178		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0178-09	Upheaval	Replace sidewalk where heaved from tree roots; Run slope will need to be ramped up, over, and down over roots at 8.33% slope and 2 % cross slope; Will need to provide Geotech barrier below sidewalk	\$2,100
South 2nd Street Remediation Estimated Costs:										\$238,374
SW0194	North 3rd Street	West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0194-02	Broken surface material	Replace broken surface material	\$600
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-05	Broken surface material	Replace broken surface material	\$600
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-08	Broken surface material	Replace broken surface material	\$4,200
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-02	Broken surface material	Replace broken surface material	\$300
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-06	Broken surface material	Replace broken surface material	\$1,500
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-07	Broken surface material	Replace broken surface material	\$1,200
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-08	Broken surface material	Replace broken surface material	\$600
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-09	Broken surface material	Replace broken surface material	\$900
SW0191		West Cheatham Street	West Gibbs Street	Y	Y	Sidewalk starts at W Cheatham and limited to one property	SW0191-01	Curb ramp	No remediation recommended	\$0
SW0194		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW-0194-04	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; Extend sidewalk	\$3,100
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-01	Curb ramp	Construct a compliant one way directional ramp; Extend sidewalk; Add yellow truncated domes	\$2,150

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est. (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0196	North 3rd Street	West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-09	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; Extend sidewalk	\$3,700
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-01	Curb ramp	Construct a compliant one way directional ramp; Add yellow truncated domes	\$1,550
SW0200		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to Railroad	SW0200-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; Construct a mid way common landing; Extend new sidewalk in each sidewalk direction; Run slopes need to be less than 8.33% and cross slopes of landing and sidewalks less than 2%	\$3,100
SW0194		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW-0194-01	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; Extend sidewalk	\$3,100
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-07	Drive Ramp	Replace sidewalk in drive ramp continuation area	\$1,800
SW0194		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW-0194-02	Grass	Edge and trim grass: clean expansion joints	\$200
SW0194		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0194-03	Grass	Edge and trim grass: clean expansion joints	\$200
SW0194		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW-0194-03	Grass	Edge and trim grass: clean expansion joints	\$100
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-02	Grass	Edge and trim grass: clean expansion joints	\$200
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-06	Grass	Edge and trim grass: clean expansion joints	\$200
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-03	Grass	Edge and trim grass: clean expansion joints	\$200
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-04	Grass	Edge and trim grass: clean expansion joints	\$200
SW0200		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to Railroad	SW0200-02	Grass	Edge and trim grass: clean expansion joints	\$200
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-03	Heaved	Replace sidewalk with maximum of 8.33% run slopes and 2% maximum cross slopes ; Use Geotech	\$1,200
SW0196		West Palmer Street	West College Street	Y	Y	Sidewalk starts at W Palmer to W College	SW0196-04	Heaved	Replace sidewalk with maximum of 8.33% run slopes and 2% maximum cross slopes ; Use Geotech	\$900
SW0200		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to Railroad	SW0200-03	Missing sidewalk	No remediation recommended	\$0
SW0200		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to Railroad	SW0200-04	Missing sidewalk	No remediation recommended	\$0
SW0199		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk starts at MLK to W Main	SW0199-05	Missing sidewalk	No remediation recommended	\$0
SW0192		West Cheatham Street	West Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0193		West Gibbs Street	West Palmer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0195		West Palmer Street	West College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0197		West College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0198		West College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0194		West Gibbs Street	West Palmer Street	Y	Y	Sidewalk starts at W Gibbs to W Palmer	SW0194-04	Scrubs	Trim scrubs	\$100
North 3rd Street Remediation Estimated Costs:										\$32,100
SW0201	South 3rd Street	West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-02	Broken surface material	Replace broken surface material	\$300
SW0201		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-04	Broken surface material	Replace broken surface material	\$900
SW0201		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-06	Broken surface material	Replace broken surface material	\$600
SW0202		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to 222	SW0202-01	Broken surface material	Replace broken surface material from sidewalk continuation from corner at West Main to 222	\$24,600
SW0204		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0203-02	Broken surface material	Broken surface material long frontage of 311	\$3,000
SW0205		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0203-03	Broken surface material	Broken surface material	\$900
SW0206		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0203-04	Broken surface material	Broken surface material	\$900
SW0201		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-08	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; Construct a mid way common landing; Extend new sidewalk in each sidewalk direction; Run slopes need to be less than 8.33% and cross slopes of landing and sidewalks less than 2%	\$3,000
SW0202		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to 222	SW0202-02	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; Extend sidewalk	\$3,400
SW0203		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0203-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0204		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0204-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0204		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0204-03	Curb ramp	Replace with a compliant diagonal ramp with landing in ramp; Add yellow truncated domes	\$2,600
SW0207		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0203-05	Curb ramp	Construct a compliant one way directional ramp; Construct a compliant perpendicular ramp; Add yellow truncated domes; Construct landings for ramps; Extend sidewalk	\$3,400

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est. (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0201	South 3rd Street	West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-01	Drive Ramp	Replace broken surface material in sidewalk continuation area and ramp to street	\$1,200
SW0204		West Church Street	Bill Burnett Circle	Y	Y	Sidewalk starts at W Church to Bill Burnett	SW0204-02	Drive Ramp	Construct sidewalk continuation area missing	\$1,200
SW0201		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-03	Grass	Edge and trim grass: clean expansion joints	\$200
SW0201		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-05	Grass	Edge and trim grass: clean expansion joints	\$200
SW0201		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0201-07	Heaved	Replace sidewalk where heaved	\$1,200
South 3rd Street Remediation Estimated Costs:										\$53,100
SW0214	Bill Burnett Circle	N-S - Eastside	West Washington Avenue	Y	Y	Sidewalk along outside perimeter	SW0214-02	Broken surface material	Broken surface material	\$600
SW0216		E - W turn - North Side	N - S turn - West Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0216-01	Broken surface material	Broken surface material	\$750
SW0216		E - W turn - North Side	N - S turn - West Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0216-02	Broken surface material	Broken surface material	\$900
SW0205		South 3rd Street	N - S turn - West Side	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0209		E - W turn - South Side	N - S turn - East Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0209-02	Curb ramp	Construct a compliant parallel ramp; Add yellow truncated domes	\$2,800
SW0213		West Washington Avenue	E - W turn - North Side	Y	Y	Sidewalk along outside perimeter	SW0213-01	Curb ramp	Add yellow truncated domes	\$350
SW0213		West Washington Avenue	E - W turn - North Side	Y	Y	Sidewalk along outside perimeter	SW0213-03	Curb ramp	Construct 2 perpendicular ramps	\$2,500
SW0214		N-S - Eastside	West Washington Avenue	Y	Y	Sidewalk along outside perimeter	SW0214-01	Curb ramp	Add yellow truncated domes	\$350
SW0214		N-S - Eastside	West Washington Avenue	Y	Y	Sidewalk along outside perimeter	SW0214-03	Curb ramp	Add yellow truncated domes	\$350
SW0215		E - W turn - North Side	South 3rd Street	Y	Y	Sidewalk along outside perimeter	SW0215-01	Curb ramp	Construct one way directional ramp; add yellow truncated domes	\$1,550
SW0208		N - S turn - West Side	E - W turn - South Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0208-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,800
SW0212		N - S turn - East Side	E - W turn - North Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0212-02	Meter	Level surface and meter box to eliminate vertical misalignment	\$475
SW0206		N - S turn - West Side	West Washington Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0207		West Washington Avenue	E - W turn - South Side	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0210		E - W turn - South Side	South 3rd Street	N	N	Sidewalk around entire perimeter of County Bldg.	NA	NA	No Barriers	\$0
SW0211		South 3rd Street	N - S turn - East Side	N	N	Sidewalk around entire perimeter of County Bldg.	NA	NA	No Barriers	\$0
SW0213		West Washington Avenue	E - W turn - North Side	Y	Y	Sidewalk along outside perimeter	SW0213-02	Pole	Widen sidewalk this block to allow for a 4 ft clear pathway	\$9,000
SW0212		N - S turn - East Side	E - W turn - North Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0212-05	Riser	Level surface and meter box to eliminate vertical misalignment; Reconstruct sidewalk to provide a 4 ft clear pathway or move or modify riser	\$3,000
SW0215		E - W turn - North Side	South 3rd Street	Y	Y	Sidewalk along outside perimeter	SW0215-02	Settling	Replace area where settled	\$600
SW0208		N - S turn - West Side	E - W turn - South Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0208-02	Sign	Raise sign to 80 inch vertical minimum	\$200
SW0209		E - W turn - South Side	N - S turn - East Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0209-01	Sign	Raise sign to 80 inch vertical minimum	\$200
SW0209		E - W turn - South Side	N - S turn - East Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0209-03	Sign	Raise sign to 80 inch vertical minimum	\$200
SW0212		N - S turn - East Side	E - W turn - North Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0212-01	Sign	Raise signs	\$200
SW0212		N - S turn - East Side	E - W turn - North Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0212-03	Sign	Raise sign	\$100
SW0212		N - S turn - East Side	E - W turn - North Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0212-04	Sign	Raise sign	\$100
SW0216		E - W turn - North Side	N - S turn - West Side	Y	Y	Sidewalk around entire perimeter of County Bldg.	SW0216-03	Sign	Raise sign	\$100
Bill Burnett Circle Remediation Estimated Costs:										\$26,125
SW0217	South 3rd Street	Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-03	Broken surface material	Broken surface material	\$600
SW0217		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-04	Broken surface material	Broken surface material	\$600
SW0217		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-06	Broken surface material	Broken surface material	\$1,200
SW0217		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-07	Broken surface material	Replace broken surface material	\$1,500
SW0218		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0218-04	Broken surface material	Replace broken surface material	\$600
SW0218		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0218-05	Broken surface material	Replace broken surface material	\$600
SW0219		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-02	Broken surface material	Replace broken surface material	\$600
SW0219		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-05	Broken surface material	Replace broken surface material from 611 to 619	\$12,000
SW0219		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-06	Broken surface material	Replace broken surface material	\$600
SW0220		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0220-02	Broken surface material	Replace broken surface material and poor quality material from Lee to Florida: Extend sidewalk in all sidewalk continuation areas	\$24,600
SW0221		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0221-03	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0221		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0221-04	Broken surface material	Replace broken surface material and poor quality material from 706 to 808	\$18,000
SW0222		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0222-02	Broken surface material	Replace broken surface material and poor quality material	\$7,200
SW0222		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0222-03	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW0222		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0222-04	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0223		West Bransford Street	West Park Street	Y	Y	Sidewalk starts are W Bransford to W Park	SW0223-04	Broken surface material	Replace broken surface material and poor quality material	\$4,400
SW0224		West Bransford Street	West Sterling Street	Y	Y	Sidewalk starts at W Florida to W Sterling	SW0224-02	Broken surface material	Replace broken surface material and poor quality material entire segment	\$25,200

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0225	South 3rd Street	West Sterling Street	West Jackson Street	Y	Y	Sidewalk starts at W Sterling to W Jackson	SW0225-02	Broken surface material	Replace broken surface material and poor quality material entire segment	\$10,800
SW0226		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0226-02	Broken surface material	Replace broken surface material and poor quality material entire segment	\$5,400
SW0218		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0218-06	Curb Ramp	Newly Constructed Compliant Ramp	\$0
SW0217		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-01	Curb ramp	Replace with a one way directional ramp with yellow truncated domes	\$1,550
SW0217		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-10	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0218		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0218-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0219		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0219		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-08	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0220		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0220-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0220		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0220-04	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0221		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0221-02	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0221		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0221-05	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalks	\$3,400
SW0222		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0222-05	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalks	\$3,400
SW0223		West Bransford Street	West Park Street	Y	Y	Sidewalk starts are W Bransford to W Park	SW0223-01	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalks	\$3,400
SW0223		West Bransford Street	West Park Street	Y	Y	Sidewalk starts are W Bransford to W Park	SW0223-05	Curb Ramp	Construct a one way directional ramp; add domes	\$1,900
SW0224		West Bransford Street	West Sterling Street	Y	Y	Sidewalk starts at W Florida to W Sterling	SW0224-01	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalks	\$3,400
SW0224		West Bransford Street	West Sterling Street	Y	Y	Sidewalk starts at W Florida to W Sterling	SW0224-03	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalks	\$3,400
SW0225		West Sterling Street	West Jackson Street	Y	Y	Sidewalk starts at W Sterling to W Jackson	SW0225-01	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,500
SW0225		West Sterling Street	West Jackson Street	Y	Y	Sidewalk starts at W Sterling to W Jackson	SW0225-03	Curb ramp	Construct a parallel ramp near stop sign; Add yellow truncated domes	\$2,150
SW0226		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0226-01	Curb ramp	Construct a one way directional ramp near stop sign; Add yellow truncated domes	\$1,550
SW0226		West Park Street	West Jackson Street	Y	Y	Sidewalk starts at W Park to W Jackson	SW0226-03	Curb ramp	Construct a diagonal ramp with domes and avoid catch basin	\$1,800
SW0218		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0218-02	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$4,800
SW0218		Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0218-03	Drive Ramp	Construct sidewalk in the drive continuation area	\$1,800
SW0219		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-04	Grass	Edge and trim grass: clean expansion joints	\$200
SW0219		West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-07	Grass	Edge and trim grass: clean expansion joints	\$200
SW0223		West Bransford Street	West Park Street	Y	Y	Sidewalk starts are W Bransford to W Park	SW0223-02	Grass	Edge and trim grass: clean expansion joints	\$200
SW0223		West Bransford Street	West Park Street	Y	Y	Sidewalk starts are W Bransford to W Park	SW0223-03	Grass	Edge and trim grass: clean expansion joints	\$200
SW0221		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0221-01	Median Crossing	Newly Constructed Compliant Ramp	\$0
SW0222		West Florida Avenue	West Bransford Street	Y	Y	Sidewalk starts at W Florida to W Bransford	SW0222-01	Median Crossing	Newly Constructed Compliant Ramp	\$0
SW0227		West Jackson Street	West Wade Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0228		West Wade Street	West Wade Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0229		West Wade Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0230	West Wade Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0217	Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-05	Scrubs	Trim scrubs	\$500	
SW0220	West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0220-03	Scrubs	Trim scrubs to allow a 4 ft clear pathway	\$500	
SW0217	Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-02	Settling	Replace area where settled multiple locations	\$2,700	
SW0217	Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-08	Settling	Replace area where settled multiple locations	\$600	
SW0219	West Lee Street	West Florida Avenue	Y	Y	Sidewalk from W Lee to W Florida	SW0219-03	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$300	
SW0217	Bill Burnett Circle	West Lee Street	Y	Y	Sidewalk from Bill Burnett to W Lee	SW0217-09	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$300	
South 3rd Street Remediation Estimated Costs:										\$167,250
SW0231	North 4th Street	West Cheatham Street	West Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0232				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0233		West Gibbs Street	West Palmer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0234				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North 4th Street Remediation Estimated Costs:										\$0
SW0235	South 4th Street	West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0235-01	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0235		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0235-02	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0236		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0236-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0236		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0236-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0236		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0236-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0236		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0236-05	Broken surface material	Replace broken surface material and poor quality material	\$5,100
SW0236		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0236-06	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-02	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-07	Broken surface material	Replace broken surface material and poor quality material	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0237	South 4th Street	West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-08	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0238		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0238-03	Broken surface material	Replace broken surface material and poor quality material	\$6,300
SW0239		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-04	Broken surface material	Replace broken surface material and poor quality material	\$9,000
SW0240		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-08	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0241		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW241-02	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-02	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-07	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-10	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-11	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0235		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0235-05	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes;	\$3,100
SW0236		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0236-07	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes ;Extend sidewalk	\$3,400
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-01	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$4,300
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-09	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$2,400
SW0238		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0238-01	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$3,100
SW0238		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0238-05	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$3,400
SW0239		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-01	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$3,400
SW0239		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-05	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$3,400
SW0240		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-07	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$4,300
SW0240		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-10	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$3,100
SW0241		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW241-01	Curb ramp	Construct a perpendicular ramp; Add yellow truncated domes both ramps	\$1,900
SW0241		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW241-05	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,300
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-01	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$4,000
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-12	Curb Ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$4,000
SW0235		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0235-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,200
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-06	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$1,200
SW0239		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-03	Drive Ramp	Construct sidewalk in the drive continuation	\$1,200
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-08	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$0
SW0236		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0236-01	Grass	Edge and trim grass	\$200
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-03	Grass	Edge and trim grass	\$200
SW0238		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0238-02	Grass	Edge and trim grass	\$200
SW0240		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0241		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW241-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-06	Grass	Edge and trim grass; clean expansion joints	\$0
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0238		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0238-06	Median Crossing	Construct median sidewalk; Add truncated domes	\$1,900
SW0240		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-06	Median Crossing	Construct median sidewalk; Add truncated domes	\$1,900
SW0241		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW241-06	Median Crossing	Construct sidewalk across median: add yellow truncated domes	\$1,900
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-13	Median Crossing	Construct sidewalk across median: add yellow truncated domes	\$1,900
SW0238		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0238-04	Missing sidewalk	Construct sidewalk along the parking lot for pedestrian pathway	\$9,600
SW0239		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0239-02	Missing sidewalk	Construct sidewalk along the parking lot for pedestrian pathway, drive and buildings	\$9,600
SW0243		West Jackson Street	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0244		West Wade Street	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0245		West Wade Street	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0237		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0237-05	Settling	Replace sidewalk where settled	\$600
SW0241		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW241-04	Settling	Replace sidewalk where settled	\$600
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-04	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$300
SW0242		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee to W Florida	SW242-05	Vegetation	Trim vegetation	\$200
SW0235		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0235-04	Vegetation	Trim and edge vegetation	\$200
South 4th Street Remediation Estimated Costs:										\$135,700

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0246	North 5th Street	Railroad Tracks	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0247				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0248				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0249		Dr Martin Luther King Jr Drive	West Main Street	Y	Y	Sidewalk limited to Firehall and Union City Glass	SW0249-01	NA	No Barriers	\$0
North 5thStreet Remediation Estimated Costs:										\$0
SW0250	South 5th Street	West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-09	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-11	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0251		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0251-02	Broken surface material	Replace broken surface material and poor quality material	\$8,400
SW0251		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0251-05	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0252		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0252-03	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0252		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0252-04	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-08	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-09	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-10	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-12	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-14	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-05	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-10	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0256		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee t5o W Florida	SW0256-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0256		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee t5o W Florida	SW0256-03	Broken surface material	Replace broken surface material and poor quality material	\$4,500
SW0256		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee t5o W Florida	SW0256-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0256		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee t5o W Florida	SW0256-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0256		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee t5o W Florida	SW0256-06	Broken surface material	Replace broken surface material and poor quality material	\$9,600
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-13	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-14	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-17	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-32	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-34	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-37	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-40	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-41	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-13	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$4,000
SW0251		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0251-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$4,000
SW0251		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0251-07	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,700
SW0252		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0252-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0252		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0252-05	Curb ramp	Construct a perpendicular ramps with yellow truncated domes	\$1,550

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est. (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0252	South 5th Street	West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0252-06	Curb ramp	Construct one way directional ramp; add yellow truncated domes	\$1,550
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-15	Curb ramp	Construct a perpendicular ramps with yellow truncated domes	\$1,200
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-11	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$4,000
SW0256		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee t5o W Florida	SW0256-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$4,000
SW0256		West Lee Street	West Florida Avenue	Y	Y	Sidewalk starts at W Lee t5o W Florida	SW0256-07	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,700
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-01	Curb ramp	Add yellow truncated domes	\$350
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-02	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-03	Drive Ramp	Replace broken surface material and poor quality material	\$600
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-04	Drive Ramp	Replace broken surface material and poor quality material	\$600
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-06	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-03	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$1,500
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-05	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$3,900
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-07	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$3,900
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-08	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-10	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-15	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-18	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-21	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-23	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-25	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-28	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-31	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,250
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-39	Drive Ramp	Replace broken surface material and poor quality material	\$1,500
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-10	Grass	Edge and trim grass; clean expansion joints	\$200
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-12	Grass	Edge and trim grass; clean expansion joints	\$200
SW0251		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0251-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0251		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0251-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0251		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0251-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0252		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0252-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0254		West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-13	Grass	Edge and trim grass; clean expansion joints	\$200
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0255		West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-11	Grass	Edge and trim grass; clean expansion joints	\$200
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-20	Grass	Edge and trim grass; clean expansion joints	\$200
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-27	Grass	Edge and trim grass; clean expansion joints	\$200
SW0257		West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-38	Grass	Edge and trim grass; clean expansion joints	\$200
SW0250		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0250-01	Missing sidewalk	Construct sidewalk across gas station lot	\$13,800
SW0253		West Church Street	West Washington Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0258		West Florida Avenue	West Jackson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0259		West Jackson Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-06	Pole	Construct sidewalk to allow a 4 ft clear pathway	\$750	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-12	Pole	Construct sidewalk to allow a 4 ft clear pathway	\$750	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-16	Pole	Construct sidewalk to allow a 4 ft clear pathway	\$1,125	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-24	Pole	Construct sidewalk to allow a 4 ft clear pathway	\$750	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-29	Pole	Construct sidewalk to allow a 4 ft clear pathway	\$750	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-33	Pole	Construct sidewalk to allow a 4 ft clear pathway	\$750	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-35	Pole	Construct sidewalk to allow a 4 ft clear pathway	\$750	
SW0254	West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-05	Settling	Replace sidewalk where settled	\$600	
SW0254	West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-07	Settling	Replace sidewalk where settled	\$900	
SW0254	West Washington Avenue	West Florida Avenue	Y	Y	Sidewalk starts at W Washington to W Florida	SW0254-11	Settling	Replace sidewalk where settled	\$900	
SW0255	West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-03	Settling	Replace sidewalk where settled	\$1,200	
SW0255	West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-04	Settling	Replace sidewalk where settled	\$600	
SW0255	West Washington Avenue	West Lee Street	Y	Y	Sidewalk starts at W Washington to W Lee	SW0255-06	Settling	Replace sidewalk where settled	\$600	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-09	Settling	Replace sidewalk where settled	\$600	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-19	Settling	Replace sidewalk where settled	\$900	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-22	Settling	Replace sidewalk where settled	\$900	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-26	Settling	Replace sidewalk where settled	\$600	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-30	Settling	Replace sidewalk where settled	\$600	
SW0257	West Florida Avenue	West Reelfoot Avenue	Y	Y	Starts at W Florida to Transformer Station	SW0257-36	Settling	Replace sidewalk where settled	\$1,200	
South 5th Street Remediation Estimated Costs:										\$173,025

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		Prowag PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	Prowag Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0263	North 6th Street	West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-07	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-10	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-11	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-02	Broken surface material	Replace broken surface material and poor quality material	\$1,360
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-11	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-04	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-08	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-09	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-14	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-15	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,700
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-01	Curb ramp	Construct one way directional ramp; add yellow truncated domes	\$1,550
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-12	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-12	Grass	Edge and trim grass; clean expansion joints	\$200
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-10	Grass	Edge and trim grass; clean expansion joints	\$200
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-12	Grass	Edge and trim grass; clean expansion joints	\$200
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-13	Missing sidewalk	Replace missing sidewalk	\$6,000
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-11	Missing sidewalk	Replace missing sidewalk	\$6,600
SW0260		West Cheatham Street	Railroad Tracks	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0261		West Cheatham Street	West Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0262		West Gibbs Street	Railroad Tracks	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0266		West Washington Avenue	Pryor Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0267		West Washington Avenue	West Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0268		West Washington Avenue	West Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0263		West Main Street	West Washington Avenue	Y	Y	Sidewalk from W Main to W Washington	SW0263-08	Settling	Replace sidewalk where settled	\$2,100
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-04	Settling	Replace sidewalk where settled	\$600
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-05	Settling	Replace sidewalk where settled	\$600
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-08	Settling	Replace sidewalk where settled	\$600
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-09	Settling	Replace sidewalk where settled	\$600
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-13	Settling	Replace sidewalk where settled	\$600
SW0264		West Main Street	West Church Street	Y	Y	Sidewalk starts at W Main to W Church	SW0264-14	Settling	Replace sidewalk where settled	\$600
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-03	Settling	Replace sidewalk where settled	\$1,500
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-07	Settling	Replace sidewalk where settled	\$1,200
SW0265		West Church Street	West Washington Avenue	Y	Y	Sidewalk starts at W Church to W Washington	SW0265-10	Settling	Replace sidewalk where settled	\$600
North 6th Street Remediation Estimated Costs:										\$51,910
SW0269	Pryor Lane	South 6th Street	South 7th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0270				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Pryor Lane Remediation Estimated Costs:										\$0
SW0271	South 7th Street	Pryor Lane	West Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0272				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
South 7th Street Remediation Estimated Costs:										\$0
SW0273	East Tate Street	North Baker Street	North Division Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0274				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Tate Street Remediation Estimated Costs:										\$0
SW0275	North Baker Street	East Tate Street	East Todd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0276				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0277		East Todd Street	East Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0278				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North Baker Street Remediation Estimated Costs:										\$0
SW0279	North Division Street	East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-03	Broken surface material	Replace broken surface material and poor quality material	\$1,980
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-08	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-12	Broken surface material	Replace broken surface material and poor quality material	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers In Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0280	North Division Street	East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-05	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-07	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-04	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-05	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0282		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0282-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0282		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0282-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0283		East Cheatham Street	East Gibbs Street	Y	Y	Sidewalk starts at E Cheatham to E Gibbs	SW0283-02	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0283		East Cheatham Street	East Gibbs Street	Y	Y	Sidewalk starts at E Cheatham to E Gibbs	SW0283-03	Broken surface material	Replace broken surface material and poor quality material to E Gibbs	\$18,000
SW0284		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0284-02	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$16,200
SW0285		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts E Mercer to E Gibbs	SW0285-02	Broken surface material	Replace broken surface material and poor quality material	\$5,100
SW0285		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts E Mercer to E Gibbs	SW0285-03	Broken surface material	Replace broken surface material and poor quality material in drive sidewalk continuation area	\$900
SW0285		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts E Mercer to E Gibbs	SW0285-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0285		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts E Mercer to E Gibbs	SW0285-05	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0285		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts E Mercer to E Gibbs	SW0285-06	Broken surface material	Replace broken surface material and poor quality material	\$9,000
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-06	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-08	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-10	Broken surface material	Replace broken surface material and poor quality material	\$5,400
SW0288		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0288		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-03	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0288		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0288		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-07	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0290		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0290-02	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$14,400
SW0291		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0291-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0293		East Leah Street	East Main Street	Y	Y	Sidewalk starts at E Leah E Vine Street	SW0293-03	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0293		East Leah Street	East Main Street	Y	Y	Sidewalk starts at E Leah E Vine Street	SW0293-05	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0293		East Leah Street	East Main Street	Y	Y	Sidewalk starts at E Leah E Vine Street	SW0293-06	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-14	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-09	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-08	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0282		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0282-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0282		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0282-06	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0283		East Cheatham Street	East Gibbs Street	Y	Y	Sidewalk starts at E Cheatham to E Gibbs	SW0283-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0283		East Cheatham Street	East Gibbs Street	Y	Y	Sidewalk starts at E Cheatham to E Gibbs	SW0283-04	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0284		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0284-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0284		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0284-03	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0285	East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts E Mercer to E Gibbs	SW0285-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0285	East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts E Mercer to E Gibbs	SW0285-07	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0286	East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0286	East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-11	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0288	East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0288	East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-08	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0290	East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0290-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0290	East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0290-03	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0291	East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0291-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0291	East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0291-04	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0292	Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0292-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0292	Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0292-04	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0293	East Leah Street	East Main Street	Y	Y	Sidewalk starts at E Leah E Vine Street	SW0293-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0293	East Leah Street	East Main Street	Y	Y	Sidewalk starts at E Leah E Vine Street	SW0293-07	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0296	East Vine Street	East Main Street	Y	Y	Sidewalk starts E Vine Street to E Main	SW0296-01	Curb ramp	Newly Constructed Compliant Ramp	\$0	
SW0296	East Vine Street	East Main Street	Y	Y	Sidewalk starts E Vine Street to E Main	SW0296-03	Curb ramp	Newly Constructed Compliant Ramp	\$0	

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0279	North Division Street	East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-05	Drive Ramp	Construct Sidewalk in drive continuation area	\$1,200
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-07	Drive Ramp	Construct Sidewalk in drive continuation area	\$1,200
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-04	Drive Ramp	Replace Sidewalk in drive continuation area	\$1,500
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-06	Drive Ramp	Construct Sidewalk in drive continuation area	\$3,600
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-11	Grass	Edge and trim grass; clean expansion joints	\$200
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-13	Grass	Edge and trim grass; clean expansion joints	\$200
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-03	Grass	Edge and trim grass; clean expansion joints	\$0
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-02	Grass	Edge and trim grass; clean expansion joints	\$0
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0282		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0282-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0282		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0282-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0286		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0286-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-02	Missing sidewalk	Add sidewalk where missing	\$3,000
SW0280		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0280-02	Missing sidewalk	Replace missing sidewalk	\$600
SW0291		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0291-03	Missing sidewalk	Replace sidewalk where missing	\$9,600
SW0296		East Vine Street	East Main Street	Y	Y	Sidewalk starts E Vine Street to E Main	SW0296-02	Missing sidewalk	Construct sidewalk and compliant drive ramp	\$4,800
SW0292		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0292-03	Missing sidewalk	Across E Leah, construct sidewalk continuation area	\$1,200
SW0287		East Gibbs Street	East Palmer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0289		East Palmer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0294		Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0295		East Vine Street	East Main Street	Y	Y	PART OF SW0293	NA	NA	NA	\$0
SW0293		East Leah Street	East Main Street	Y	Y	Sidewalk starts at E Leah E Vine Street	SW0293-02	Scrubs	Trim scrubs	\$1,000
SW0293		East Leah Street	East Main Street	Y	Y	Sidewalk starts at E Leah E Vine Street	SW0293-04	Scrubs	Trim scrubs	\$1,000
SW0279		East Tate Street	East Todd Street	Y	Y	Sidewalk starts at E Tate to E Todd	SW0279-10	Settling	Replace sidewalk where settled	\$1,200
SW0281		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0281-03	Settling	Replace sidewalk where settled	\$0
SW0296		East Vine Street	East Main Street	Y	Y	Sidewalk starts E Vine Street to E Main	SW0296-04	Sign	Raise sign to 80 inch minimum	\$100
SW0288		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-06	Stump	Remove stump	\$500
SW0292		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0292-02	Trees	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$500
SW0288		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Gibbs E Palmer	SW0289-04	Vegetation	Trim vegetation	\$200
North Division Street Remediation Estimated Costs:										\$135,880
SW0300	South Division Street	Exchange Street	East Church Street	Y	Y	Sidewalk starts Exchange to E Church	SW0300-04	Broken surface material	Replace broken surface material and poor quality material	\$750
SW0300		Exchange Street	East Church Street	Y	Y	Sidewalk starts Exchange to E Church	SW0300-03	Cross slope exceeds 2% or ramp side slopes exceed 8.33%	Construct compliant side slopes with less than 8.33 % slopes	\$2,700
SW0298		East Main Street	Exchange Street	Y	Y	Sidewalk starts E Main to Exchange	SW0298-04	Curb ramp	Construct one way directional ramp with yellow truncated domes	\$2,500
SW0300		Exchange Street	East Church Street	Y	Y	Sidewalk starts Exchange to E Church	SW0300-01	Curb ramp	Construct one way directional ramp with yellow truncated domes	\$2,500
SW0300		Exchange Street	East Church Street	Y	Y	Sidewalk starts Exchange to E Church	SW0300-06	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0300		Exchange Street	East Church Street	Y	Y	Sidewalk starts Exchange to E Church	SW0300-02	Debris	Clean debris off of sidewalk	\$200
SW0298		East Main Street	Exchange Street	Y	Y	Sidewalk starts E Main to Exchange	SW0298-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0298		East Main Street	Exchange Street	Y	Y	Sidewalk starts E Main to Exchange	SW0298-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0300		Exchange Street	East Church Street	Y	Y	Sidewalk starts Exchange to E Church	SW0300-05	Fire hydrant	Construct street bubble to allow construction of street bubble for a 4 ft clear pathway	\$1,500
SW0297		East Main Street	Exchange Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0299		Exchange Street	East Church Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0301		Waddell Street	Harrison Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0302		Waddell Street	Harrison Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0298		East Main Street	Exchange Street	Y	Y	Sidewalk starts E Main to Exchange	SW0298-01	Sign	Raise sign to 80 inch minimum	\$250
South Division Street Remediation Estimated Costs:										\$20,100
SW0303	South Rose Street	Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-06	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-05	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-01	Curb ramp	Construct diagonal ramp with yellow truncated domes	\$3,400

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		Prowag PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	Prowag Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0303	South Rose Street	Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-12	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-01	Curb ramp	Construct diagonal ramp with yellow truncated domes with landing in ramp	\$2,950
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-08	Curb ramp	Construct one way directional ramp with yellow truncated domes	\$1,550
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-04	Drive Ramp	Replace broken surface material and poor quality material	\$7,800
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-08	Drive Ramp	Replace sidewalk to provide an 8.33% slope maximum	\$1,200
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-11	Drive Ramp	Replace sidewalk to provide an 8.33% slope maximum	\$1,200
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0305		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW0305-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0304		Harrison Street	East Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0306		East Florida Avenue	East Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-05	Pipe	Bury pipe under sidewalk	\$1,250
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-10	Pipe	Bury pipe under sidewalk	\$2,000
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-07	Wall AC Unit	Add cane protection beside door	\$200
SW0303		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0303-09	Wall AC Unit	Add cane protection beside door	\$200
South Rose Street Remediation Estimated Costs:										\$31,950
SW0309	North Ury Street	East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0309-02	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0309		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0309-04	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0309		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0309-05	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0310		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0310-03	Broken surface material	Replace broken surface material and poor quality material	\$7,800
SW0311		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0311-02	Broken surface material	Replace broken surface material and poor quality material	\$5,400
SW0311		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0311-03	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0311		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0311-04	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0312		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0312-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0312		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0312-03	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0312		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0312-04	Broken surface material	Replace broken surface material and poor quality material	\$4,500
SW0312		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0312-05	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0313		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0313-02	Broken surface material	Replace broken surface material and poor quality material	\$6,600
SW0313		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0313-03	Broken surface material	Replace broken surface material and poor quality material	\$3,900
SW0313		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0313-04	Broken surface material	Replace broken surface material and poor quality material	\$6,600
SW0314		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0314-02	Broken surface material	Replace broken surface material and poor quality material entire street segment	\$18,000
SW0315		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Palmer to E College	SW0315-02	Broken surface material	Replace broken surface material and poor quality material entire street segment	\$13,800
SW0316		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Palmer to E College	SW0316-02	Broken surface material	Replace broken surface material and poor quality material entire street segment	\$14,400
SW0317		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts E College to MLK	SW0317-02	Broken surface material	Replace broken surface material and poor quality material	\$375
SW0317		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts E College to MLK	SW0317-03	Broken surface material	Replace broken surface material and poor quality material	\$4,125
SW0317		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts E College to MLK	SW0317-04	Broken surface material	Replace broken surface material and poor quality material	\$1,125
SW0317		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts E College to MLK	SW0317-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-04	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-06	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-07	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-08	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-09	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0320		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0320-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0320		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0320-03	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0320		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0320-04	Broken surface material	Replace broken surface material and poor quality material	\$5,100

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0321	North Ury Street	East Leah Street	East Vine Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0321-02	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0322		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0322-04	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0309		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0309-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0309		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0309-06	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0310		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0310-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0310		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0310-04	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0311		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0311-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0311		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0311-06	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0312		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0312-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0312		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0312-06	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0313		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0313-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0313		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0313-05	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0314		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0314-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0314		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at Gibbs to E Palmer	SW0314-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0315		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Palmer to E College	SW0315-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0315		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Palmer to E College	SW0315-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0316		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Palmer to E College	SW0316-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0316		East Palmer Street	East College Street	Y	Y	Sidewalk starts at E Palmer to E College	SW0316-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0317		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts E College to MLK	SW0317-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0317		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts E College to MLK	SW0317-06	Curb ramp	Construct diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-01	Curb ramp	Construct diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-11	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$900
SW0320		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0320-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0320		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0320-05	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0321		East Leah Street	East Vine Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0321-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0321		East Leah Street	East Vine Street	Y	Y	Sidewalk starts at E Leah to E Vine	SW0321-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0322		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0322-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0323		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0323-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-03	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$2,700
SW0322		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0322-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,150
SW0322		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0322-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,159
SW0322		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0322-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$4,500
SW0323		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0323-05	Drive Ramp	Replace broken surface material and poor quality material	\$3,150
SW0323		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0323-07	Drive Ramp	Construct compliant side slopes with less than 8.33 % slopes	\$3,150
SW0309		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0309-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0311		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0311-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0319		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0319-10	Grass	Edge and trim grass; clean expansion joints	\$200
SW0323		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0323-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0323		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0323-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0323		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0323-02	Missing Sidewalk	Construct sidewalk where missing	\$3,000
SW0307		East Todd Street	East Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0308			East Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0318		East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0323		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0323-03	Settling	Replace sidewalk where settled	\$600
SW0310		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0310-02	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$500
North Ury Street Remediation Estimated Costs:										\$230,734
SW0324	South Ury Street	East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0324-01	Broken surface material	Replace broken surface material and poor quality material	\$750
SW0326		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0326-03	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0326		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0326-04	Broken surface material	Replace broken surface material and poor quality material	\$750
SW0327		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0327-04	Broken surface material	Replace broken surface material and poor quality material	\$750
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-06	Broken surface material	Replace broken surface material and poor quality material	\$4,500
SW0329		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0329-02	Broken surface material	Replace broken surface material and poor quality material	\$2,400

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0329	South Ury Street	East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0329-03	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0329		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0329-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0329		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0329-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0330		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0330-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0330		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0330-03	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-03	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-05	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-06	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-05	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-08	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-11	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-12	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-06	Broken surface material	Replace broken surface material and poor quality material	\$2,235
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-07	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-02	Broken surface material	Replace broken surface material and poor quality material	\$1,035
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-06	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-07	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-08	Broken surface material	Replace broken surface material and poor quality material	\$4,500
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-02	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-05	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-06	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-08	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-10	Broken surface material	Replace broken surface material and poor quality material	\$9,000
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-02	Broken surface material	Replace broken surface material and poor quality material	\$8,400
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0338		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0338-02	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$8,700
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-06	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-07	Broken surface material	Replace broken surface material and poor quality material	\$3,600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0339	South Ury Street	East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-09	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0324		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0324-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0325		East Main Street	Exchange Street	N	Y	Sidewalk starts at E Main to Exchange	SW0325-01	Curb ramp	Add yellow truncated domes	\$350
SW0326		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0326-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0326		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0326-05	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0327		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0327-02	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0327		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0327-05	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,250
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-08	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0329		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0329-01	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0329		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0329-06	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$1,550
SW0330		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0330-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0330		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0330-05	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-08	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-15	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-08	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-09	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-11	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,200
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-09	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0338		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0338-03	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-11	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0340		East Bransford Street	East Jackson Street	Y	Y	Sidewalk E Bransford to E Jackson	SW0340-01	Curb ramp	No remediation recommended unless City wants a street project	\$0
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-03	Debris	Clean up debris	\$100
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-08	Debris	Clean up debris	\$200
SW0327		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0327-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$5,250
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-09	Drive Ramp	Replace broken surface material and poor quality material	\$900
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-03	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0335		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Sumner e Florida	SW0335-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$4,950
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-04	Drive Ramp	Replace broken surface material and poor quality material	\$1,500
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-09	Drive Ramp	Replace broken surface material and poor quality material	\$1,500
SW0338		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0338-01	Drive Ramp	Replace street, drive type with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,400
SW0324		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0324-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-10	Grass	Edge and trim grass; clean expansion joints	\$200
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-13	Grass	Edge and trim grass; clean expansion joints	\$200
SW0334		Harrison Street	Summer Street	Y	Y	Sidewalk starts at Harrison to Sumner	SW0334-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0336		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0336-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0328		East Church Street	Waddell Street	Y	Y	Sidewalk starts at E Church to Waddell	SW0328-07	Missing sidewalk	Replace sidewalk where missing	\$4,200
SW0330		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0330-04	Missing sidewalk	Construct and drive ramp where missing	\$4,800
SW0332		Waddell Street	Harrison Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0341		East Bransford Street	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0342		East Oak Street	East Jackson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0343		East Jackson Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0344		East Bishop Street	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0345		East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0339		East Flower Street	East Bransford Street	Y	Y	Sidewalk starts at E Flower to E Bransford	SW0339-10	Scrubs	Trim scrubs	\$100
SW0326		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0326-02	Settling	Replace sidewalk where settled	\$750
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-03	Settling	Replace sidewalk where settled	\$600
SW0333		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW0333-14	Settling	Replace sidewalk where settled	\$600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0327	South Ury Street	Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0327-01	Sign	Move sign into green space outside vertical and horizontal pathway	\$200
SW0331		Waddell Street	Harrison Street	Y	Y	Sidewalk starts at Waddell to Harrison	SW0331-07	Tree	Trim Trees to allow for 80 inch vertical and 48 inch horizontal pathway	\$300
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-03	Trees	Trim tress	\$500
SW0337		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida to E Flower	SW0337-06	Trees	Trim tress	\$300
South Ury Street Remediation Estimated Costs: \$181,970										
SW0348	North Morgan Street	East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0348		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0348		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-09	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-06	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-08	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0352		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0352-02	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW0352		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0352-04	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW0353		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0353-02	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$17,400
SW0356		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0356-02	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$16,800
SW0357		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0357-02	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0358		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0358-02	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$14,400
SW0359		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0359-02	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0359		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0359-04	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0359		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0359-06	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0361		East Leah Street	East Vine Street	Y	Y	Sidewalk from E Leah to E Vine	SW0361-02	Broken surface material	Replace broken surface material and poor quality material	\$4,500
SW0361		East Leah Street	East Vine Street	Y	Y	Sidewalk from E Leah to E Vine	SW0361-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0363		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0363-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0363		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0363-04	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0348		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0348		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-10	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-10	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0352		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0352-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0352		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0352-06	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0353		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0353-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0353		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0353-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,750
SW0356		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0356-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,750
SW0357		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0357-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0357		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0357-07	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0358		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0358-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0358		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0358-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,750
SW0359		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0359-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,150
SW0359		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0359-07	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; extend sidewalk	\$3,100
SW0360		East Leah Street	East Vine Street	Y	Y	Sidewalk limited to one property at E Leah	SW0360-01	Curb ramp	No remediation recommended	\$0
SW0361		East Leah Street	East Vine Street	Y	Y	Sidewalk from E Leah to E Vine	SW0361-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0361		East Leah Street	East Vine Street	Y	Y	Sidewalk from E Leah to E Vine	SW0361-05	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; extend sidewalk	\$3,100
SW0363		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0363-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0348		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0356		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0356-01	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$4,300
SW0357		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0357-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0357	North Morgan Street	East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0357-05	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0348		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0350		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0350-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0352		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0352-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0352		East Gibbs Street	East Palmer Street	Y	Y	Sidewalk starts at E Gibbs to E Palmer	SW0352-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0357		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0357-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0359		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0359-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0359		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0359-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0361		East Leah Street	East Vine Street	Y	Y	Sidewalk from E Leah to E Vine	SW0361-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0363		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0363-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0346		East Todd Street	East Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0347				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0349		East Cheatham Street	East Mercer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0351		East Mercer Street	East Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0354		East Palmer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0355		East Palmer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0362		East Vine Street	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0348	East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-02	Scrubs	Trim scrubs	\$200	
SW0348	East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-03	Scrubs	Trim scrubs	\$200	
SW0357	East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0357-06	Scrubs	Trim scrubs	\$100	
SW0348	East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0348-08	Settling	Replace sidewalk where settled	\$600	
SW0363	East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0363-05	Vegetation	Trim vegetation	\$200	
SW0363	East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0363-06	Vegetation	Construct sidewalk by curb to allow for a 4 ft clear pathway	\$3,000	
North Morgan Street Remediation Estimated Costs:										\$150,150
SW0366	South Morgan Street	Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0366-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0366		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0366-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes;	\$3,100
SW0366		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0366-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$5,200
SW0364		East Main Street	Exchange Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0365		East Main Street	Exchange Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0367		Exchange Street	East Church Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0368		East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0369	East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
South Morgan Street Remediation Estimated Costs:										\$11,400
SW0370	North Home Street	East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0370		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-05	Broken surface material	Replace broken surface material and poor quality material	\$7,500
SW0370		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-06	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0370		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-07	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-06	Broken surface material	Replace broken surface material and poor quality material	\$750
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-09	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-10	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0373		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0373-02	Broken surface material	Replace broken surface material and poor quality material	\$8,400
SW0373		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0373-04	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0374		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0374-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0375		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0375-02	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0375		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0375-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0375		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0375-04	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0375		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0375-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0375		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0375-06	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-04	Broken surface material	Replace broken surface material and poor quality material	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0378	North Home Street	East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-06	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-12	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-13	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-14	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-16	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-17	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0379		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-02	Broken surface material	Replace broken surface material and poor quality material	\$10,200
SW0379		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0379		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0379		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0380		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0380-02	Broken surface material	Replace broken surface material and poor quality material of entire segment	\$18,000
SW0381		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0381-02	Broken surface material	Replace broken surface material and poor quality material of entire segment	\$15,000
SW0382		East Leah Street	East Vine Street	Y	Y	Sidewalk starts E Leah to E Vine	SW0382-03	Broken surface material	Replace broken surface material and poor quality material from 216 N Homes new sidewalk to E Vine	\$12,600
SW0383		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0383-02	Broken surface material	Replace broken surface material and poor quality material of entire segment	\$30,000
SW0384		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0384-02	Broken surface material	Replace broken surface material and poor quality material of entire segment	\$600
SW0384		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0384-03	Broken surface material	Replace broken surface material and poor quality material of entire segment	\$3,600
SW0384		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0384-05	Broken surface material	Replace broken surface material and poor quality material of entire segment	\$300
SW0385		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0385-02	Broken surface material	Replace broken surface material and poor quality material from E Vine to 704 new sidewalk	\$11,400
SW0370		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0370		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-08	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-01	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-12	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,400
SW0373		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0373-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,850
SW0373		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0373-05	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0374		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0374-01	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0374		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0374-04	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0375		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0375-01	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0375		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0375-07	Curb ramp	Construct a diagonal ramp with yellow truncated domes with landing in ramp	\$2,600
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-18	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0379		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0379		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-08	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0380		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0380-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0380		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0380-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0381		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0381-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0381		Dr Martin Luther King Jr Drive	East Leah Street	Y	Y	Sidewalk starts at MLK to E Leah	SW0381-03	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,200
SW0382		East Leah Street	East Vine Street	Y	Y	Sidewalk starts E Leah to E Vine	SW0382-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0382		East Leah Street	East Vine Street	Y	Y	Sidewalk starts E Leah to E Vine	SW0382-04	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0383		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0383-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0383		Dr Martin Luther King Jr Drive	East Vine Street	Y	Y	Sidewalk starts at MLK to E Vine	SW0383-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0384		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0384-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0384		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0384-06	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0385		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0385-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-05	Drive Ramp	Replace broken surface material and poor quality material	\$900
SW0373		East Cheatham Street	East Mercer Street	Y	Y	Sidewalk starts at E Cheatham to E Mercer	SW0373-03	Drive Ramp	Replace broken surface material	\$1,200
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-10	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700
SW0385		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0385-04	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,700

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0371	North Home Street	East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0371		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0371-11	Grass	Edge and trim grass; clean expansion joints	\$200
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-15	Grass	Edge and trim grass; clean expansion joints	\$200
SW0382		East Leah Street	East Vine Street	Y	Y	Sidewalk starts E Leah to E Vine	SW0382-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0384		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0384-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0385		East Vine Street	East Main Street	Y	Y	Sidewalk starts at E Vine to E Main	SW0385-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0374		East Mercer Street	East Gibbs Street	Y	Y	Sidewalk starts at E Mercer to E Gibbs	SW0374-03	Missing sidewalk	Replace sidewalk and ramp where missing	\$5,400
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-09	Missing sidewalk	Replace sidewalk where missing	\$600
SW0378		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW0378-11	Missing sidewalk	Replace sidewalk where missing	\$600
SW0379		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-03	Missing sidewalk	Replace sidewalk where missing	\$900
SW0372		East Cheatham Street	East Mercer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0376		East Gibbs Street	East Palmer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0377	East Palmer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0370	East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-02	Settling	Replace sidewalk where settled	\$600	
SW0370	East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts to E Todd to E Cheatham	SW0370-03	Settling	Replace sidewalk where settled	\$600	
SW0379	East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW0379-05	Vegetation	Trim vegetation	\$200	
North Home Street Remediation Estimated Costs:										\$235,650
SW0387	South Home Street	East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0387-01	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0388		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0388-02	Broken surface material	Replace broken surface material and poor quality material	\$5,700
SW0391		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0391-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0392		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0392-03	Broken surface material	Replace broken surface material and poor quality material	\$12,600
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-04	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-05	Broken surface material	Replace broken surface material and poor quality material from 629 to Church drive	\$12,600
SW0399		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Summer to E Florida	SW0399-02	Broken surface material	Replace broken surface material and poor quality material from Summer to 612	\$14,400
SW0400		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida but limited to 2 properties	SW0399-05	Broken surface material	No remediation unless City wants a street project	\$0
SW0387		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0387-05	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0388		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0388-01	Curb ramp	Construct a diagonal ramp with yellow truncated domes	\$2,600
SW0388		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0388-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0389		Exchange Street	Alley	Y	Y	Sidewalk starts at Exchange to Alley	SW0389-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0389		Exchange Street	Alley	Y	Y	Sidewalk starts at Exchange to Alley	SW0389-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0391		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0391-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0391		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0391-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0392		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0392-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0392		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0392-04	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-08	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0399		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Summer to E Florida	SW0399-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,100
SW0399		Summer Street	East Florida Avenue	Y	Y	Sidewalk starts at Summer to E Florida	SW0399-03	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes; Extend sidewalk	\$4,300
SW0400		East Florida Avenue	East Flower Street	Y	Y	Sidewalk starts at E Florida but limited to 2 properties	SW0400-01	Curb ramp	No remediation unless City wants a street project	\$0
SW0386		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0386-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,100
SW0387		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0387-02	Drive Ramp	Replace broken surface material and poor quality material	\$3,150
SW0389		Exchange Street	Alley	Y	Y	Sidewalk starts at Exchange to Alley	SW0389-02	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$3,600
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-06	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes; Add yellow truncated domes	\$4,500
SW0386		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0386-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0387		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0387-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0392		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0392-02	Missing sidewalk	Construct sidewalk where missing	\$2,100
SW0393		High Street	Waddell Street	Y	Y	Sidewalk starts at High to Waddell	SW0393-07	Missing sidewalk	Construct sidewalk where missing	\$3,000
SW0390		Alley	East Church Street	Y	Y	Evaluated under SW0389	NA	NA	NA	\$0
SW0394		High Street	Howard Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0395		Howard Street	Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0397		Waddell Street	Summer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0398		Summer Street	East Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0401		East Flower Street	East Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0402		East Florida Avenue	East Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0403		East Bransford Street	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		Prowag PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	Prowag Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0404	South Home Street	East Bransford Street	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0405		East Oak Street	East Jackson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0406		East Oak Street	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0407		East Jackson Street	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0408		East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0409		East Bishop Street	East Reelfoot Avenue	Y	Y	Sidewalk limited to commercial properties	NA	NA	No Barriers	\$0
SW0410		East Reelfoot Avenue	Nelson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0411		East Reelfoot Avenue	Sherrill Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0387		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0387-03	Vegetation	Trim vegetation	\$200
South Home Street Remediation Estimated Costs:										\$110,100
SW0412	Nelson Street	Sherrill Street	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0413				Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0418		Rutherford Street	Williamsburg Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0419		Williamsburg Drive	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0420		Rutherford Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Nelson Street Remediation Estimated Costs:										\$0
SW0414	Sherrill Street	South Home Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0415		Nelson Street	Rutherford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0416		Rutherford Street	Williamsburg Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0417		Williamsburg Drive	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Sherrill Street Remediation Estimated Costs:										\$0
SW0421	Rutherford Street	Sherrill Street	Nelson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0422				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0423		Nelson Street	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0424				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Rutherford Street Remediation Estimated Costs:										\$0
SW0425	Williamsburg Drive	Sherrill Street	Nelson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0426				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Williamsburg Drive Remediation Estimated Costs:										\$0
SW0427	North Glendale Street	East Todd Street	East Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0428				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North Glendale Street Remediation Estimated Costs:										\$0
SW0429	Greenwood Street	East Cheatham Street	East Mercer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0430				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0431		East Mercer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0432				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0433		East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0434				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0435		Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0436				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0437		East Vine Street	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0438				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Greenwood Street Remediation Estimated Costs:										\$0
SW0442	Melrose Street	East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0442		East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0442		East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-08	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,700
SW0442		East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-03	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes from sidewalk to sidewalk across parking to provide a sidewalk continuation area	\$7,200
SW0442		East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-04	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes from sidewalk to sidewalk across parking to provide a sidewalk continuation area	\$7,200
SW0442		East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0442		East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0442		East Mercer Street	East College Street	Y	Y	Sidewalk starts to E Mercer to E College	SW0442-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0439		East Cheatham Street	East Mercer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0440		East Cheatham Street	East Mercer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0441		East Mercer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0443		East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0444		East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Melrose Street Remediation Estimated Costs:										\$21,700
SW0445	North Street	East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-07	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-01	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-03	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-09	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-11	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-12	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-16	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-17	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-19	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-21	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-25	Broken surface material	Replace broken surface material and poor quality material	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0446	North Street	East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-26	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-05	Curb ramp	Add yellow truncated domes	\$350
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-06	Curb ramp	Add yellow truncated domes	\$350
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-13	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$3,400
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-06	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-08	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-22	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-23	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-29	Curb ramp	Construct a diagonal ramp with yellow truncated domes	\$3,400
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-10	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes from sidewalk to sidewalk across parking to provide a sidewalk continuation area	\$6,000
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-13	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$3,600
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-14	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$2,250
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-15	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$3,150
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-18	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$3,150
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-24	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$2,250
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-27	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$2,250
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-28	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$3,600
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-11	Grass	Edge and trim grass; clean expansion joints	\$200
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-12	Grass	Edge and trim grass; clean expansion joints	\$200
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-10	Grass	Edge and trim grass; clean expansion joints	\$200
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-20	Grass	Edge and trim grass; clean expansion joints	\$200
SW0445		East Mercer Street	East College Street	Y	Y	Sidewalk starts at E Mercer to E College	SW0445-08	Sidewalk run slope	Replace sidewalk with compliant run slope	\$1,800
SW0446		East Mercer Street	Nash Street	Y	Y	Sidewalk starts at Eastgate Apts to Nailling Drive	SW0446-07	Sidewalk run slope	Replace sidewalk with compliant run slope	\$1,200
North Street Remediation Estimated Costs:										\$62,350
SW0447	Nash Street	East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0448		Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0449		East Vine Street	Nailling Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0450		Beginning of Street	Nailling Drive	Y	Y	Part of SW0446	NA	NA	NA	\$0
Nash Street Remediation Estimated Costs:										\$0
SW0451	North Miles Street	East Cheatham Street	Nailling Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0452		East Cheatham Street	Nailling Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0453		Nailling Drive	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0454		Nailling Drive	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North Miles Street Remediation Estimated Costs:										\$0
SW0455	South Miles Street	East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0455-01	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0455		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0455-02	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0455		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0455-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0455		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0455-04	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0455		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0455-05	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0457		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0457-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0457		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0457-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-04	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-05	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-07	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-08	Broken surface material	Replace broken surface material and poor quality material	\$4,500

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0458	South Miles Street	High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-10	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0455		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0455-06	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0456		East Main Street	East Church Street	Y	Y	Sidewalk starts at E Main to E Church	SW0456-01	Curb ramp	Add yellow truncated domes	\$700
SW0457		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0457-01	Curb ramp	Add yellow truncated domes	\$350
SW0457		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0457-06	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,200
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-11	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0460		East High School Drive	East Oak Street	Y	Y	Sidewalk starts at E High Drive to E Oak	SW0460-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0460		East High School Drive	East Oak Street	Y	Y	Sidewalk starts at E High Drive to E Oak	SW0460-02	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-09	Drive Ramp	Construct a compliant drive ramp with 8.33% side slopes and 2 % cross slopes	\$4,800
SW0457		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0457-03	Missing sidewalk	Construct sidewalk where missing	\$1,200
SW0457		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0457-04	Missing sidewalk	Construct sidewalk where missing	\$1,200
SW0458		High Street	East High School Drive	Y	Y	Sidewalk starts at High to E High Drive	SW0458-02	Missing sidewalk	Construct sidewalk where missing	\$1,200
SW0459		East Church Street	East Matthews Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0461		East High School Drive	Union City Elementary Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0462		East Oak Street	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0463		Union City Elementary Entrance	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0464		East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0465		East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0466		East Reelfoot Avenue	Honeysuckle Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0467		East Reelfoot Avenue	Holiday Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0468		Holiday Drive	Starlight Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0469		Starlight Drive	Honeysuckle Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1492		East Matthews Street	East High School Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
South Miles Street Remediation Estimated Costs:										\$45,550
SW0470	North Ford Street	Nailling Drive	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0471				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North Ford Street Remediation Estimated Costs:										\$0
SW0472	Jernigan Drive	E - W Jernigan Drive	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0473				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0474		N - S Jernigan Drive	Rear Alley Access (North Sunswep Drive)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0475				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0476		Rear Alley Access (Jernigan Drive)	North Sunswep Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0477		North Sunswep Drive	Rear Alley Access (North Sunswep Drive)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Jernigan Drive Remediation Estimated Costs:										\$0
SW0478	Rear Alley Access (Jernigan Drive)	E - W Jernigan Drive	North Sunswep Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0479				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Rear Alley Access (Jernigan Drive) Remediation Estimated Costs:										\$0
SW0480	North Sunswep Drive	E - W Jernigan Drive	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0481				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North Sunswep Drive Remediation Estimated Costs:										\$0
SW0482	Rear Alley Access (North Sunswep Drive)	E - W Jernigan Drive	Sunswep Baptist Church	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0483				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Rear Alley Access (North Sunswep Drive) Remediation Estimated Costs:										\$0
SW0484	Sunswep Drive	East Main Street	East Church Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0485				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0486		East Church Street	South Sunswep Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1491		South Sunswep Street	East High School Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0487		East Church Street	East High School Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0488		East High School Drive	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0489				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Sunswep Drive Remediation Estimated Costs:										\$0
SW0493	East Cheatham Street	Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-11	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-12	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-13	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-14	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-15	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-16	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-17	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-03	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-07	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-08	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-09	Broken surface material	Replace broken surface material and poor quality material	\$4,800

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0495	East Cheatham Street	North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-10	Broken surface material	Replace broken surface material and poor quality material 806 drive to 700 drive	\$25,200
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-06	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-10	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-12	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-01	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-05	Broken surface material	Replace broken surface material and poor quality material	\$7,200
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-06	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-07	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0498		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0498-02	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0498		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0498-03	Broken surface material	Replace broken surface material and poor quality material	\$6,600
SW0499		North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0499-01	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0499		North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0499-02	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0499		North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0499-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0499		North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0499-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0499		North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0499-05	Broken surface material	Replace broken surface material and poor quality material	\$5,400
SW0500		North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0500-01	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0500		North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0500-03	Broken surface material	Replace broken surface material and poor quality material	\$5,100
SW0501		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0501-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0501		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0501-04	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0502		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0502-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0502		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0502-04	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-01	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-03	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-05	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-06	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-07	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,900
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-19	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,550
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-11	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-13	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-10	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,250
SW0502		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0502-01	Debris	Remove debris from pathway	\$200
SW0502		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0502-03	Debris	Remove debris from pathway	\$200
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-08	Drive Ramp	Replace with concrete surface	\$1,200
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-09	Drive Ramp	Replace with compliant slopes	\$1,200
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-11	Drive Ramp	Replace with compliant slopes	\$1,200
SW0497		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0497-08	Drive Ramp	Replace with concrete surface	\$1,200
SW0498		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0498-01	Drive Ramp	Replace with concrete surface	\$9,600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0500	East Cheatham Street	North Morgan Street	North Ury Street	Y	Y	Sidewalk N Morgan to N Ury	SW0500-02	Drive Ramp	Replace broken surface material and poor quality material	\$1,500
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-18	Grass	Edge and trim grass; clean expansion joints	\$200
SW0501		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0501-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0501		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0501-01	Heaved sidewalk	Replace sidewalk where heaved	\$900
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-02	Missing sidewalk	Construct sidewalk where missing	\$5,400
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-09	Missing sidewalk	Replace sidewalk where settled	\$8,400
SW0490		North Miles Street	North Glendale Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0491		North Miles Street	Melrose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0492		Melrose Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0494		Greenwood Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0504		North Division Street	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0505		North Baker Street	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0503		North Division Street	North Baker Street	Y	Y	Sidewalk starts at N Division to N Baker	SW0503-08	Scrubs	Trim scrubs	\$299
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-07	Settling	Replace sidewalk where settled	\$900
SW0495		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0495-06	Settling	Replace broken surface material and poor quality material	\$600
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-02	Settling	Replace sidewalk where settled	\$900
SW0496		North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-04	Settling	Replace sidewalk where settled	\$600
SW0501		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0501-05	Settling	Replace sidewalk where settled	\$1,200
SW0493	Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-08	Sidewalk run slope	Replace sidewalk and ramp sidewalk continuation with compliant run slope	\$3,000	
SW0493		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-09	Sidewalk run slope	Replace sidewalk and ramp sidewalk continuation with compliant run slope	\$1,800
SW0493	Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at 1009 to N Clover	SW0493-10	Sidewalk run slope	Replace sidewalk and ramp sidewalk continuation with compliant run slope	\$2,400	
SW0496	North Clover Street	North Home Street	Y	Y	Sidewalk starts at N Clover to N Home	SW0496-03	Sidewalk run slope	Replace with compliant slopes	\$1,200	
East Cheatham Street Remediation Estimated Costs:										\$185,099
SW0506	West Cheatham Street	North 1st Street	North 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0507		North 2nd Street	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0508			North 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0509			North 4th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0510			North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0511		North 5th Street	Mount Zion Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0512			North 6th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0513			North 6th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0514		North 6th Street	Mount Zion Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Cheatham Street Remediation Estimated Costs:										\$0
SW0529	East Mercer Street	North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0529-01	Broken surface material	Replace broken surface material and poor quality material entire street segment	\$21,600
SW0516		North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0516-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0516		North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0516-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0516		North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0516-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0515		North Street	Melrose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0517		Melrose Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0518		Melrose Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0519		Greenwood Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0520		Greenwood Street	North Glendale Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0521		North Glendale Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0522		North Clover Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0523		North Clover Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0524		North Home Street	North Morgan Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0525		North Home Street	North Morgan Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0526		North Morgan Street	North Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0527		North Morgan Street	North Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0528		North Ury Street	North Division Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Mercer Street Remediation Estimated Costs:										\$22,200
SW0533	East Gibbs Street	North Home Street	North Morgan Street	Y	Y	Sidewalk starts at 622 to N Morgan	SW0533-02	Broken surface material	Replace broken surface material and poor quality material to 614	\$6,000
SW0535		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0535-03	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0536		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0536-01	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW0536		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0536-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0536		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0536-03	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0536		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0536-05	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0536		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0536-06	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0537		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0537-02	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0537		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0537-03	Broken surface material	Replace broken surface material and poor quality material from 418 to N Division	\$12,300
SW0538		North Ury Street	North Division Street	N	N	Sidewalk starts at N Ury to N Division	SW0538-02	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0538		North Ury Street	North Division Street	N	N	Sidewalk starts at N Ury to N Division	SW0538-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0538		North Ury Street	North Division Street	N	N	Sidewalk starts at N Ury to N Division	SW0538-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0538		North Ury Street	North Division Street	N	N	Sidewalk starts at N Ury to N Division	SW0538-06	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-01	Broken surface material	Replace broken surface material and poor quality material	\$3,000

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est. (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0539	East Gibbs Street	North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-06	Broken surface material	Replace broken surface material and poor quality material	\$5,100
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-07	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-10	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-12	Broken surface material	Replace broken surface material and poor quality material	\$1,875
SW0540		North Division Street	North Bank Street	Y	Y	Sidewalk starts N Division to N Bank	SW0540-01	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0540		North Division Street	North Bank Street	Y	Y	Sidewalk starts N Division to N Bank	SW0540-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0541		North Bank Street	North 1st Street	Y	Y	Sidewalk starts N Bank to train rail; Missing from rail to N 1st	SW0541-02	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0535		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0535-01	Drive Ramp	Replace broken surface material and poor quality material in sidewalk continuation area	\$3,000
SW0537		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0537-01	Drive Ramp	Replace sidewalk and ramp to provide compliant maximum 8.33% run slope and 2% maximum cross slope	\$2,700
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-11	Drive Ramp	Replace with a compliant driveway ramp with 2% slopes in the sidewalk continuation area and 8.33% side slopes	\$2,250
SW0540		North Division Street	North Bank Street	Y	Y	Sidewalk starts N Division to N Bank	SW0540-05	Drive Ramp	Replace sidewalk and ramp to provide compliant maximum 8.33% run slope and 2% maximum cross slope	\$1,800
SW0536		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0536-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0536		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0536-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0538		North Ury Street	North Division Street	N	N	Sidewalk starts at N Ury to N Division	SW0538-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0538		North Ury Street	North Division Street	N	N	Sidewalk starts at N Ury to N Division	SW0538-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0540		North Division Street	North Bank Street	Y	Y	Sidewalk starts N Division to N Bank	SW0540-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0540		North Division Street	North Bank Street	Y	Y	Sidewalk starts N Division to N Bank	SW0540-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0541		North Bank Street	North 1st Street	Y	Y	Sidewalk starts N Bank to train rail; Missing from rail to N 1st	SW0541-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0535		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0535-02	Heaved sidewalk	Replace sidewalk where heaved	\$1,200
SW0533		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at 622 to N Morgan	SW0533-01	Missing sidewalk	Replace sidewalk where missing	\$8,400
SW0530		North Clover Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0531		North Clover Street	North Dobbin Street	Y	Y	Sidewalk limited to the Church	SW0531-01	NA	No remediation recommended unless City wants a street project	\$0
SW0532		North Dobbin Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0534		North Home Street	North Morgan Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0539		North Division Street	North 1st Street	Y	Y	Sidewalk starts N Division to N 1st	SW0539-08	Settling	Replace sidewalk where settled	\$2,250
East Gibbs Street Remediation Estimated Costs:										\$87,375
SW0542	West Gibbs Street	North 1st Street	North 2nd Street	Y	Y	Sidewalk starts at N 1st to first 2 properties	SW0542-01	Grass	No remediation unless City wants a street project	\$0
SW0543		North 2nd Street	North 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0544				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0545		North 3rd Street	North 4th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0546				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0547		North 4th Street	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0548				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0549		North 5th Street	North 6th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0550				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0551		West Gibbs Street Remediation Estimated Costs:								
SW0555	East Palmer Street	North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0555-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$19,800
SW0556		North Ury Street	North Division Street	N	N	Sidewalk starts at N Morgan to N Ury	SW0556-01	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0556		North Ury Street	North Division Street	N	N	Sidewalk starts at N Morgan to N Ury	SW0556-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0556		North Ury Street	North Division Street	N	N	Sidewalk starts at N Morgan to N Ury	SW0556-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0556		North Ury Street	North Division Street	N	N	Sidewalk starts at N Morgan to N Ury	SW0556-05	Broken surface material	Replace broken surface material and poor quality material from 412 to N Ury	\$7,200
SW0558		North Division Street	North Bank Street	Y	Y	Sidewalk starts at N Division to N Bank	SW0558-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$11,400
SW0559		North Division Street	North Bank Street	Y	Y	Sidewalk starts at N Division to N Bank	SW0559-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$11,400
SW0560		North Bank Street	North 1st Street	Y	Y	Sidewalk starts at N Bank to 1st	SW0560-02	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0560		North Bank Street	North 1st Street	Y	Y	Sidewalk starts at N Bank to 1st	SW0560-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0560		North Bank Street	North 1st Street	Y	Y	Sidewalk starts at N Bank to 1st	SW0560-04	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0560		North Bank Street	North 1st Street	Y	Y	Sidewalk starts at N Bank to 1st	SW0560-05	Broken surface material	Replace broken surface material and poor quality material	\$4,800

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0560	East Palmer Street	North Bank Street	North 1st Street	Y	Y	Sidewalk starts at N Bank to 1st	SW0560-06	Broken surface material	Replace broken surface material and poor quality material from rail to 1st	\$19,950
SW0562		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-02	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0563		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0564		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0566		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-06	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0567		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-07	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW0568		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-08	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0558		North Division Street	North Bank Street	Y	Y	Sidewalk starts at N Division to N Bank	SW0558-02	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0559		North Division Street	North Bank Street	Y	Y	Sidewalk starts at N Division to N Bank	SW0559-02	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0560		North Bank Street	North 1st Street	Y	Y	Sidewalk starts at N Bank to 1st	SW0560-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0561		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-01	Curb ramp	Construct 2 perpendicular ramps with yellow truncated domes	\$2,800
SW0565		North Bank Street	Depot Road	Y	Y	Sidewalk starts at N Bank to Railroad	SW-561-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0556		North Ury Street	North Division Street	N	N	Sidewalk starts at N Morgan to N Ury	SW0556-03	Heaved sidewalk	Replace sidewalk where heaved	\$2,100
SW0552		North Home Street	North Morgan Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0553		North Home Street	North Morgan Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0554		North Morgan Street	North Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0557		North Ury Street	North Division Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0562	Depot Road	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
East Palmer Street Remediation Estimated Costs:										\$107,550
SW0564	West Palmer Street	North 1st Street	North 2nd Street	Y	Y	Sidewalk starts at N 1st to 1st property	SW-0565-01	Broken surface material	No remediation recommended	\$0
SW0565		North 2nd Street	North 3rd Street	Y	Y	Sidewalk starts at last property	SW-0566-01	Broken surface material	No remediation recommended	\$0
SW0563		North 1st Street	North 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0566		North 2nd Street	North 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0567		North 3rd Street	North 4th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0568		North 4th Street	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0569		North 3rd Street	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Palmer Street Remediation Estimated Costs:										\$0
SW0570	East College Street	North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0570-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0576		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood and ends at Boys and Girls Club	SW0576-02	Broken surface material	Replace broken surface material and poor quality material	\$750
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0578		North Home Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-05	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-06	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-08	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-04	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-06	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-07	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0580		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0580-01	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0580		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0580-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0580		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0580-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0580		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0580-05	Broken surface material	Replace broken surface material and poor quality material	\$10,800
SW0581		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0581-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0582		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0582-01	Broken surface material	Replace broken surface material and poor quality material	\$9,000
SW0582		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0582-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0582	East College Street	North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0582-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0582		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0582-06	Broken surface material	Replace broken surface material and poor quality material	\$4,200
SW0585		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0585-01	Broken surface material	Replace broken surface material and poor quality material from 404 to N Ury	\$15,600
SW0585		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0585-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0586		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0585-01	Broken surface material	Replace broken surface material and poor quality material	\$21,000
SW0591		Depot Road	North 1st Street	Y	Y	Sidewalk starts at Depot Road to N 1st	SW0591-01	Broken surface material	Replace broken surface material and poor quality material	\$10,800
SW0570		North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0570-05	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0576		Greenwood Street	North Clover Street	Y	Y	Sidewalk starts at Greenwood and ends at Boys and Girls Club	SW0576-01	Curb ramp	Add yellow truncated domes	\$350
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-08	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-09	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-01	Curb ramp	Newly Constructed Compliant Ramp	\$0
SW0591		Depot Road	North 1st Street	Y	Y	Sidewalk starts at Depot Road to N 1st	SW0591-02	Curb Ramp	Replace with one way directional ramp and yellow truncated domes	\$1,250
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-05	Drive Ramp	Replace sidewalk and ramp with compliant run slope	\$1,200
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-08	Drive Ramp	Replace sidewalk and ramp with compliant run slope	\$1,200
SW0581		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0581-02	Drive Ramp	Replace ramp with a compliant drive ramp	\$2,400
SW0582		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0582-04	Drive Ramp	Replace with compliant ramp with cross slope less than 2%	\$1,800
SW0570		North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0570-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0570		North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0570-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0578		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0578-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0579		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0579-09	Grass	Edge and trim grass; clean expansion joints	\$0
SW0580		North Dobbin Street	North Home Street	Y	Y	Sidewalk starts at N Dobbin to N Home	SW0580-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW0581		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0581-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0581		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0581-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0581		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0581-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0582		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0582-02	Heaved sidewalk	Replace sidewalk where heaved	\$600
SW0570		North Street	Melrose Street	Y	Y	Sidewalk starts at N Street to Melrose	SW0570-02	Missing Sidewalk	Construct sidewalk where missing	\$5,400
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-07	Missing Sidewalk	Construct sidewalk where missing	\$900
SW0571		North Street	Melrose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0572		Melrose Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0573		Melrose Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0574		Greenwood Street	North Glendale Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0575		North Glendale Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0583		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0583-01	None	New Sidewalk installation with compliant Curb Ramps	\$0
SW0584		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Morgan to N Ury	SW0584-01	None	New Sidewalk installation with compliant Curb Ramps	\$0
SW0587		North Division Street	North Bank Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0588		North Division Street	North Bank Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0589		North Bank Street	Depot Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0590		Depot Road	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1489		North Bank Street	Depot Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0577		North Clover Street	North Dobbin Street	Y	Y	Sidewalk starts at N Clover to N Dobbin	SW0577-03	Settling	Replace sidewalk where settled	\$900
East College Street Remediation Estimated Costs:										\$108,850
SW0592	West College Street	North 1st Street	Unnamed Alley	Y	Y	Sidewalk starts at N 1st to alley	SW0592-01	Broken surface material	Replace broken surface material and poor quality material to include alley	\$7,200
SW0593		North 1st Street	Unnamed Alley	Y	Y	Sidewalk starts at N 1st to alley	SW0593-01	Broken surface material	Replace broken surface material and poor quality material to include alley	\$1,800
SW0594		Unnamed Alley	North 2nd Street	Y	Y	Sidewalk starts at alley to N 2nd	SW0594-01	Broken surface material	Replace broken surface material and poor quality material to include alley	\$2,100
SW0598		Unnamed Alley	North 3rd Street	Y	Y	Sidewalk starts at alley to N 3rd	SW0598-01	Broken surface material	No remediation recommended at this time since incomplete block	\$0
SW0595		Unnamed Alley	North 2nd Street	Y	Y	Sidewalk starts at alley to N 2nd	SW0595-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0596		North 2nd Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0597		North 2nd Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0599		Unnamed Alley	North 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0600		North 3rd Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0601		North 3rd Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West College Street Remediation Estimated Costs:										\$11,300
SW0613	Dr Martin Luther King Jr Drive	North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0613-01	Broken surface material	Replace broken surface material and poor quality material to include entire street segment	\$23,400
SW0614		North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0614-01	Broken surface material	Replace broken surface material and poor quality material to include to 605	\$21,900
SW0615		North Morgan Street	North Ury Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0615-01	Broken surface material	Replace broken surface material and poor quality material to include to 606	\$19,200
SW0617		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to N Division	SW0617-01	Broken surface material	Replace broken surface material and poor quality material to include N Division to 414	\$12,600
SW0623		Depot Road	North 1st Street	Y	Y	Sidewalk starts at Depot to N 1st	SW0623-01	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0625		North 1st Street	Unnamed Alley	Y	Y	Sidewalk starts at N 1st to Alley	SW0625-01	Broken surface material	Replace broken surface material and poor quality material	\$4,500

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)	
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification			
SW0630	Dr Martin Luther King Jr Drive	North 2nd Street	North 3rd Street	Y	Y	Sidewalk starts at N 2nd to N 3rd	SW-0630-03	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW0627		Unnamed Alley	North 2nd Street	Y	Y	Sidewalk starts at Alley to N 2nd	SW-0627-01	Drive Ramp	Construct a compliant drive ramp	\$1,800	
SW0630		North 2nd Street	North 3rd Street	Y	Y	Sidewalk starts at N 2nd to N 3rd	SW-0630-02	Drive Ramp	Construct a compliant drive ramp	\$7,500	
SW0630		North 2nd Street	North 3rd Street	Y	Y	Sidewalk starts at N 2nd to N 3rd	SW-0630-01	Grass	Edge and trim grass; clean expansion joints	\$200	
SW0630		North 2nd Street	North 3rd Street	Y	Y	Sidewalk starts at N 2nd to N 3rd	SW-0630-04	Grass	Edge and trim grass; clean expansion joints	\$200	
SW0602		North Street	Melrose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0603		Nash Street	Royal Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0604		Royal Street	North Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0605		Melrose Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0606		North Taylor Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0607		Greenwood Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0608		Greenwood Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0609		North Clover Street	North Dobbin Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0610		North Clover Street	North Dobbin Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0611		North Dobbin Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0612		North Dobbin Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0616		North Morgan Street	North Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0618		North Ury Street	North Division Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0619		North Division Street	North Bank Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0620		North Bank Street	Depot Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0621		North Division Street	Depot Road	Y	Y	Sidewalk starts at N Division to 305	NA	NA	None required	\$0	
SW0622		Depot Road	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0624		North 1st Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0626		Unnamed Alley	North 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0628		North 2nd Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0629		Unnamed Alley	North 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0631		North 3rd Street	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0632		North 3rd Street	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Dr Martin Luther King Jr Drive Remediation Estimated Costs:										\$95,200	
SW0633	Casey Circle	North Clover Street	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0634				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Casey Circle Remediation Estimated Costs:										\$0	
SW0635	East Leah Street	North Home Street	North Morgan Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0636		North Morgan Street	North Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0637				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0638		North Division Street	Railroad Tracks	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0639				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0640		Depot Road	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0641				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0642		West Leah Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0643	N			N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
SW0644	N			N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
SW0645	Y			Y	Sidewalk limited to one property	NA	NA	No Barriers	\$0		
SW0646	N			N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
West Leah Street Remediation Estimated Costs:										\$0	
SW0643	East Vine Street	North 1st Street	Unnamed Alley	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0644		Unnamed Alley	North 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0645				Y	Y	Sidewalk limited to one property	NA	NA	No Barriers	\$0	
SW0646		N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0			
West Leah Street Remediation Estimated Costs:										\$0	
SW0657		East Vine Street	North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW-0657-01	Broken surface material	Replace broken surface material and poor quality material	\$9,280
SW0658			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0658-02	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0658			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0658-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0659			North Morgan Street	North Ury Street	Y	Y	Sidewalk starts N Morgan to N Ury	SW-0659-01	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0659			North Morgan Street	North Ury Street	Y	Y	Sidewalk starts N Morgan to N Ury	SW-0659-02	Broken surface material	Replace broken surface material and poor quality material	\$10,800
SW0660			North Morgan Street	North Ury Street	Y	Y	Sidewalk starts N Morgan to N Ury	SW-0660-01	Broken surface material	Replace broken surface material and poor quality material	\$5,400
SW0660			North Morgan Street	North Ury Street	Y	Y	Sidewalk starts N Morgan to N Ury	SW-0660-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0660			North Morgan Street	North Ury Street	Y	Y	Sidewalk starts N Morgan to N Ury	SW-0660-03	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0660			North Morgan Street	North Ury Street	Y	Y	Sidewalk starts N Morgan to N Ury	SW-0660-04	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0657			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW-0657-03	Curb Ramp	Construct 2 one way directional ramps; Add yellow truncated domes	\$2,500
SW0658			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0658-07	Debris	Clean debris form pathway	\$200
SW0658			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0658-03	Drive Ramp	Replace broken surface material and poor quality material	\$1,200
SW0658			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0658-06	Drive Ramp	Replace broken surface material and poor quality material	\$1,800
SW0657			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW-0657-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0658			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0658-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0658			North Home Street	North Morgan Street	Y	Y	Sidewalk starts at N Home to N Morgan	SW0658-01	Missing sidewalk	Replace missing where missing	\$900
SW0647			Nash Street	Royal Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0648			Royal Street	North Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0649			Nash Street	North Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0650		North Taylor Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0651		North Taylor Street	Greenwood Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0652		Greenwood Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0653		Greenwood Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0654		North Clover Street	North Dobbin Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0655		North Dobbin Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0656		North Clover Street	North Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0661		North Ury Street	North Division Street	Y	Y	Sidewalk starts at N Ury to 498	SW-0561-01	NA	No remediation recommended	\$0	
SW0662		North Ury Street	North Division Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0663	Depot Road	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
SW0664	Depot Road	North 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
SW0665	North 1st Street	North 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
SW0666	North 1st Street	North 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
West Leah Street Remediation Estimated Costs:										\$37,580	
SW0667	Keller Street	East Main Street	East Church Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0668				Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0669		East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0670				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Keller Street Remediation Estimated Costs:										\$0	

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0698	East Church Street	South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0698-04	Air conditioner	Provide cane protection	\$300
SW0697		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0697-01	Awnings	Reconstruct awning to allow for 80 vertical clearance	\$2,000
SW0675		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0575-01	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0675		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0575-02	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0675		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0575-03	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0675		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0575-04	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0675		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0575-05	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-05	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-06	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-08	Broken surface material	Replace broken surface material and poor quality material	\$6,000
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-10	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0682		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0682-02	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0682		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0682-03	Broken surface material	Replace broken surface material and poor quality material	\$6,900
SW0683		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0683-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0683		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0683-03	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0683		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0683-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0683		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0683-05	Broken surface material	Replace broken surface material and poor quality material	\$9,000
SW0684		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0684-02	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW0684		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0684-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0684		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0684-05	Broken surface material	Replace broken surface material and poor quality material ; Remove asphalt	\$1,400
SW0684		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0684-06	Broken surface material	Replace broken surface material and poor quality material ; Remove asphalt	\$300
SW0685		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0685-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0685		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0685-04	Broken surface material	Replace broken surface material and poor quality material ; Remove asphalt	\$1,700
SW0685		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0685-05	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0685		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0685-06	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0686		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0686-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0686		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0686-03	Broken surface material	Replace broken surface material and poor quality material	\$5,100
SW0687		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0687-02	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0687		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0687-03	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0687		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0687-04	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0687		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0687-05	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0687		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0687-06	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0688		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0688-01	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0688		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0688-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0688		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0688-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0688		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0688-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0689		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0689-01	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0689		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0689-04	Broken surface material	Replace broken surface material and poor quality material	\$7,500

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0692	East Church Street	South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0692-01	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0692		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0692-02	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW0692		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0692-03	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0692		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0692-04	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW0692		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0692-06	Broken surface material	Replace broken surface material and poor quality material	\$4,500
SW0692		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0692-07	Broken surface material	Replace broken surface material and poor quality material	\$750
SW0693		South Ury Street	Waddell Street (Railroad Tracks)	Y	Y	Sidewalk starts at S Ury to Waddell	SW0693-01	Broken surface material	Replace broken surface material and poor quality material	\$3,900
SW0693		South Ury Street	Waddell Street (Railroad Tracks)	Y	Y	Sidewalk starts at S Ury to Waddell	SW0693-02	Broken surface material	Replace broken surface material and poor quality material	\$6,000
SW0693		South Ury Street	Waddell Street (Railroad Tracks)	Y	Y	Sidewalk starts at S Ury to Waddell	SW0693-03	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0693		South Ury Street	Waddell Street (Railroad Tracks)	Y	Y	Sidewalk starts at S Ury to Waddell	SW0693-04	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0693		South Ury Street	Waddell Street (Railroad Tracks)	Y	Y	Sidewalk starts at S Ury to Waddell	SW0693-05	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0693		South Ury Street	Waddell Street (Railroad Tracks)	Y	Y	Sidewalk starts at S Ury to Waddell	SW0693-06	Broken surface material	Replace broken surface material and poor quality material; Replace missing sidewalk	\$11,400
SW0694		South Division Street	Unnamed Alley next to RR	Y	Y	Sidewalk starts at S Division to Alley	SW0694-01	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0696		Waddell Street (Railroad Tracks)	Perkins Street	Y	Y	Sidewalk starts at Waddell to Perkins	SW0696-01	Broken surface material	Replace broken surface material and poor quality material	\$7,800
SW0698		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0698-02	Broken surface material	Replace broken surface material and poor quality material	\$8,100
SW0675		South Miles Street	Keller Street	Y	Y	Sidewalk starts at S Miles to Keller	SW0575-06	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,500
SW0680		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at 1018 to Adams	SW0680-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-01	Curb Ramp	Construct 1 one way directional ramp; Add yellow truncated domes	\$1,550
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-11	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0682		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0682-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0682		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0682-04	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0683		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0683-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0683		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0683-06	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,100
SW0684		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0684-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$3,000
SW0684		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0684-07	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,550
SW0685		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0685-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0685		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0685-07	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,550
SW0686		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0686-01	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,550
SW0686		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0686-04	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0687		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at Dobbin to S Home	SW0687-01	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,550
SW0691		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0691-03	Curb Ramp	Add yellow truncated domes each side of drive ramp	\$700
SW0691		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0691-04	Curb Ramp	Add yellow truncated domes each side of drive ramp	\$700
SW0692		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW0692-05	Curb Ramp	Add yellow truncated domes	\$350
SW0694		South Division Street	Unnamed Alley next to RR	Y	Y	Sidewalk starts at S Division to Alley	SW0694-02	Curb Ramp	Construct a one way directional ramp with yellow truncated domes	\$1,250
SW0695		Unnamed Alley next to RR	South Depot Street	Y	Y	Sidewalk starts at Alley to S Depot	SW0695-01	Curb Ramp	Construct a diagonal ramp with yellow truncated domes	\$3,050
SW0696		Waddell Street (Railroad Tracks)	Perkins Street	Y	Y	Sidewalk starts at Waddell to Perkins	SW0696-02	Curb Ramp	Add yellow truncated domes	\$350
SW0696		Waddell Street (Railroad Tracks)	Perkins Street	Y	Y	Sidewalk starts at Waddell to Perkins	SW0696-03	Curb Ramp	Add yellow truncated domes	\$350
SW0697		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0697-02	Curb Ramp	Construct a diagonal ramp with yellow truncated domes	\$3,350
SW0698		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0698-01	Curb Ramp	Construct a diagonal ramp with yellow truncated domes	\$3,350
SW1088		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1008-01	Curb Ramp	Construct a diagonal ramp with yellow truncated domes	\$3,050
SW0688		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0688-05	Drive Ramp	Replace drive ramp with compliant 2% cross slopes in sidewalk continuation area	\$3,150
SW0689		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0689-03	Drive Ramp	Replace with sidewalk continuation area	\$1,200
SW0689		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0689-05	Drive Ramp	Replace with sidewalk continuation area	\$1,500
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0681		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0688		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0688-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0689		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0689-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0685		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0685-03	Heaved sidewalk	Replace sidewalk where	\$600
SW0698		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0698-03	Meter	Provide cane protection	\$300
SW0671		Ball Fields/Fairgrounds	North Sunswest Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0672		Ball Fields/Fairgrounds	North Sunswest Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)	
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification			
SW0673	East Church Street	North Sunswept Drive	South Miles Street	Y	Y	Sidewalk is not continuous in the entire block nor continuous along the housing complex.	SW0573-01	NA	No remediation recommended	\$0	
SW0674		North Sunswept Drive	South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0676		South Miles Street	Keller Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0677		Keller Street	South Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0678		Keller Street	Beck Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0679		Beck Street	South Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0690		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0690-01	NA	No Remediation Recommended	\$0	
SW0691		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0691-02	Run slope	Replace sidewalk and curb ramp; Add yellow truncated domes	\$3,350	
SW0681	West Church Street	South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0681-09	Shrub	Trim Shrub	\$200	
SW0684		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to Dobbin	SW0684-04	Tree	Replace broken surface material and poor quality material	\$200	
East Church Street Remediation Estimated Costs:										\$198,800	
SW0701		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0701-01	Awning	Raise awning to 80 inches	\$1,000	
SW0702		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0702-01	Broken surface material	Replace broken surface material and poor quality material	\$2,700	
SW0702		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0702-03	Broken surface material	Replace broken surface material and poor quality material	\$1,500	
SW0704		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0704-02	Broken surface material	Replace broken surface material and poor quality material	\$1,400	
SW0704		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0704-03	Broken surface material	Replace broken surface material and poor quality material	\$1,100	
SW0705		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0705-01	Broken surface material	Replace broken surface material and poor quality material	\$1,800	
SW0706		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0706-01	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW0706		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0706-02	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW0706		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0706-03	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW0706		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0706-06	Broken surface material	Replace broken surface material and poor quality material	\$3,300	
SW0707		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0707-01	Broken surface material	Replace broken surface material and poor quality material	\$3,300	
SW0707		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0707-02	Broken surface material	Replace broken surface material and poor quality material	\$5,700	
SW0707		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0707-04	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW0707		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0707-06	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW0707		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0707-07	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW0708		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to one house shy of S 6th	SW0708-01	Broken surface material	Replace broken surface material and poor quality material	\$0	
SW0708		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to one house shy of S 6th	SW0708-03	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW0708		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to one house shy of S 6th	SW0708-04	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW0699		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0699-01	Curb Ramp	Replace red domes with yellow domes	\$1,050	
SW0700		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0700-01	Curb Ramp	Replace red domes with yellow domes	\$1,050	
SW0699		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0699-02	Drive Ramp	Replace drive ramps with 2% cross slopes and 8.33% side slopes	\$9,000	
SW0701		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0701-02	Drive Ramp	Replace drive ramp with compliant 2% cross slopes in sidewalk continuation area	\$9,000	
SW0701		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0701-03	Drive Ramp	Replace drive ramp with compliant 2% cross slopes in sidewalk continuation area	\$2,100	
SW0702		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0702-02	Drive Ramp	Replace drive ramps with 2% cross slopes and 8.33% side slopes	\$6,000	
SW0705		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0705-02	Drive Ramp	Construct sidewalk continuation area where missing	\$1,200	
SW0706		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0706-04	Drive Ramp	Construct sidewalk continuation area where missing	\$1,500	
SW0707		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0707-03	Drive Ramp	Construct sidewalk continuation area where missing	\$1,800	
SW0704		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0704-01	Grass	Edge and trim grass; clean expansion joints	\$200	
SW0707		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0707-05	Grass	Edge and trim grass; clean expansion joints	\$200	
SW0708		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to one house shy of S 6th	SW0708-02	Grass	Edge and trim grass; clean expansion joints	\$200	
SW0702		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0702-04	Heaved sidewalk	Replace sidewalk where heaved	\$1,500	
SW0708		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to one house shy of S 6th	SW0708-05	Missing sidewalk	Replace sidewalk where missing	\$6,600	
SW0709		South 5th Street	South 6th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0704	South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0704-04	Settling	Replace sidewalk where settled	\$200		
SW0706	South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0706-05	Settling	Replace sidewalk where settled	\$1,200		
SW0700	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0700-02	Signs	Remove or raise signs to 80 inches	\$100		
SW0701	South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0701-04	Tree	Trim trees	\$300		
West Church Street Remediation Estimated Costs:										\$71,900	
SW0720	West Washington Avenue	South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0720-01	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW0720		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0720-02	Broken surface material	Replace broken surface material and poor quality material	\$3,000	
SW0720		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0720-04	Broken surface material	Replace broken surface material and poor quality material	\$4,200	
SW0721		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0721-01	Broken surface material	Replace broken surface material and poor quality material	\$5,400	

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0722	West Washington Avenue	South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0722-01	Broken surface material	Replace broken surface material and poor quality material. No remediation since serves only one property in sidewalk segment	\$0
SW0723		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 6th	SW0723-01	Broken surface material	Replace broken surface material and poor quality material to 520	\$15,000
SW0710		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0710-01	Curb ramp	Replace with a compliant diagonal ramp; Add yellow truncated domes	\$3,350
SW0711		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0711-01	Curb ramp	Replace with a compliant diagonal ramp; Add yellow truncated domes	\$3,350
SW0712		South 1st Street	Post Office Alley	Y	Y	Sidewalk starts at S 1st to Post Office Alley	SW0712-01	Drive Ramp	Construct sidewalk continuation area where missing	\$2,400
SW0713		South 1st Street	Post Office Alley	Y	Y	Sidewalk starts at S 1st to Post Office Alley	SW0713-01	Drive Ramp	Construct sidewalk continuation area where missing	\$2,400
SW0720		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0720-03	Drive Ramp	Construct sidewalk continuation area where missing	\$1,200
SW0710		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW07010-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0714		Post Office Alley	South 2nd Street	Y	Y	Sidewalk starts at Post Office Alley to S 2nd	SW0714-01	NA	None required	\$0
SW0715		Post Office Alley	South 2nd Street	Y	Y	Sidewalk starts at Post Office Alley to S 2nd	SW0715-01	NA	None required	\$0
SW0716		South 2nd Street	Bill Burnett Circle	Y	Y	Sidewalk starts at S 2nd to Bill Burnett Circle	SW0716-01	NA	None required	\$0
SW0717		South 2nd Street	Bill Burnett Circle	Y	Y	Sidewalk starts at S 2nd to Bill Burnett Circle	SW0717-01	NA	None required	\$0
SW0718		Bill Burnett Circle	South 4th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0719		Bill Burnett Circle	South 4th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0724		South 6th Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0725		South 6th Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Washington Avenue Remediation Estimated Costs:										\$41,100
SW0727	High Street	Keller Street	Beck Street	Y	Y	Sidewalk starts at 1314 High to Beck	SW0727-01	Broken surface material	Replace broken surface material and poor quality material; No remediation since sidewalk incomplete in segment	\$0
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-01	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-03	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-10	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-12	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0729		Beck Street	South Taylor Street	Y	Y	Sidewalk starts at 1204 High to S Taylor	SW0729-01	Broken surface material	Replace broken surface material and poor quality material; No remediation since sidewalk incomplete in segment	\$0
SW0730		Beck Street	South Taylor Street	Y	Y	Sidewalk starts at Beck to S Taylor	SW0730-02	Broken surface material	Replace broken surface material and poor quality material	\$0
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-04	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-06	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-09	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0732		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0732-02	Broken surface material	Replace broken surface material and poor quality material	\$13,800
SW0732		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0732-03	Broken surface material	Replace broken surface material and poor quality material	\$6,600
SW0732		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0732-04	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0732		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0732-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0732		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0732-06	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0732a		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0732a-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0733		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0733-06	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0734		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0734-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0734		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0734-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0734		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0734-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0735		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0735-02	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-02	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-03	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-04	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-06	Broken surface material	Replace broken surface material and poor quality material	\$3,600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0736	High Street	South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-07	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-08	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-09	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-12	Broken surface material	Replace broken surface material and poor quality material	\$8,400
SW0737		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0737-01	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0737		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0737-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0737		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW0737-03	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW0738		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW0738-01	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0739		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Home to S Ury	SW0739-01	Broken surface material	Replace broken surface material and poor quality material to 601	\$24,600
SW0739		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Home to S Ury	SW0739-02	Broken surface material	Replace broken surface material and poor quality material to 602	\$6,000
SW0739		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Home to S Ury	SW0739-03	Broken surface material	Replace broken surface material and poor quality material to 603	\$1,200
SW0739		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Home to S Ury	SW0739-05	Broken surface material	Replace broken surface material and poor quality material to 603	\$2,100
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-18	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,200
SW0730		Beck Street	South Taylor Street	Y	Y	Sidewalk starts at Beck to S Taylor	SW0730-04	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$200
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-01	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-10	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0732		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0732-01	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0732		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0732-07	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0732a		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0732a-01	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0732a		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0732a-07	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0733		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0733-01	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0733		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0733-07	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0734		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0734-01	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0734		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0734-06	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,250
SW0735		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0735-01	Curb ramp	Construct a one way directional ramp with yellow truncated domes	\$1,250
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-01	Curb ramp	Construct 2 perpendicular directional ramp2 with yellow truncated domes	\$2,800
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-09	Grass	Edge and trim grass; clean expansion joints	\$200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-11	Grass	Edge and trim grass; clean expansion joints	\$200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-13	Grass	Edge and trim grass; clean expansion joints	\$200
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-17	Grass	Edge and trim grass; clean expansion joints	\$200
SW0730		Beck Street	South Taylor Street	Y	Y	Sidewalk starts at Beck to S Taylor	SW0730-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW0730		Beck Street	South Taylor Street	Y	Y	Sidewalk starts at Beck to S Taylor	SW0730-03	Grass	Edge and trim grass; clean expansion joints	\$0
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-03	Grass	Edge and trim grass; clean expansion joints	\$0
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-05	Grass	Edge and trim grass; clean expansion joints	\$200
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-07	Grass	Edge and trim grass; clean expansion joints	\$200
SW0731		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW0731-08	Grass	Edge and trim grass; clean expansion joints	\$200
SW0732a		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0732a-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0732a		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0732a-06	Grass	Edge and trim grass; clean expansion joints	\$200
SW0732a		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0732a-03	Heaved sidewalk	Replace sidewalk where heaved	\$1,200
SW0734		South Clover Street	South Dobbin Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW0734-02	Heaved sidewalk	Replace sidewalk where heaved	\$900
SW0735		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0735-03	Heaved sidewalk	Replace sidewalk where heaved	\$2,100
SW0735		South Dobbin Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW0735-04	Heaved sidewalk	Replace sidewalk where heaved	\$2,100
SW0733		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0733-02	Missing sidewalk	Replace sidewalk where missing	\$600
SW0733		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0733-03	Missing sidewalk	Replace sidewalk where missing	\$900
SW0733		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0733-04	Missing sidewalk	Replace sidewalk where missing	\$1,200

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)	
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification			
SW0733	High Street	Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0733-05	Missing sidewalk	Replace sidewalk where missing	\$600	
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-10	Missing sidewalk	Replace sidewalk where missing	\$600	
SW0736		South Clover Street	South Home Street	Y	Y	Sidewalk starts at S Clover to S Home	SW0736-11	Missing sidewalk	Replace sidewalk where missing	\$300	
SW0726		South Miles Street	Keller Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0732a		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW0732a-04	Run Slope	Replace sidewalk continuation area	\$1,200	
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-08	Settling	Replace sidewalk where settled	\$1,200	
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-14	Settling	Replace sidewalk where settled	\$900	
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-15	Settling	Replace sidewalk where settled	\$2,400	
SW0728		South Miles Street	Beck Street	Y	Y	Sidewalk starts at S Miles to Beck	SW0728-16	Settling	Replace sidewalk where settled	\$2,100	
SW0739		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Home to S Ury	SW0739-04	Settling	Replace sidewalk where settled	\$900	
SW0739	South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Home to S Ury	SW0739-06	Shrub	Trim Shrub	\$300		
High Street Remediation Estimated Costs:										\$161,700	
SW0740	Howard Street	South Clover Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0741				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Howard Street Remediation Estimated Costs:										\$0	
SW0742	Summer Street	Russell Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0743			Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0744		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0745		Woodlawn Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0746		South Ury Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0747		South Home Street	Pierce Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0748		Pierce Street	Lilac Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0749		Lilac Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Summer Street Remediation Estimated Costs:										\$0	
SW0750	East Lee Street	South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0750-01	Awning	Raise awning to 80 inches	\$1,000	
SW0750							SW0750-02	Curb ramp	Construct diagonal ramp with yellow truncated domes with landing in ramp	\$3,050	
SW0751				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
East Lee Street Remediation Estimated Costs:										\$4,050	
SW0752	West Lee Street	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0752-01	Air conditioner	Add cane protection to all AC units	\$300	
SW0752		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0752-03	Awning	Raise awning to 80 inches	\$500	
SW0752		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0752-04	Broken surface material	Replace broken surface material and poor quality material	\$6,300	
SW0753		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0753-01	Broken surface material	Replace broken surface material and poor quality material	\$2,700	
SW0755		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0755-02	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW0756		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0756-01	Broken surface material	Replace broken surface material and poor quality material from alley to S 4th	\$8,400	
SW0757		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0757-01	Broken surface material	Replace broken surface material and poor quality material	\$1,800	
SW0757		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0757-03	Broken surface material	Replace broken surface material and poor quality material	\$2,100	
SW0758		South 4th Street	Unnamed Alley	Y	Y	Sidewalk starts at S 4th to Alley	SW0758-01	Broken surface material	Replace broken surface material and poor quality material	\$1,800	
SW0759		Unnamed Alley	South 5th Street	Y	Y	Sidewalk starts at Alley to 5th	SW0759-01	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW0760		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at 4th to 5th	SW0760-01	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW0760		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at 4th to 5th	SW0760-03	Broken surface material	Replace broken surface material and poor quality material	\$0	
SW0760		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at 4th to 5th	SW0760-05	Broken surface material	Replace broken surface material and poor quality material	\$7,200	
SW0754		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0754-01	Drive Ramp	Construct sidewalk continuation area	\$1,500	
SW0755		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0755-01	Drive Ramp	Replace with a compliant drive with 2% cross slope and 8.33% rune slopes	\$5,400	
SW0757		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0757-02	Drive Ramp	Replace with a compliant drive with 2% cross slope and 8.33% rune slopes	\$6,000	
SW0758		South 4th Street	Unnamed Alley	Y	Y	Sidewalk starts at S 4th to Alley	SW0758-03	Drive Ramp	Replace with a compliant drive ramp	\$3,000	
SW0760		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at 4th to 5th	SW0760-02	Drive Ramp	Construct a compliant sidewalk continuation area	\$0	
SW0760		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at 4th to 5th	SW0760-04	Drive Ramp	Replace with a compliant drive with 2% cross slope and 8.33% rune slopes	\$2,400	
SW0758		South 4th Street	Unnamed Alley	Y	Y	Sidewalk starts at S 4th to Alley	SW0758-02	Grass	Edge and trim grass; clean expansion joints	\$200	
SW0759		Unnamed Alley	South 5th Street	Y	Y	Sidewalk starts at Alley to 5th	SW0759-02	Grass	Edge and trim grass; clean expansion joints	\$200	
SW0752		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0752-05	Heaved sidewalk	Replace sidewalk where heaved	\$900	
SW0752		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0752-02	Tree	Trim trees	\$500	
West Lee Street Remediation Estimated Costs:										\$53,900	
SW0761		East High School Drive	End of Drive	Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-04	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0761	End of Drive		Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-05	Curb Ramp	Construct 2 one way directional ramps; Add yellow truncated domes	\$21,700	
SW0761	End of Drive		Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-08	Curb Ramp	Construct a diagonal ramp; Add yellow truncated domes	\$3,050	
SW0761	End of Drive		Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-01	Debris	Clean up debris	\$200	
SW0761	End of Drive		Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-06	Grass	Edge and trim grass; clean expansion joints	\$0	
SW0761	End of Drive		Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-07	Grass	Edge and trim grass; clean expansion joints	\$0	
SW0762	End of Drive		Sunswept Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0763	Sunswept Drive		South Sunswept Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0764	South Sunswept Street		Matthews Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0765	Matthews Street		South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0766	Sunswept Drive		South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0761	End of Drive		Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-02	Settling	Replace sidewalk where settled	\$1,200	
SW0761	End of Drive		Sunswept Drive	Y	Y	Sidewalk starts at End of Drive to S Sunswept	SW0761-03	Settling	Replace sidewalk where settled	\$1,200	
East High School Drive Remediation Estimated Costs:										\$27,950	

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0767	South Sunswept Street	Sunswept Drive	East High School Drive	Y	Y	Housing Authority Sidewalks, not at street side	NA	NA	No Barriers	\$0
SW0768				Y	Y	Housing Authority Sidewalks, not at street side	NA	NA	No Barriers	\$0
South Sunswept Street Remediation Estimated Costs: \$0										
SW0769	Matthews Street	East High School Drive	South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0770				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Matthews Street Remediation Estimated Costs: \$0										
SW0771	High School Drive	South Miles Street	East Florida Avenue (N-S)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0772				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
High School Drive Remediation Estimated Costs: \$0										
SW0773	East High School Drive	High School Drive	East High School Drive (E-W)	Y	Y	Sidewalk starts at Middle School entrance to E High School (E-W)	NA	NA	No Barriers	\$0
SW0774		High School Drive	East High School Drive (E-W)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0775		East High School Drive (N-S)	Russell Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0776		East High School Drive (N-S)	Russell Street	Y	Y	Sidewalk starts at E-W turn to Russell	NA	NA	No Barriers	\$0
East High School Drive Remediation Estimated Costs: \$0										
SW0793	East Florida Avenue	Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0793-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0793		Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0793-03	Broken surface material	Replace broken surface material and poor quality material	\$11,400
SW0794		Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0794-02	Broken surface material	Replace broken surface material and poor quality material	\$16,200
SW0797		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0797-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW0798		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0798-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0798		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0798-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW0798		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0798-05	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW0802		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW0802-01	Broken surface material	No remediation recommended	\$0
SW0793		Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0793-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0794		Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0794-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0797		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0797-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0798		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0798-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0799		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW0799-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0799		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW0799-03	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0800		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW0800-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0800		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW0800-02	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0797		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0797-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0798		South Rose Street	Perkins Street	Y	Y	Sidewalk starts at S Rose to Perkins	SW0798-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0799		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW0799-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0777		High School Drive	East Florida Avenue (E-W)	Y	Y	Sidewalk starts at Middle School entrance to E Florida (E-W)	NA	NA	No Barriers	\$0
SW0778		High School Drive	East Florida Avenue (E-W)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0779		East Florida Avenue (N-S)	South Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0780		South Taylor Street	Russell Street	Y	Y	Sidewalk starts at S Taylor to Russell	NA	NA	No Barriers	\$0
SW0781		East Florida Avenue (N-S)	Russell Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0782		Russell Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0783		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0784		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0785		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0786		Woodlawn Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0787		Woodlawn Street	Whirmantler Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0788		Whirmantler Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0789		South Home Street	Pierce Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0790		Pierce Street	Lilac Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0791		Pierce Street	Lilac Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0792		Pierce Street	Lilac Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0795		South Ury Street	South Rose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0796		South Ury Street	South Rose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0801		South Depot Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Florida Avenue Remediation Estimated Costs: \$55,700										
SW0803	West Florida Avenue	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0803-01	Broken surface material	Replace broken surface material and poor quality material	\$13,800
SW0804		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st to S 2nd	SW0804-01	Broken surface material	Replace broken surface material and poor quality material	\$13,800
SW0805		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0805-01	Broken surface material	Replace broken surface material and poor quality material	\$7,200
SW0806		South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW0806-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$15,900
SW0807		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW0807-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$14,400
SW0808		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW0808-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment except 411	\$14,400
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-01	Broken surface material	Replace broken surface material and poor quality material to	\$8,100
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-03	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-06	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-09	Broken surface material	Replace broken surface material and poor quality material	\$3,600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0810	West Florida Avenue	South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 5th on south side of W Florida	SW0810-02	Broken surface material	Replace broken surface material and poor quality material	\$7,200
SW0810		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 5th on south side of W Florida	SW0810-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$0
SW0810		South 5th Street	South 6th Street	Y	Y	Sidewalk starts at S 5th to S 5th on south side of W Florida	SW0810-03	Curb Ramp	Construct a parallel ramp; Add yellow truncated domes	\$1,550
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-04	Drive Ramp	Replace with a compliant drive with sidewalk continuation area	\$6,000
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-02	Grass	Edge and trim grass; clean expansion joints	\$200
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-07	Heaved sidewalk	Replace sidewalk where heaved	\$3,000
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-08	Heaved sidewalk	Replace sidewalk where heaved	\$3,000
SW0809		South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-10	Missing sidewalk	Construct sidewalk where missing	\$6,300
SW0811		South 6th Street	South 7th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0812		South 6th Street	South 7th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0809	South 3rd Street	South 5th Street	Y	Y	Sidewalk starts at S 3rd to S 5th	SW0809-05	Settling	Replace sidewalk where settled	\$900	
West Florida Avenue Remediation Estimated Costs:										\$123,550
SW0823	East Bransford Street	Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0823-02	Broken surface material	Replace broken surface material and poor quality material of entire street segment	\$18,600
SW0822		Pierce Street	Lilac Street	Y	Y	Sidewalk starts at Pierce to Lilac	SW0822-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0822		Pierce Street	Lilac Street	Y	Y	Sidewalk starts at Pierce to Lilac	SW0822-02	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,550
SW0823		Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0823-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0823		Lilac Street	South Ury Street	Y	Y	Sidewalk starts at Lilac to S Ury	SW0823-03	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW0813		Russell Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0814		Russell Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0815		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0816		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0817		Woodlawn Street	Whirmantler Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0818		Woodlawn Street	Whirmantler Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0819		Whirmantler Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0820		Whirmantler Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0821		South Home Street	Pierce Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0824		South Home Street	South Uri Street	Y	Y	Sidewalk starts and ends at 625 E Bransford	SW0824-01	NA	No remediation recommended	\$0
SW0825		South Ury Street	South Rose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0826		South Rose Street	Perkins Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0827	South Ury Street	Perkins Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0828	Perkins Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0829	Perkins Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
East Bransford Street Remediation Estimated Costs:										\$28,550
SW0831	West Bransford Street	South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st5 to S 2nd	SW0831-02	Broken surface material	Replace broken surface material and poor quality material of entire street segment	\$13,800
SW0831		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts at S 1st5 to S 2nd	SW0831-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,100
SW0830		South 1st Street	South 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0832		South 2nd Street	South 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0833		South 2nd Street	South 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0834		South 3rd Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0835		South 3rd Street	Nevel Street - then end of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Bransford Street Remediation Estimated Costs:										\$15,900
SW0836	East Oak Street	South Miles Street	Russell Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0837		Sheridan Drive	Sheridan Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0838		Sheridan Drive	Sheridan Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0839		Sheridan Drive	Russell Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0840		Russell Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0841		Russell Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0842		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0843		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0844		Woodlawn Street	Whirmantler Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0845		Woodlawn Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0846		Whirmantler Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0847		South Home Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0848	South Home Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
East Oak Street Remediation Estimated Costs:										\$0
SW0849	Sheridan Drive	East Oak Street	Sheridan Drive (E-W)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0850		Sheridan Drive (N-S, East Side)	Sheridan Drive (N-S, West Side)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0851		Sheridan Drive (N-S, East Side)	Sheridan Drive (N-S, West Side)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0852		East Oak Street	Sheridan Drive (E-W)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0853		East Oak Street	Sheridan Drive (E-W)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0854	East Oak Street	Sheridan Drive (E-W)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Sheridan Drive Remediation Estimated Costs:										\$0
SW0858	East Bishop Street	Elementary School Entrance	Elementary School Entrance	Y	Y	Sidewalk starts at Entrance to Entrance	SW0858-01	Curb Ramp	Add yellow truncated domes	\$0
SW0859		Elementary School Entrance	South Miles Street	Y	Y	Blacktop Sidewalk starts at entrance and turns north halfway to S Miles	SW0859-01	Curb Ramp	Add yellow truncated domes	\$0
SW0863		Russell Street	Edwards Street	Y	Y	Sidewalk starts at Church of Christ to Edwards	SW0863-01	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,250
SW0863		Russell Street	Edwards Street	Y	Y	Sidewalk starts at Church of Christ to Edwards	SW0863-02	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,260
SW0863		Russell Street	Edwards Street	Y	Y	Sidewalk starts at Church of Christ to Edwards	SW0863-03	Drive Ramp	Replace with a compliant drive ramp	\$1,500
SW0855		Sunswept Drive	School Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0856		Sunswept Drive	South Sunswept Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0857		South Sunswept Drive	South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0860		South Miles Street	Russell Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0861		South Miles Street	Hillcrest Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0862		Hillcrest Street	Russell Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0864		Russell Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0865		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0866		Edwards Street	Woodlawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0867		Woodlawn Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0868		Woodlawn Street	South Home Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0869		South Home Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0870		South Home Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Bishop Street Remediation Estimated Costs:										\$4,010
SW0871	Hillcrest Drive	East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0872		East Bishop Street	East Reelfoot Avenue	Y	Y	Sidewalk starts at Clinic entrance to East Reelfoot	SW0872-01	NA	Nine required	\$0
Hillcrest Drive Remediation Estimated Costs:										\$0
SW0873	Perry Browder Road	Hunter Lane (City Limits)	Railroad Tracks (City Limits)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Perry Browder Road Remediation Estimated Costs:										\$0
SW0874	Hunter Lane	Perry Browder Road (City Limits)	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0875		Perry Browder Road (City Limits)	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Hunter Lane Remediation Estimated Costs:										\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0882	North Clover Street	Jere B Ford Memorial Highway	Sherwood Drive	Y	Y	Sidewalk starts at Jere B Ford to Sherwood Drive	SW0882-01	Curb ramp	Replace red domes with yellow domes	\$350
SW0882		Jere B Ford Memorial Highway	Sherwood Drive	Y	Y	Sidewalk starts at Jere B Ford to Sherwood Drive	SW0882-02	Curb ramp	Replace red domes with yellow domes	\$350
SW0884		Sherwood Drive	Magnolia Place	Y	Y	Sidewalk starts at Sherwood Drive to Magnolia Place	SW0884-01	Curb ramp	Replace red domes with yellow domes	\$350
SW0884		Sherwood Drive	Magnolia Place	Y	Y	Sidewalk starts at Sherwood Drive to Magnolia Place	SW0884-02	Curb ramp	Add yellow domes	\$350
SW0876		City Limits	Unnamed Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0877		Unnamed Road	Greenfield Drive (Industrial Parkway)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0878		Greenfield Drive (Industrial Parkway)	Veteran's Park Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0879		Veteran's Park Entrance	Jere B Ford Memorial Highway	Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0880		A future road (City Limits)	Barnham Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0881		Barnham Road	Jere B Ford Memorial Highway	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0883		Jere B Ford Memorial Highway	Sherwood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0885		Sherwood Drive	Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0886		Robinhood Drive	Jordan Terrace	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0887		Magnolia Place	Mosswood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0888		Mosswood Drive	East Todd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0889		Jordan Terrace	East Todd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0890		East Todd Street	East Cheatham Street	Y	Y	Sidewalk starts at E Todd to E Cheatham	SW0890-01	NA	No remediation recommended	\$0
SW0891		East Todd Street	East Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0892		East Cheatham Street	East Mercer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0893		East Cheatham Street	East Mercer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0894		East Mercer Street	East Gibbs Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0895		East Gibbs Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0896		East Mercer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0897		East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0898		East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0899		Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0900		Dr Martin Luther King Jr Drive	Casey Circle	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0901		Casey Circle	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0902	East Vine Street	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW0903	East Vine Street	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
North Clover Street Remediation Estimated Costs:										\$1,400
SW0907	South Clover Street	Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0907-02	Broken surface material	Replace broken surface material and poor quality material	\$300
SW0907		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0907-03	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW0907		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0907-04	Broken surface material	Replace broken surface material and poor quality material	\$6,600
SW0909		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW0909-01	Broken surface material	Replace broken surface material and poor quality material of entire street segment	\$15,600
SW0907		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW0907-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,450
SW0904		East Main Street	Exchange Street	Y	Y	Sidewalk starts and ends at 101 S Clover	SW0904-01	NA	Sidewalk limited to one property; No remediation required	\$0
SW0905		Exchange Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW0905-01	NA	Sidewalk limited to one property; No remediation required	\$0
SW0906		Exchange Street	East Church Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0908		East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0910		High Street	Howard Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0911		High Street	Howard Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
South Clover Street Remediation Estimated Costs:										\$26,450
SW0912	Greenfield Drive	North Clover Street	Turn in road south	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0913				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0914			Spur Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0915		Turn in road south	Greenfield Products Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0916		Spur Drive	Made in America Seating Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0917		Greenfield Products Entrance	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0918		Made in America Seating Entrance	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Greenfield Drive Remediation Estimated Costs:										\$0
SW0919	Spur Drive	Greenfield Drive	Railroad Tracks (City Limits)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0920				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Spur Drive Remediation Estimated Costs:										\$0
SW0921	Entrance to Veteran's Park	North Clover Street	Circle Cul-de-sac	Y	Y	Sidewalk Starts and ends at parking spaces	SW0921-01	NA	No remediation recommended	\$0
SW0922				Y	Y	Sidewalk Starts and ends at parking spaces	SW0922-01	NA	No remediation recommended	\$0
Entrance to Veteran's Park Remediation Estimated Costs:										\$0
SW0923	Barnham Road	North Clover Street	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0924				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Barnham Road Remediation Estimated Costs:										\$0
SW0925	Mount Zion Road	City Limits	Bradford Pear Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0926			E - W turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0927		E - W turn	George Moss Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0928		Bradford Pear Lane	Unnamed Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0929		Unnamed Road	Mount Zion Road turn to N - S	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0930		Mount Zion Road turn to N - S	Brevard Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0931		George Moss Road	Goodyear Plant Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0932		Goodyear Plant Road	Goodyear Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0933		Brevard Road	Jere B Ford Memorial Highway	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0934		Goodyear Road	Jere B Ford Memorial Highway	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0935		Jere B Ford Memorial Highway	Law Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0936		Law Lane	Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0937		Jere B Ford Memorial Highway	Turn in road south	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0938		Turn in road south	Graham Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0939		Robinhood Drive	West Tate Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0940		Graham Drive	West Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0941		West Tate Street	West Cheatham Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Mount Zion Road Remediation Estimated Costs:										\$0
SW0942	Goodyear Road	Mount Zion Road	Goodyear Plant Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0943			City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Goodyear Road Remediation Estimated Costs:										\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est. (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW0944	Brevard Road	Mount Zion Road	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0945			City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Brevard Road Remediation Estimated Costs:										\$0
SW0946	Law Lane	Mount Zion Road	Obion County Sherriff/Jail Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0947		Obion County Sherriff/Jail Entrance	E - W turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0948		Mount Zion Road	E - W turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0949		E - W turn	Barham Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0950			North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Law Lane Remediation Estimated Costs:										\$0
SW0951	Robinhood Drive	Mount Zion Road	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0952			North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Robinhood Drive Remediation Estimated Costs:										\$0
SW0953	North Morgan Street Extension	City Limits	West Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0954			Sherwood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0955		Sherwood Drive	West Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0956			West Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0957		Dead End	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
North Morgan Street Extension Remediation Estimated Costs:										\$0
SW0958	West Robinhood Drive	Dead End	North Morgan Street Extension	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0959			Harding Place	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0960		Harding Place	North Morgan Street Extension	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0961			North Morgan Street Extension	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0962		Parking Lot	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
West Robinhood Drive Remediation Estimated Costs:										\$0
SW0963	Harding Place	West Robinhood Drive	Dead End	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0964				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Harding Place Remediation Estimated Costs:										\$0
SW0965	Sherwood Drive	North Morgan Street Extension	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0966				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0967		North Clover Street	Robinhood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0968				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0969		Robinhood Drive	Little John Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0970				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0971		Little John Drive	Forest Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0972				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0973		Forest Drive	Friar Tuck Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0974				North Miles Avenue Extended	N	N	No Sidewalk in street segment	NA	NA	No Barriers
Sherwood Drive Remediation Estimated Costs:										\$0
SW0975	Robinhood Drive	North Clover Street	Sherwood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0976				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0977		Sherwood Drive	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0978				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Robinhood Drive Remediation Estimated Costs:										\$0
SW0979	Little John Drive	Sherwood Drive	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0980				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Little John Drive Remediation Estimated Costs:										\$0
SW0981	Lady Marion Drive	Sherwood Drive	Nottingham Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0982				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Lady Marion Drive Remediation Estimated Costs:										\$0
SW0983	Nottingham Drive	Lady Marion Drive	North Miles Avenue Extended	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0984				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Nottingham Drive Remediation Estimated Costs:										\$0
SW0985	Forest Drive	Sherwood Drive	Cul-de-sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0986				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Forest Drive Remediation Estimated Costs:										\$0
SW0987	Friar Tuck Drive	Sherwood Drive	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0988				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Friar Tuck Drive Remediation Estimated Costs:										\$0
SW1091	North Miles Avenue Extended	Nottingham Drive	Sherwood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1092				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North Miles Avenue Extended Remediation Estimated Costs:										\$0
SW0989	Graham Drive	Mount Zion Road	Jere B Ford Memorial Highway	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0990				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0991		Jere B Ford Memorial Highway	Welcome Circle	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0992				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0993		Welcome Circle	North Dead End	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0994				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0995		Welcome Circle	E - W turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0996				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0997		E - W turn	Sleep Inn and Suites	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW0998				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Graham Drive Remediation Estimated Costs:										\$0
SW0999	West Tate Street	Mount Zion Road	North 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1000				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Tate Street Remediation Estimated Costs:										\$0
SW1001	Wade Street	Perkins Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1002				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1003		South 1st Street	South 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1004				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1005		South 2nd Street	South 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1006				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1007		South 3rd Street	South 4th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1008	N			N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Wade Street Remediation Estimated Costs:										\$0
SW1009	East Jackson Street	South Home Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1010				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1011		South Ury Street	Perkins Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1012				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1013		Perkins Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1014				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Jackson Street Remediation Estimated Costs:										\$0
SW1018	West Jackson Street	South 2nd Street	South 3rd Street	Y	Y	Sidewalk starts at S 2nd to S 3rd	SW1018-01	Broken surface material	Replace broken surface material and poor quality material on entire street segment	\$11,400
SW1019		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1019-01	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1019		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1019-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW1019		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1019-03	Broken surface material	Replace broken surface material and poor quality material on entire street segment	\$2,400
SW1020		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW1020-02	Broken surface material	Replace broken surface material and poor quality material on street segment from 306 to 320	\$9,600

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est. (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW1021	West Jackson Street	South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW1021-01	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW1021		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW1021-02	Broken surface material	Replace broken surface material and poor quality material	\$0
SW1021		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW1021-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1021		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW1021-05	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW1019		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1019-05	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1019		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1019-04	Grass	Edge and trim grass; clean expansion joints	\$200
SW1020		South 3rd Street	South 4th Street	Y	Y	Sidewalk starts at S 3rd to S 4th	SW1020-01	Grass	Edge and trim grass; clean expansion joints	\$200
SW1021		South 4th Street	South 5th Street	Y	Y	Sidewalk starts at S 4th to S 5th	SW1021-03	Grass	Edge and trim grass; clean expansion joints	\$200
SW1015		South 1st Street	South 2nd Street	Y	Y	Sidewalk starts and ends at Union City Tire Auto Sales	SW1015-01	NA	No remediation recommended	\$0
SW1016		South 1st Street	South 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1017		South 2nd Street	South 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1022		Nevel Street	South 5th Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Jackson Street Remediation Estimated Costs:										\$34,600
SW1023	East Park Street	Perkins Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1024			Unnamed Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1025		Unnamed Road	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Park Street Remediation Estimated Costs:										\$0
SW1026	West Park Street	South 1st Street	South 2nd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1027				Y	Y	Sidewalk starts at S 1st for < 100 ft	SW1027-01	NA	No remediation recommended	\$0
SW1028				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1029		South 2nd Street	South 3rd Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
West Park Street Remediation Estimated Costs:										\$0
SW1030	West Sterling Street	South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1030-01	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1030		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1030-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1030		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1030-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1030		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1030-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1030		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1030-05	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1031		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1031-01	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW1031		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1031-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1031		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1031-03	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW1030		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1030-06	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1031		South 3rd Street	Nevel Street	Y	Y	Sidewalk starts at S 3rd to Nevel	SW1031-04	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
West Sterling Street Remediation Estimated Costs:										\$13,700
SW1032	East Flower Street	South Home Street	Pierce Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1033				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1034		Pierce Street	Lilac Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1035				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1036		Lilac Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1037				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1038				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1039		South Ury Street	Rose Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Flower Street Remediation Estimated Costs:										\$0
SW1040	Harrison Street	Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1040-02	Broken surface material	Replace broken surface material and poor quality material	\$4,800
SW1040		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1040-04	Broken surface material	Replace broken surface material and poor quality material	\$1,100
SW1040		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1040-05	Broken surface material	Replace broken surface material and poor quality material	\$12,000
SW1041		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1041-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1041		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1041-03	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1041		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1041-04	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW1042		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1042-01	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1042		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1042-02	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW1042		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1042-03	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1042		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1042-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1042		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1042-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1042		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1042-06	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1043		South Ury Street	Rose Street	Y	Y	Sidewalk starts at S Ury to Rose	SW1043-02	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1044		Rose Street	Perkins Street	Y	Y	Sidewalk starts at Rose to Perkins	SW1044-02	Broken surface material	Replace broken surface material and poor quality material	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)	
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification			
SW1044	Harrison Street	Rose Street	Perkins Street	Y	Y	Sidewalk starts at Rose to Perkins	SW1044-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW1044		Rose Street	Perkins Street	Y	Y	Sidewalk starts at Rose to Perkins	SW1044-05	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-05	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-07	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-09	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW1047		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1047-03	Broken surface material	Replace broken surface material and poor quality material	\$750	
SW1047		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1047-04	Broken surface material	Replace broken surface material and poor quality material	\$750	
SW1040		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1040-01	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,250	
SW1040		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1040-06	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,100	
SW1043		South Ury Street	Rose Street	Y	Y	Sidewalk starts at S Ury to Rose	SW1043-03	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$1,250	
SW1044		Rose Street	Perkins Street	Y	Y	Sidewalk starts at Rose to Perkins	SW1044-01	Curb Ramp	Construct a one way directional ramp; Add yellow truncated domes	\$9,350	
SW1044		Rose Street	Perkins Street	Y	Y	Sidewalk starts at Rose to Perkins	SW1044-07	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-11	Curb Ramp	Construct a diagonal ramp Add yellow truncated domes	\$0	
SW1047		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1047-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800	
SW1047		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1047-05	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$0	
SW1049		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW1049-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800	
SW1049		South Depot Street	South 1st Street	Y	Y	Sidewalk starts at S Depot to S 1st	SW1049-02	Curb Ramp	Construct a diagonal ramp; Add yellow truncated domes	\$3,050	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-04	Drive Ramp	Replace with a compliant drive ramp	\$1,800	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-06	Drive Ramp	Replace with a compliant drive ramp	\$1,500	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-08	Drive Ramp	Replace with a compliant drive ramp	\$4,500	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-10	Drive Ramp	Replace with a compliant drive ramp	\$4,500	
SW1040		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1040-03	Grass	Edge and trim grass; clean expansion joints	\$0	
SW1041		Waddell Street	South Ury Street	Y	Y	Sidewalk starts at Waddell to S Ury	SW1041-01	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1043		South Ury Street	Rose Street	Y	Y	Sidewalk starts at S Ury to Rose	SW1043-01	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1044		Rose Street	Perkins Street	Y	Y	Sidewalk starts at Rose to Perkins	SW1044-06	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1047		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1047-02	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-03	Hydrant	Construct sidewalk around pole	\$1,200	
SW1044		Rose Street	Perkins Street	Y	Y	Sidewalk starts at Rose to Perkins	SW1044-04	Missing sidewalk	Replace sidewalk where missing in drive	\$1,800	
SW1045		South Division Street	Perkins Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1048		South Depot Street	South 1st Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1046		Perkins Street	South Depot Street	Y	Y	Sidewalk starts at Perkins to S Depot	SW1046-02	Poles	Construct sidewalk around pole	\$1,200	
Harrison Street Remediation Estimated Costs:										\$83,500	
SW1051	Waddell Street	South Home Street	Harrison Street	Y	Y	Sidewalk starts at S Home to Harrison	SW1051-01	Broken surface material	Replace broken surface material and poor quality material from S Home to 623	\$8,400	
SW1051		South Home Street	Harrison Street	Y	Y	Sidewalk starts at S Home to Harrison	SW1051-03	Broken surface material	Replace broken surface material and poor quality material	\$9,600	
SW1054		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to 411 Waddell	SW1054-01	Broken surface material	Replace broken surface material and poor quality material	\$13,200	
SW1051		South Home Street	Harrison Street	Y	Y	Sidewalk starts at S Home to Harrison	SW1051-02	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1054		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to 411 Waddell	SW1054-02	Missing sidewalk	Construct sidewalk where missing	\$10,200	
SW1050		South Home Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1052		Harrison Street	South Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1053		South Ury Street	South Division Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Waddell Street Remediation Estimated Costs:										\$41,600	
SW1057	Exchange Street	South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to 1021 Exchange	SW1057-02	Broken surface material	Sidewalk limited in sidewalk segment: remediation not recommended	\$0	
SW1058		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to Adams	SW1058-01	Broken surface material	Sidewalk limited in sidewalk segment: remediation not recommended	\$0	
SW1059		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1059-02	Broken surface material	Replace broken surface material and poor quality material from Adams to 912	\$12,000	
SW1060		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1060-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW1060		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1060-04	Broken surface material	Replace broken surface material and poor quality material	\$1,500	
SW1060		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1060-05	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1061		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbins	SW1061-03	Broken surface material	Replace broken surface material and poor quality material	\$300	
SW1061		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbins	SW1061-05	Broken surface material	Replace broken surface material and poor quality material	\$300	
SW1062		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbins	SW1062-02	Broken surface material	Replace broken surface material and poor quality material	\$300	
SW1062		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbins	SW1062-03	Broken surface material	Replace broken surface material and poor quality material	\$900	

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW1062	Exchange Street	South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1062-05	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW1063		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1063-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1063		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1063-03	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW1064		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1064-01	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW1064		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1064-02	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW1064		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1064-03	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW1064		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1064-04	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW1064		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1064-05	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1065		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW1065-01	Broken surface material	Replace broken surface material and poor quality material	\$5,400
SW1065		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW1065-02	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW1066		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW1066-01	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1067		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW1067-02	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW1068		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW1068-02	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW1069		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1069-01	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1069		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1069-02	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW1069		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1069-03	Broken surface material	Replace broken surface material and poor quality material	\$300
SW1069		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1069-04	Broken surface material	Replace broken surface material and poor quality material	\$3,300
SW1069		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1069-05	Broken surface material	Replace broken surface material and poor quality material	\$3,000
SW1070		South Ury Street	South Division Street	Y	Y	Sidewalk starts at S Ury to S Division	SW1070-01	Broken surface material	Replace broken surface material and poor quality material	\$11,400
SW1057		South Taylor Street	Adams Street	Y	Y	Sidewalk starts at S Taylor to 1021 Exchange	SW1057-01	Curb Ramp	Sidewalk limited in sidewalk segment: remediation not recommended	\$0
SW1059		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1059-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1059		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1059-03	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1060		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1060-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1060		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1060-06	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1061		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1061-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$0
SW1061		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1061-06	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1062		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1062-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1062		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1062-06	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800
SW1061		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1061-02	Drive Ramp	Construct a compliant drive ramp	\$3,600
SW1066		South Home Street	South Morgan Street	Y	Y	Sidewalk starts at S Home to S Morgan	SW1066-02	Drive Ramp	Construct a compliant drive ramp	\$3,150
SW1068		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW1068-03	Drive Ramp	Replace drive ramp	\$1,500
SW1061		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1061-04	Grass	Edge and trim grass; clean expansion joints	\$0
SW1055		Beginning of Street	South Taylor Street	Y	Y	Sidewalk starts and ends at 1204 Exchange	SW1055-01	NA	Sidewalk limited to one property; No remediation required	\$0
SW1056		Beginning of Street	South Taylor Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1071		South Division Street	Railroad Tracks	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1072		South Division Street	Railroad Tracks	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1067		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW1067-01	Run slope	Replace sidewalk	\$1,500
SW1068		South Morgan Street	South Ury Street	Y	Y	Sidewalk starts at S Morgan to S Ury	SW1068-01	Run slope	Replace sidewalk	\$2,700
SW1062		South Clover Street	South Dobbins Street	Y	Y	Sidewalk starts at S Clover to S Dobbin	SW1062-04	Settling	Replace sidewalk where settled	\$600
SW1063		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1063-04	Shrub	Trim Shrubs	\$500
SW1060		Adams Street	South Clover Street	Y	Y	Sidewalk starts at Adams to S Clover	SW1060-02	Tree	Trim trees	\$500
SW1063		South Dobbins Street	South Home Street	Y	Y	Sidewalk starts at S Dobbin to S Home	SW1063-01	Tree	Trim trees	\$500
Exchange Street Remediation Estimated Costs:										\$103,450
SW1073	Beck Street	East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1074		High Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1075		High Street	End of Street	Y	Y	Sidewalk starts and ends on side yard of 1209 High	SW1075-01	NA	No remediation recommended	\$0
SW1076		High Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Exchange Street Remediation Estimated Costs:										\$0
SW1077	Adams Street	East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW1077-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$13,200
SW1078		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW1078-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$13,200

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)	
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification			
SW1079	Adams Street	Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1079-01	Broken surface material	Replace broken surface material and poor quality material for entire street segment	\$13,800	
SW1080		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1080-01	Broken surface material	Replace broken surface material and poor quality material	\$5,700	
SW1082		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to 312 Adams	SW1082-01	Broken surface material	No remediation recommended; Partial street segment sidewalks	\$0	
SW1081		East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1083		High Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1084		High Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Adams Street Remediation Estimated Costs:										\$45,900	
SW1085	Royal Street	Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1086				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Royal Street Remediation Estimated Costs:										\$0	
SW1087	North Taylor Street	Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1094				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1095		East Vine Street	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1096				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
North Taylor Street Remediation Estimated Costs:										\$0	
SW1098	South Taylor Street	East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW1098-01	Broken surface material	Replace broken surface material and poor quality material	\$4,200	
SW1100		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1100-02	Broken surface material	Replace broken surface material and poor quality material	\$900	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-04	Broken surface material	Replace broken surface material and poor quality material	\$1,500	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-06	Broken surface material	Replace broken surface material and poor quality material	\$2,100	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-08	Broken surface material	Replace broken surface material and poor quality material	\$4,500	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-10	Broken surface material	Replace broken surface material and poor quality material	\$4,200	
SW1102		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW1102-01	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1102		East Church Street	High Street	Y	Y	Sidewalk starts at E Church to High	SW1102-02	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-01	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-03	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-05	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-07	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1103		High Street	East Florida Avenue	Y	Y	Sidewalk starts at High to E Florida	SW1103-09	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1100		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1100-01	Missing sidewalk	Replace sidewalk where missing	\$600	
SW1097			East Main Street	Exchange Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1099			Exchange Street	East Church Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1101			East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1104			High Street	East Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
South Taylor Street Remediation Estimated Costs:										\$20,600	
SW1105	North Glendale Street	East Mercer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1106				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
North Glendale Street Remediation Estimated Costs:										\$0	
SW1107	North Dobbins Street	East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1107-03	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW1107		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1107-04	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW1107		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1107-06	Broken surface material	Replace broken surface material and poor quality material	\$1,800	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-03	Broken surface material	Replace broken surface material and poor quality material	\$1,800	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-05	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-06	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-07	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-08	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1109		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1109-01	Broken surface material	Replace broken surface material and poor quality material	\$2,700	
SW1109		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1109-02	Broken surface material	Replace broken surface material and poor quality material	\$0	
SW1109		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1109-05	Broken surface material	Replace broken surface material and poor quality material	\$2,700	
SW1110		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1110-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200	
SW1110		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1110-03	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1110		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1110-04	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-01	Curb Ramp	Construct 2 perpendicular ramps; Add yellow truncated domes	\$2,800	
SW1107		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1107-05	Drive Ramp	Replace drive ramp	\$4,200	
SW1109		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1109-04	Drive Ramp	Replace with a compliant drive ramp	\$3,300	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-02	Fire hydrant	Construct sidewalk around hydrant to provide a clear 4 ft pathway	\$1,200	
SW1107		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1107-01	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1108		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1108-04	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1109		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1109-03	Grass	Edge and trim grass; clean expansion joints	\$800	
SW1111			Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	PIN# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW1112	North Dobbins Street	Dr Martin Luther King Jr Drive	East Vine Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1110		East College Street	Dr Martin Luther King Jr Drive	Y	Y	Sidewalk starts at E College to MLK	SW1110-01	Pathway too Narrow	Construct a street bubble with curb and gutter and sidewalk to provide a 4 ft minimum clear pedestrian sidewalk pathway	\$5,000
SW1107		East Gibbs Street	East College Street	Y	Y	Sidewalk starts at E Gibbs to E College	SW1107-02	Settling	Replace sidewalk where settled	\$900
North Dobbins Street Remediation Estimated Costs:										\$35,400
SW1113	South Dobbins Street	East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW1113-01	Broken surface material	Replace broken surface material and poor quality material from E Main to and include alley	\$7,800
SW1113		East Main Street	Exchange Street	Y	Y	Sidewalk starts at E Main to Exchange	SW1113-02	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW1115		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1115-01	Broken surface material	Replace broken surface material and poor quality material	\$5,100
SW1115		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1115-02	Broken surface material	Replace broken surface material and poor quality material	\$2,100
SW1116		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1116-01	Broken surface material	No remediation recommended; sidewalk serves only one property	\$0
SW1115		Exchange Street	East Church Street	Y	Y	Sidewalk starts at Exchange to E Church	SW1115-03	Drive Ramp	Replace drive ramp and alley drive with a compliant drive ramp	\$6,300
SW1114		East Main Street	Exchange Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1117		East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1118		East Church Street	High Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
South Dobbins Street Remediation Estimated Costs:										\$23,100
SW1119	Russell Street	East Summer Street	East Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1120				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1121		East Florida Avenue	East Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1122			East High School Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1123		East Bransford Street	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1124		East High School Drive	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1125		East Oak Street	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1126				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1127		East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1128			N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Russell Street Remediation Estimated Costs:										\$0
SW1129	Edwards Street	East Summer Street	East Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1130				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1131		East Florida Avenue	East Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1132				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1133		East Bransford Street	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1134				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1135		East Oak Street	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1136				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1137		East Bishop Street	East Reelfoot Avenue	N	Y	No Sidewalk in street segment, ped signal at E Reelfoot	NA	NA	No Barriers	\$0
SW1138		East Bishop Street	East Reelfoot Avenue	N	Y	No Sidewalk in street segment, ped signal at E Reelfoot	NA	NA	No Barriers	\$0
SW1139		East Reelfoot Avenue	Sherrill Street	N	Y	No Sidewalk in street segment, ped signal at E Reelfoot	NA	NA	No Barriers	\$0
SW1140		East Reelfoot Avenue	Honeysuckle Street	N	Y	No Sidewalk in street segment, ped signal at E Reelfoot	NA	NA	No Barriers	\$0
SW1141		Sherrill Street	Nelson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1142		Honeysuckle Street	Ethridge Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1143		Nelson Street	City Limits (across from Ethridge)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1144		Ethridge Street	Turner Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1145		Turner Street	Polk Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Edwards Street Remediation Estimated Costs:										\$0
SW1146	Woodlawn Street	East Summer Street	East Florida Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1147				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1148		East Florida Avenue	East Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1149				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1150		East Bransford Street	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1151				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1152		East Oak Street	Woodlawn Place	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1284		Woodlawn Place	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1153		East Oak Street	East Bishop Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1154			N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1155	East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Woodlawn Street Remediation Estimated Costs:										\$0
SW1156	Whirmantler Street	East Florida Avenue	East Bransford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1157				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1158		East Bransford Street	East Oak Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1159				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Whirmantler Street Remediation Estimated Costs:										\$0
SW1160	North Bank Street	East Gibbs Street	East Palmer Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1161				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1162		East Palmer Street	East College Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1163				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1164		East College Street	Dr Martin Luther King Jr Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1165				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
North Bank Street Remediation Estimated Costs:										\$0
SW1168	Perkins Street	Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1168-01	Broken surface material	Replace broken surface material and poor quality material	\$2,400
SW1168		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1168-02	Broken surface material	Replace broken surface material and poor quality material	\$1,200
SW1168		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1168-03	Broken surface material	Replace broken surface material and poor quality material	\$1,800
SW1168		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1168-04	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1169		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1169-01	Broken surface material	Replace broken surface material and poor quality material	\$300
SW1169		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1169-02	Broken surface material	Replace broken surface material and poor quality material	\$600
SW1169		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1169-04	Broken surface material	Replace broken surface material and poor quality material	\$1,500
SW1170		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW1170-01	Broken surface material	Replace broken surface material and poor quality material	\$900
SW1170		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW1170-02	Broken surface material	Replace broken surface material and poor quality material	\$2,700
SW1170		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW1170-03	Broken surface material	Replace broken surface material and poor quality material	\$3,600
SW1171		East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW1171-01	Broken surface material	Replace broken surface material and poor quality material	\$900

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)	
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification			
SW1171	Perkins Street	East Florida Avenue	East Bransford Street	Y	Y	Sidewalk starts at E Florida to e Bransford	SW1171-02	Broken surface material	Replace broken surface material and poor quality material	\$600	
SW1172		East Bransford Street	East Park Street	Y	Y	Sidewalk starts at 929 Perkins to E Park	SW1172-01	Broken surface material	Sidewalk limited in sidewalk segment: remediation not recommended	\$0	
SW1173		East Park Street	East Jackson Street	Y	Y	Sidewalk starts at E Park to 1008 Perkins	SW1173-01	Broken surface material	Sidewalk limited in sidewalk segment: remediation not recommended	\$0	
SW1169		Harrison Street	East Florida Avenue	Y	Y	Sidewalk starts at Harrison to E Florida	SW1169-03	Grass	Edge and trim grass; clean expansion joints	\$200	
SW1166		East Church Street	Harrison Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1167		East Church Street	Harrison Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1174		East Bransford Street	East Jackson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1175		East Jackson Street	Wade Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1176		Wade Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1177	East Jackson Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
Perkins Street Remediation Estimated Costs:										\$17,600	
SW1178	Nailing Drive	City Limits	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1179		Entry-Exit Ramp	Entry-Exit Ramp	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1180			Entry-Exit Ramp	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1181		Section Line Road	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1182		Section Line Road	Bethlehem Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1183		Section Line Road	Hayes Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1184		Section Line Road	Hayes Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1185		Section Line Road	Stevens Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1186		Section Line Road	North Ford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1187		Section Line Road	Bethlehem Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1188	Section Line Road	North Ford Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
SW1189	Section Line Road	North Miles Street	Nash Street/East Main	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Nailing Drive Remediation Estimated Costs:										\$0	
SW1190	Stevens Street	Nailing Drive	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1191		Wilma Drive	Wilma Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1192			Wilma Drive	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Stevens Street Remediation Estimated Costs:										\$0	
SW1193	Wilma Drive	End of Street	Stevens Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1194		End of Street	Stevens Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Wilma Drive Remediation Estimated Costs:										\$0	
SW1195	Hayes Street	Section Line Road	Nailing Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1196		Section Line Road	Nailing Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Hayes Street Remediation Estimated Costs:										\$0	
SW1197	Section Line Road	Nailing Drive	Hayes Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1198		Nailing Drive	Old Harris Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1199		Nailing Drive	Country Wood	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1200		Nailing Drive	Old Harris Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1201		Nailing Drive	Country Wood	Town and Country Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1202		Nailing Drive	Town and Country Road	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1203		Nailing Drive	Knox Daniel Road (McConnell Road)	Tyson Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1204		Nailing Drive	East Main Street	Norwood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1205		Nailing Drive	Tyson Drive	Woodfin Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1206		Nailing Drive	Woodfin Road	Burrus Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1207		Nailing Drive	Norwood Drive	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1208		Nailing Drive	Burrus Street	Vernon Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1209	Nailing Drive	Vernon Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Section Line Road Remediation Estimated Costs:										\$0	
SW1210	Old Harris Road	City Limits	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1211		City Limits	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Old Harris Road Remediation Estimated Costs:										\$0	
SW1212	Country Wood	Section Line Road	Sunnyview Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1213		Section Line Road	Sunnyview Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Country Wood Remediation Estimated Costs:										\$0	
SW1214	Sunnyview Road	Cul-de-Sac	Country Wood	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1215		Cul-de-Sac	Country Wood	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1216		Country Wood	Town and Country Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1217			Town and Country Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Sunnyview Road Remediation Estimated Costs:										\$0	
SW1218	Town and Country Road	Section Line Road	Sunnyview Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1219		Sunnyview Road	N-S Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1220			Sunnyview Road	Stevens Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1221		Stevens Street	N-S Turn (Unnamed Road)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1222		N-S Turn (Unnamed Road)	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1223		N-S Turn	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Town and Country Road Remediation Estimated Costs:										\$0	
SW1224	Knox Daniel Road	Gibbs Road (City Limits)	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1225		City Limits (350 feet east of Section Line)	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Knox Daniel Road (McConnell Road) Remediation Estimated Costs:										\$0	
SW1226	Gibbs Road	Knox Daniel Road (McConnell Road)	Tyson Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1227		Knox Daniel Road (McConnell Road)	Tyson Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1228		Tyson Drive	Lantern Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1229		Lantern Lane	Lynn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1230		Tyson Drive	Lynn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Gibbs Road Remediation Estimated Costs:										\$0	
SW1231	Tyson Drive	Gibbs Road	Entry Ramp (SR22)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1232		Gibbs Road	Exit Ramp (SR22)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1233		Entry Ramp (SR22)	Exit Ramp (SR22)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1234		Exit Ramp (SR22)	Entry Ramp (SR22)	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1235		Section Line Road	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1236		Entry Ramp (SR22)	Gibbs Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1237		Gibbs Road	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Tyson Drive Remediation Estimated Costs:										\$0	
SW1238	Unnamed Access Road to Soccer Fields	East Main Street	Playground Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1239		Playground Entrance	Baseball Field Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1240		Baseball Field Entrance	Soccer Field Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1241		Soccer Field Entrance	Picnic Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1242		Picnic Entrance	Norwood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1243		East Main Street	Norwood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Unnamed Access Road to Soccer Fields Remediation Estimated Costs:										\$0	
SW1244	Norwood Drive	Section Line Road	Unnamed Access Road to Soccer Fields	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1245		Section Line Road	Elm Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1246		Section Line Road	Highland Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1247		Unnamed Access Road to Soccer Fields	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1248		Highland Avenue	Circle Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1249	Circle Drive	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0		
Norwood Drive Remediation Estimated Costs:										\$0	
SW1250	Evergreen Street	Cul-de-Sac	Elm Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1251		Cul-de-Sac	Byrn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1252		Cul-de-Sac	Elm Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Evergreen Street Remediation Estimated Costs:										\$0	

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)	
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification			
SW1253	Carol Street	Baptist Church Parking Lot	Byrn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1254				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1255		Byrn Street	Elm Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1256				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Carol Street Remediation Estimated Costs:											\$0
SW1257	Elm Street	Norwood Drive	Carol Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1258			Evergreen Street	Evergreen Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1259		Evergreen Street	Carol Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Elm Street Remediation Estimated Costs:											\$0
SW1260	Highland Avenue	Norwood Drive	Circle Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1261				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1262		Circle Drive	Longview Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1263		Longview Road	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1264		Circle Drive	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Highland Avenue Remediation Estimated Costs:											\$0
SW1265	Circle Drive	Norwood Drive	Highland Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1266				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1267		Highland Avenue	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1268				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Circle Drive Remediation Estimated Costs:											\$0
SW1269	Longview Road	Highland Avenue	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1270				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Longview Road Remediation Estimated Costs:											\$0
SW1271	Woodfin Road	End of Street	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1272				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Woodfin Road Remediation Estimated Costs:											\$0
SW1273	Burrus Street	Cul-de-Sac	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1274			Fairway Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1275		Fairway Avenue	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Burrus Street Remediation Estimated Costs:											\$0
SW1276	Vernon Street Extension	Cul-de-Sac	Fairway Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1277				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1278		Fairway Avenue	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1279		Fairway Avenue	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Vernon Street Extension Remediation Estimated Costs:											\$0
SW1280	Vernon Street	McAdoo Circle	Section Line Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1281				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Vernon Street Remediation Estimated Costs:											\$0
SW1282	Lantern Lane	Gibbs Road	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1283				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Lantern Lane Remediation Estimated Costs:											\$0
SW1285	Walker Street	Lantern Lane	Lynn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1286				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Walker Street Remediation Estimated Costs:											\$0
SW1287	Lynn Street	Gibbs Road	Walker Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1288		Walker Street	Acorn Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1289		Acorn Drive	Lone Oak Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1290		Gibbs Road	Lone Oak Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1291		Lone Oak Drive	Unnamed Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1292		Unnamed Road	Fairway Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1293		Fairway Avenue	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1294		Lone Oak Drive	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Lynn Street Remediation Estimated Costs:											\$0
SW1295	Green Leaf Street	E-W Turn	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1296				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1297		Cul-de-Sac	Acorn Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1298				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Green Leaf Street Remediation Estimated Costs:											\$0
SW1299	Acorn Drive	Green Leaf Street	Lynn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1300				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Acorn Drive Remediation Estimated Costs:											\$0
SW1301	Lone Oak Drive	Cul-de-Sac	Lynn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1302				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1303		Lynn Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1304				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Lone Oak Drive Remediation Estimated Costs:											\$0
SW1305	Hillsboro Street	East Reelfoot Avenue	City Limits	Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1306				Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Hillsboro Street Remediation Estimated Costs:											\$0
SW1307	Webster Street	East Reelfoot Avenue	End of Street	Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1308				Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Webster Street Remediation Estimated Costs:											\$0
SW1309	Oakshire Road	East Reelfoot Avenue	City Limits	Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1310				Y	Y	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Oakshire Road Remediation Estimated Costs:											\$0
SW1311	Holiday Street	Cul-de-Sac	South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1312				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Holiday Street Remediation Estimated Costs:											\$0
SW1313	Starlight Drive	Cul-de-Sac	South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1314				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Starlight Drive Remediation Estimated Costs:											\$0
SW1315	Hillcrest Drive	Cul-de-Sac	Honeysuckle Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1316				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Hillcrest Drive Remediation Estimated Costs:											\$0
SW1317	Honeysuckle Street	Pleasant Valley Avenue	South Miles Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1318		South Miles Street	Hillcrest Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1319		Hillcrest Drive	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1320		Pleasant Valley Avenue	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1321		End of Street	Kris Lynndale Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1322		Kris Lynndale Drive	Mockingbird Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1323		Mockingbird Drive	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1324		End of Street	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Honeysuckle Street Remediation Estimated Costs:											\$0
SW1325	Mockingbird Drive	Cul-de-Sac	Honeysuckle Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1326				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Mockingbird Drive Remediation Estimated Costs:											\$0
SW1327	Kris Lynndale Drive	Cul-de-Sac	Honeysuckle Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1328				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Kris Lynndale Drive Remediation Estimated Costs:											\$0
SW1329	Stone Street	End of Street	Camden Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1330		Camden Street	South Sunswep Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1331		South Sunswep Drive	Pleasant Valley Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1332		End of Street	Pleasant Valley Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Stone Street Remediation Estimated Costs:											\$0
SW1333	Camden Street	Cul-de-Sac	Stone Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1334				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Camden Street Remediation Estimated Costs:											\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		Prowag PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	Prowag Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW1335	Ethridge Lane	Pleasant Valley Avenue	Wildwood Cove	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1336			Shatz Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1337		Shatz Road	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1338		Stonewall Drive	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1339		Wildwood Cove	Edwards Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Ethridge Lane Remediation Estimated Costs:										\$0
SW1340	Wildwood Cove	N-S Turn	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1341				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1342		N-S Turn	Ethridge Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1343				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Wildwood Cove Remediation Estimated Costs:										\$0
SW1344	Shatz Road	Ethridge Lane	Polk Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1345			Joe Moore Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1346		Polk Street	Henderson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1347		Henderson Street	Moss Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1348		Joe Moore Drive	Moss Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Shatz Road Remediation Estimated Costs:										\$0
SW1349	Polk Street	Shatz Road	Short Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1350		Stonewall Drive	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1351		Shatz Road	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1352		End of Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1353		Stonewall Drive	Meadowlark Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1354		Meadowlark Street	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Polk Street Remediation Estimated Costs:										\$0
SW1355	Short Street	Polk Street	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1356				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Short Street Remediation Estimated Costs:										\$0
SW1357	Henderson Street	Shatz Road	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1358			Wedgewood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1359			Wedgewood Drive	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers
Henderson Street Remediation Estimated Costs:										\$0
SW1360	Joe Moore Drive	Pleasant Valley Avenue	Shatz Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1361				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Joe Moore Drive Remediation Estimated Costs:										\$0
SW1362	Moss Avenue	Shatz Road	Wedgewood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1363				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Moss Avenue Remediation Estimated Costs:										\$0
SW1364	Wedgewood Drive	Henderson Street	Armstrong Boulevard	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1365			Moss Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1366		Moss Avenue	Armstrong Boulevard	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1367		Armstrong Boulevard	Berkshire Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1368		Berkshire Road	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1369				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1370	N			N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Wedgewood Drive Remediation Estimated Costs:										\$0
SW1371	Armstrong Boulevard	Pleasant Valley Avenue	Wedgewood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1372				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1373		Wedgewood Drive	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1374				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1375		Stonewall Drive	Meadowlark Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1376				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Armstrong Boulevard Remediation Estimated Costs:										\$0
SW1377	Oaklawn Street	Pleasant Valley Avenue	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1378				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Oaklawn Street Remediation Estimated Costs:										\$0
SW1379	Berkshire Road	Pleasant Valley Avenue	Wedgewood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1380			South Meade Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1381		South Meade Street	Wedgewood Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1382		Wedgewood Drive	Stonewall Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1383				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1384		Stonewall Drive	Grayson Circle	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1385				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Oaklawn Street Remediation Estimated Costs:										\$0
SW1386	Grayson Circle	Cul-de-Sac	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1387			Berkshire Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1388			Berkshire Road	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers
Grayson Circle Remediation Estimated Costs:										\$0
SW1389	Stonewall Drive	Ethridge Lane	Turner Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1390			Short Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1391		Turner Street	Polk Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1392		Short Street	Polk Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1393		Polk Street	Armstrong Boulevard	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1394			Henderson Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1395		Henderson Street	Armstrong Boulevard	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1396		Armstrong Boulevard	Berkshire Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1397				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1398		Berkshire Road	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1399	N			N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Grayson Circle Remediation Estimated Costs:										\$0
SW1400	Meadowlark Street	Polk Street	Armstrong Boulevard	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1401				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Meadowlark Street Remediation Estimated Costs:										\$0
SW1402	Julie Street	End of Street	Future Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1500		Future Road	Pleasant Valley Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1403		End of Street	Pleasant Valley Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Julie Street Remediation Estimated Costs:										\$0
SW1404	Lynch Lane	Water Treatment Plant	N-S Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1405				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1406		N-S Turn	E-W Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1407				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1408		E-W Turn	Valley Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1409			Dee Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1410		Valley Drive	Pleasant Valley Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1411	Dee Street	Pleasant Valley Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
Lynch Lane Remediation Estimated Costs:										\$0
SW1412	South Meade Street	Berkshire Road	End of Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1413				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
South Meade Street Remediation Estimated Costs:										\$0
SW1414	Stonehedge Boulevard	End of Street	Pleasant Valley Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1415				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Stonehedge Boulevard Remediation Estimated Costs:										\$0
SW1416	Pleasant Valley Avenue	East Reelfoot Avenue	Honeysuckle Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1417			Stone Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1418		Honeysuckle Street	Ethridge Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1419		Stone Street	Stonehedge Boulevard	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1420		Ethridge Lane	Joe Moore Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1421		Joe Moore Drive	Armstrong Boulevard	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin# remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW1422	Pleasant Valley Avenue	Armstrong Boulevard	Oaklawn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1423		Stonehedge Boulevard	Lynch Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1424		Oaklawn Street	Berkshire Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1425		Berkshire Road	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1426		Lynch Lane	Julie Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1427		Julie Street	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Pleasant Valley Avenue Remediation Estimated Costs:										\$0
SW1428	Phebus Lane	Old Troy Road	Jere B Ford Memorial Highway	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1429				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1430		Jere B Ford Memorial Highway	Walker Tanner Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1431				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Phebus Lane Remediation Estimated Costs:										\$0
SW1432	Walker Tanner Road	City Limits	Phebus Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1433			West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1434		Phebus Lane	Southlane Circle	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1435		Southlane Circle	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Walker Tanner Road Remediation Estimated Costs:										\$0
SW1436	Southlane Circle	Cul-de-Sac	Walker Tanner Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1437				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Southlane Circle Remediation Estimated Costs:										\$0
SW1438	Old Rives Road	West Reelfoot Avenue	Stad Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1439			Marshall Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1440		Marshall Avenue	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1441		Stad Avenue	Rutledge Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1442		Rutledge Lane	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Old Rives Road Remediation Estimated Costs:										\$0
SW1443	Rutledge Lane	Old Rives Road	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1444				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Rutledge Lane Remediation Estimated Costs:										\$0
SW1445	Stad Avenue	Old Rives Road	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1446				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Stad Avenue Remediation Estimated Costs:										\$0
SW1447	Marshall Avenue	Vaden Street	Old Rives Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1448				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Marshall Avenue Remediation Estimated Costs:										\$0
SW1449	Vaden Street	West Reelfoot Avenue	Marshall Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1450			E-W Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1451		Marshall Avenue	E-W Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1452		E-W Turn	N-S Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1453		E-W Turn	N-S Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1505		N-S Turn	E-W Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1506		N-S Turn	Lowe's Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1507		E-W Turn	N-S Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1508		Lowe's Entrance	Lowe's Entrance	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1509		N-S Turn	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1510		Lowe's Entrance	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Vaden Street Remediation Estimated Costs:										\$0
SW1454	Lannom Lane	End of Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1455		End of Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Lannom Lane Remediation Estimated Costs:										\$0
SW1456	Old Troy Road	West Reelfoot Avenue	Bel Aire Circle	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1457			Phebus Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1458		Phebus Lane	Calron Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1459		Bel Aire Circle	City Limits	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Old Troy Road Remediation Estimated Costs:										\$0
SW1460	Bel Aire Circle	Pine Tree Road	Hart Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1461			Hart Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Bel Aire Circle Remediation Estimated Costs:										\$0
SW1462	Pine Tree Road	Bel Aire Circle	Bel Aire Circle	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1463				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Pine Tree Road Remediation Estimated Costs:										\$0
SW1464	Hart Drive	Bel Aire Circle	Bel Aire Circle	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1465				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Hart Drive Remediation Estimated Costs:										\$0
SW1466	Bel Aire Circle	Hart Drive	Old Troy Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1467		Pine Tree Road	Old Troy Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Bel Aire Circle Remediation Estimated Costs:										\$0
SW1468	Westgate Drive	West Main Street	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1469				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Westgate Drive Remediation Estimated Costs:										\$0
SW1470	Jere B Ford Memorial Highway	City Limits	Mount Zion Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1471				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Jere B Ford Memorial Highway Remediation Estimated Costs:										\$0
SW1472	Everett Boulevard	Mount Zion Road	Graham Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1473			N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0	
SW1474		Graham Drive	West Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1475				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1476		West Main Street	West Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1477				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Everett Boulevard Remediation Estimated Costs:										\$0
SW1478	Bethlehem Road	City Limits	Nailing Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1479			Sunrise Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1480		Sunrise Street	Morning View Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1481		Morning View Street	Nailing Drive	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Bethlehem Road Remediation Estimated Costs:										\$0
SW1482	Sunrise Street	Morning View Street	Bethlehem Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1483				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Sunrise Street Remediation Estimated Costs:										\$0
SW1484	Morning View Street	End of Street	Sunrise Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1485			E-W Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1486		Sunrise Street	E-W Turn	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1487		E-W Turn	Bethlehem Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1488				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Morning View Street Remediation Estimated Costs:										\$0
SW1490	McAdoo Circle	Vernon Street	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1491				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
McAdoo Circle Remediation Estimated Costs:										\$0
SW1492	Byrn Street	Evergreen Street	Carol Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1493				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1494		Carol Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1495				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Byrn Street Remediation Estimated Costs:										\$0
SW1496	Fairway Avenue	Burrus Street	Vernon Street Extension	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1497				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1498		Vernon Street Extension	Lynn Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1499				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Fairway Avenue Remediation Estimated Costs:										\$0
SW1501	Valley Drive	Cul-de-Sac	Lynch Lane	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1502				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Valley Drive Remediation Estimated Costs:										\$0

UNION CITY SIDEWALK BARRIERS

STREET SEGMENT LOCATION						STREET SEGMENT COMPLIANCE	INDIVIDUAL ITEM BARRIER LOCATION		PROWAG PIN Item Remediation Comments	Pin#f remediation cost est (\$)
Street Segment Number	Mainstreet Name	From Street Segment Sidestreet	To Street Segment Sidestreet	Sidewalk Exists Yes (Y) or No (N)	Barriers in Sidewalk Segment Yes (Y) or No (N)	PROWAG Street Segment Barrier Evaluation Comments	Barrier PIN ID	Barrier Classification		
SW1503	Dee Street	Lynch Lane	Cul-de-Sac	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1504				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Dee Street Remediation Estimated Costs:										\$0
SW1532	East Todd Street	North Glendale Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1533				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1534		North Clover Street	North Division Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1535				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1536		North Home Street	North Morgan Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1537				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1511		North Morgan Street	North Ury Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1512				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1513		North Division Street	North Baker Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1514				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
		North Baker Street	North Baker Street	Y	Y	Sidewalk starts at N Baker to N Baker	NA	NA	Sidewalk limited in sidewalk segment: remediation not recommended	\$0
East Todd Street Remediation Estimated Costs:										\$0
SW1515	Jordan Terrace	End of Street	North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1516			Future Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1517		Future Road	Future Road	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1518			North Clover Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Jordan Terrace Remediation Estimated Costs:										\$0
SW1519	Parkview Street	End of Street	East Vine Saint Extension	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1520			East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1521			East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Parkview Street Remediation Estimated Costs:										\$0
SW1522	East Vine Saint Extension	Parkview Street	Chivers Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1523		Parkview Street	Chivers Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
East Vine Saint Extension Remediation Estimated Costs:										\$0
SW1524	Chivers Street	End of Street	East Vine Saint Extension	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1525				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1526		East Vine Saint Extension	East Main Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1527				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
Chivers Street Remediation Estimated Costs:										\$0
SW1528	South Sunswept Drive	East Bishop Street	East Reelfoot Avenue	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1529				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1530		East Reelfoot Avenue	Stone Street	N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
SW1531				N	N	No Sidewalk in street segment	NA	NA	No Barriers	\$0
South Sunswept Drive Remediation Estimated Costs:										\$0
Total Union City Street Segment Barrier Remediation Costs:										\$5,182,256

UNION CITY PEDESTRIAN SIGNALS

Signal # (click for aerial view of intersection)	Pin #	LOCATION PHOTOGRAPH Geotagged to PIN	Mainstreet Name	Sidestreet	Compass Direction of Pedestrian Signal at Intersection	Compliant Yes (Y)/No (N)	NON-COMPLIANCE ISSUES			REMEDATION			
							INTERSECTION TYPE (T, Y OR 4 WAY)	ACCESSIBILITY COMMENT	PROWAG Remediation Recommendation	ADD ISLAND OR MEDIAN PEDESTRIAN PATHWAY SPACE (PPS REM) FOR WIDER OR ANGLE CROSSINGS OR LEVELING SURFACE (REMEDATION DIMENSION AREA IN SQUARE FEET)	ISLAND OR MEDIAN PEDESTRIAN PATHWAY SPACE (PPS REM) TOTAL REMEDIATION COST ESTIMATE (\$)	LOCATOR TONES, AUDIBLE AND TACTILE ARROWS, PED BUTTONS AND SIGNS REMEDIATION COST ESTIMATE (\$)	TOTAL REMEDIATION COST ESTIMATE (\$)
SIG1	PS001	https://www.google.co	East Reelfoot Avenue	Edwards Street	NE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator. Level Surface.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	25	\$625	\$3,000	\$3,625
	PS002	https://www.google.co	Edwards Street	East Reelfoot Avenue	NE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS003	https://www.google.co	East Reelfoot Avenue	Edwards Street	SE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS004	https://www.google.co	Edwards Street	East Reelfoot Avenue	SE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS005	https://www.google.co	East Reelfoot Avenue	Edwards Street	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS006	https://www.google.co	Edwards Street	East Reelfoot Avenue	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS007	https://www.google.co	East Reelfoot Avenue	Edwards Street	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator. Surface not level.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows. Level Surface	25	\$625	\$3,000	\$3,625
	PS008	https://www.google.co	Edwards Street	East Reelfoot Avenue	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
SIG2	PS009	https://www.google.co	East Reelfoot Avenue	South Home Street	NE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator. Surface not level.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows. Level Surface	30	\$750	\$3,000	\$3,750
	PS010	https://www.google.co	South Home Street	East Reelfoot Avenue	NE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS011	https://www.google.co	East Reelfoot Avenue	South Home Street	SE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator. Surface not level.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows. Level Surface	30	\$750	\$3,000	\$3,750
	PS012	https://www.google.co	South Home Street	East Reelfoot Avenue	SE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS013	https://www.google.co	East Reelfoot Avenue	South Home Street	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator. Surface not level.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows. Level Surface	30	\$750	\$3,000	\$3,750
	PS014	https://www.google.co	South Home Street	East Reelfoot Avenue	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS015	https://www.google.co	East Reelfoot Avenue	South Home Street	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator. Surface not level.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows. Level Surface	30	\$750	\$3,000	\$3,750
	PS016	https://www.google.co	South Home Street	East Reelfoot Avenue	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000

UNION CITY PEDESTRIAN SIGNALS

Signal # (click for aerial view of intersection)	Pin #	LOCATION PHOTOGRAPH Geotagged to PIN	Mainstreet Name	Sidestreet	Compass Direction of Pedestrian Signal at Intersection	Compliant Yes (Y)/No (N)	NON-COMPLIANCE ISSUES			REMEDATION			
							INTERSECTION TYPE (T, Y OR 4 WAY)	ACCESSIBILITY COMMENT	PROWAG Remediation Recommendation	ADD ISLAND OR MEDIAN PEDESTRIAN PATHWAY SPACE (PPS REM) FOR WIDER OR ANGLE CROSSINGS OR LEVELING SURFACE (REMEDATION DIMENSION AREA IN SQUARE FEET)	ISLAND OR MEDIAN PEDESTRIAN PATHWAY SPACE (PPS REM) TOTAL REMEDIATION COST ESTIMATE (\$)	LOCATOR TONES, AUDIBLE AND TACTILE ARROWS, PED BUTTONS AND SIGNS REMEDIATION COST ESTIMATE (\$)	TOTAL REMEDIATION COST ESTIMATE (\$)
SIG3	PS017	https://www.google.co	Jere B Ford Memorial Highway	North Clover Street	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS018	https://www.google.co	Jere B Ford Memorial Highway	North Clover Street	W	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS019	https://www.google.co	Jere B Ford Memorial Highway	North Clover Street	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS020	https://www.google.co	Jere B Ford Memorial Highway	North Clover Street	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
SIG4	PS021	https://www.google.com/	East Reelfoot Avenue	Section Line Road	NW	N	T	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS022	https://www.google.co	East Reelfoot Avenue	Section Line Road	SW	N	T	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator. Surface not level.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows. Level Surface	25	\$625	\$3,000	\$3,625
SIG5	PS023	No Street View Available	West Jackson Street	South 1st Street	NE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS024	No Street View Available	West Jackson Street	South 1st Street	SE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS025	No Street View Available	West Jackson Street	South 1st Street	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS026	No Street View Available	West Jackson Street	South 1st Street	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
SIG6	PS027	https://www.google.co	South 1st Street	East Church Street	NE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS028	https://www.google.co	East Church Street	South 1st Street	NE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS029	https://www.google.co	South 1st Street	East Church Street	SE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS030	https://www.google.co	East Church Street	South 1st Street	SE	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS031	https://www.google.co	South 1st Street	West Church Street	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS032	https://www.google.co	West Church Street	South 1st Street	SW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS033	https://www.google.co	South 1st Street	West Church Street	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
	PS034	https://www.google.co	West Church Street	South 1st Street	NW	N	4-Way	Button is not 2" directional, Ped does not have audio/vibratory signals and signal locator.	Add compliant locator signals, audible and tactile indicators, add 2" ped button directional arrows	0	\$0	\$3,000	\$3,000
SIG7	PS035	https://www.google.co	West Reelfoot Avenue	Everett Boulevard	--	N	T	No functionality, not usable as is.	Remove signal button	0	\$0	\$500	\$500
Union City Pedestrian Signal Remediation Cost:													\$107,375

ATTACHMENT D – PUBLIC INVOLVEMENT



Mayor and City Council

The City of Union City recognizes public participation is an important component in the development of this document. Input from the community has been gathered and used to help define priority areas for improvements within the jurisdiction of the City.

As part of the ADA Transition Plan's development process, the City posted the draft plan document on its website, <http://unioncitytn.gov//ADA-Transition-Plan> and made it available for public comment for a period of ten business days in November of 2019.

A link to the plan was also distributed via email to school districts, medical facilities, and other public agencies with facilities in Union City. A list of stakeholder contacts is presented in the next section.

CITY OF UNION CITY TO CONDUCT A PUBLIC MEETING CONCERNING ADA COMPLIANCE AND TRANSITION PLAN

The City of Union City held a public meeting on the development of their ADA Compliance and Transition Plan on Tuesday, November 19, 2019 from 5:30pm – 6:00pm at the Union City, City Hall, 408 South Depot Street, Union City, TN 38261 to provide an opportunity for the public to participate in the development of the City's Americans with Disabilities Act (ADA compliance and transition plan). The draft plan will be available on the City's website at www.unioncitytn.gov.

The Americans with Disabilities Act (ADA) is a civil rights law that prohibits discrimination against individuals with disabilities in all areas of public life, including jobs, schools, transportation, and all places that are open to the public. ADA became law in 1990. In 2008, the Americans with Disabilities Act Amendments Act (ADAAA) was signed into law and became effective on Jan. 1, 2009. For more information visit the ADA homepage at <https://www.ada.gov/>.

Persons with disabilities requiring special accommodations should contact Jim Temple, Director of Planning and Codes, 408 S. Depot St., Union City, TN 38261, 731/885-0918 (Direct Office), 731/885-1341 (City Hall), 731-446-0848 (Cell), planning.codesdirector@unioncitytn.gov

In accordance with the requirements of Title II of the Americans with Disabilities Act of 1990 ("ADA"), the City of Union City does not discriminate against individuals with disabilities on the basis of disability in its services, programs, or activities.

The advertised meeting was held on November 19, 2019, with no one other than City Officials in attendance. No comments were received.